Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/12/13

WINDOW HEAD DETAIL-6TH FLOOR
3" = 1'-0"

WINDOW HEAD DETAIL-3RD/4TH/5TH FLOORS
3" = 1'-0"

HEAD DETAIL-STONE LINTEL
3" = 1'-0"

3 / A21.1 HOTEL WINDOW DETAIL-2ND FLOOR WINDOWS
3" = 1'-0"

WINDOW JAMB DETAIL-6TH FLOOR
3" = 1'-0"

PROVIDE END DAM FLASHING AT ALL LOCATIONS WHERE THE FLASHING DETAIL IS NOT CONTINUOUS BEYOND THE LINTEL OR OPENING.

PROVIDE SEALANT & BACKER ROD AT ALL WINDOW/STOREFRONT/CURTAIN WALL OPENINGS FULL PERIMETER OF OPENING AT INTERIOR AND EXTERIOR OF FRAME.

WINDOW JAMB DETAIL-2ND/3RD/4TH/5TH FLOORS
3" = 1'-0"

HEAD DETAIL-STONE LINTEL
3" = 1'-0"

4 / A21.1 HOTEL STOREFRONT DETAIL-1ST FLOOR
3" = 1'-0"

WINDOW SILL DETAIL-6TH FLOOR
3" = 1'-0"

1 / A21.1 RESIDENCE WINDOW DETAILS
3" = 1'-0"

2 / A21.1 HOTEL WINDOW DETAILS
3" = 1'-0"

HEAD DETAIL-STONE LINTEL
3" = 1'-0"

5 / A21.1 HOTEL CURTAIN WALL DETAIL-2 STORY CURTAIN WALL
3" = 1'-0"

LICENSED ARCHITECT
DONALD W. BLAJDA
No. 2936
STATE OF MAINE

REVISION SCHEDULE

DATE	REVISION DESCRIPTION	BY
05-20-13	ADDED CLIPS AND ANCHORS FOR GRANITE SILLS & LINTELS	
05-24-13	REVISED WOOD BLOCKING AT WINDOW HEAD DETAILS.	
06-13-13	REVISED WINDOW DETAIL 5/A21.1, ADDED SEALANT AND BACKER ROD TO INTERIOR SIDE OF FRAMES.	

© COPYRIGHT 2012 BY O.C.C.

CONSTRUCTION CORPORATION
11 CORPORATE DRIVE, BELMONT NH 03220
PHONE (603) 527-9090 FAX (603) 527-9191

WINDOW DETAILS

PROJECT:
COMMERCIAL & MAPLE STREET
MIXED USE DEVELOPMENT
PORTLAND, ME

DATE: 05-09-13
SCALE: SEE PLAN
DRAWN BY: KPH
A21.1
SHEET: