Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/12/13

AT UNDERSIDE OF 6TH FLOOR STRUCTURE (IN ADDITION TO CEILING TYPES SHOWN)-PROVIDE (1) LAYER OF 1/2" 440 SOUNDBARRIER BY HOMASOTE OR EQUALON 25 GA 7/8" FURRING CHANNELS AT 24" O.C. TIED TO JOIST BOTTOM CHORDS W/ 12 GAG HANGER WIRE. 6" LAYER OF THERMAFIBER SOUND ATTENUATION FIRE BLANKETS (SAFB) OR EQUAL FITTED TIGHTLY IN PLACE BETWEEN JOISTS (NO VOIDS).

1 A26 FIFTH FLOOR CEILING PLAN
1/8" = 1'-0"

LICENSED ARCHITECT
DONALD W. BLAJDA
No. 2936
STATE OF MAINE

REVISION SCHEDULE		
DATE	REVISION DESCRIPTION	BY

© COPYRIGHT 2012 BY O.C.C.

COPECHEE
CONSTRUCTION CORPORATION
11 CORPORATE DRIVE, BELMONT NH 03220
PHONE (603)527-9090 FAX (603)527-9191

FIFTH FLOOR CEILING PLAN

PROJECT:
COMMERCIAL & MAPLE STREET
MIXED USE DEVELOPMENT
PORTLAND, ME

DATE: 05-09-13
SCALE: SEE PLAN
DRAWN BY: KPH

SHEET: A26