Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/12/13

NOTES (WALL SECTIONS):

1. TYPICAL EXTERIOR WALL CONSTRUCTION-SEE WALL TYPE 1 ON DWG. A0.4
2. TYPICAL ROOF CONSTRUCTION-EPDM MEMBRANE, 4" POLYISOCYANURATE INSULATION, METAL DECK
3. ALUMINUM WINDOW UNIT-SEAL PERIMETER @ INTERIOR AND EXTERIOR
4. METAL CLAD WOOD WINDOW UNIT-SEAL PERIMETER @ INTERIOR AND EXTERIOR
5. RELIEVING ANGLE @ WINDOW-SEE DETAIL 6/A15
6. RELIEVING ANGLE-SEE DETAIL 13/A15
7. FACE BRICK VENEER
8. GRANITE VENEER & BANDING
9. METAL EDGE FLASHING W/HOLD DOWN CLIPS
10. 3 HR. FIRE-RATED FLOOR/CEILING ASSEMBLY (U.L. #5512)
11. WOOD CEILING FINISH-SEE CEILING TYPE 14 ON DWG. A22.

1/A12 WALL SECTION 1/4" = 1'-0"

2/A12 WALL SECTION 1/4" = 1'-0"

3/A12 WALL SECTION 1/4" = 1'-0"

4/A12 WALL SECTION 1/4" = 1'-0"

5/A12 WALL SECTION 1/4" = 1'-0"

6/A12 WALL SECTION 1/4" = 1'-0"

LICENSED ARCHITECT
DONALD W. BLAJDA
No. 2936
STATE OF MAINE

REVISION SCHEDULE		
DATE	REVISION DESCRIPTION	BY
05-15-13	REVISED CEILINGS AT FIRST FLOOR SPACES	
06-03-13	REVISED ALL SECTIONS AT FOUNDATION LEVEL	
06-18-13	REVISED ROOF INSULATION THICKNESS.	

© COPYRIGHT 2012 BY O.C.C.

CONSTRUCTION CORPORATION
11 CORPORATE DRIVE, BELMONT NH 03220
PHONE (603) 527-9090 FAX (603) 527-9191

WALL SECTIONS

PROJECT:
COMMERCIAL & MAPLE STREET
MIXED USE DEVELOPMENT
PORTLAND, ME

DATE: 05-09-13
SCALE: SEE PLAN
DRAWN BY: KPH

SHEET: A12