





SR #: 261424



1 inch = 60 feet

Pressure Zone : 267



PORTLAND WATER DISTRICT
225 Douglass Street
Portland, ME 04104
Asset Management and Planning Dept.

Legend

● Air Valve	● Connection	⊕ Combined Service	● Manhole
● Blow Off	● Attribute Change	⊕ Domestic Service	● CSO
● By Pass	▲ Reducer	⊕ Fire Service	→ Gravity
⊗ Distribution	● Hydrant	● Private Hydrants	→ Force
⊗ Transmission	● Hydrant Control	⊕ Meter Pits	→ Contours

Hydrant Flow Testing Data

321 Commercial Street
Portland

Drawn By: BSJ
 Scale: As Noted

This map depicts flow testing data for the selected hydrants from PWD's asset management system. Note: a static pressure with a zero residual pressure and a flow hydrant that is the same as the test hydrant depicts a single-hydrant static pressure-only test.

Prepared For: Joe Petruska
 Sprinkler Systems Inc.
 Date: November 14, 2014