

**... Fire Protection by Computer Design**

Hampshire Fire Protection  
8 N Wentworth Ave  
Londonderry, NH 03053  
603-432-8221

Job Name : Courtyard by Marriott Area #3 Calc Laundry Area  
Building : 3 of 8  
Location : Portland ME  
System : Area #3  
Contract : 4396CME  
Data File : 2nd Floor Area #3 Laundry Area Calc.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**Project name:** Courtyard by Marriott

**Location:** Portland ME

**Drawing no:** 3 of 8

**Date:** 6-5-13

**Design**

**Remote area number:** Area #3

**Remote area location:** 2nd Floor Laundry Room

**Occupancy classification:** Light Hazard/Ordinary Hazard I

**Density:** .10/.15 - Gpm/SqFt

**Area of application:** 900 - SqFt

**Coverage per sprinkler:** Varies - SqFt

**Type of sprinklers calculated:** QR Recessed Pendent

**No. of sprinklers calculated:** 12

**In-rack demand:** - GPM

**Hose streams:** 250 - GPM

**Total water required (including hose streams):** 468.24 - GPM @ 79.81 - Psi

**Type of system:** Wet

**Volume of dry or preaction system:** N/A - Gal

**Water supply information**

**Date:** 5-11-13

**Location:** Commercial St & Maple St

**Source:** Portland Water

**Name of contractor:** Hampshire Fire

**Address:** N Wentworth Ave Londonderry NH 03053

**Phone number:** 603-432-8221

**Name of designer:** E Vance Wooten

**Authority having jurisdiction:** Portland

**Notes: (Include peaking information or gridded systems here.)** Area reduced for QR Sprinklers and ceiling height less than 10'-0"

# Water Supply Curve C

Hampshire Fire Protection  
Courtyard by Marriott Area #3 Calc Laundry Area


Page 2  
Date 6-4-13

## City Water Supply:

C1 - Static Pressure : 108  
C2 - Residual Pressure: 102  
C2 - Residual Flow : 1537

## Demand:

D1 - Elevation : 9.312  
D2 - System Flow : 218.244  
D2 - System Pressure : 79.805  
Hose ( Demand ) : 250  
D3 - System Demand : 468.244  
Safety Margin : 27.529



# Fittings Used Summary

Hampshire Fire Protection  
 Courtyard by Marriott Area #3 Calc Laundry Area

Page 3  
 Date 6-4-13

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0

## Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

Hampshire Fire Protection  
 Courtyard by Marriott Area #3 Calc Laundry Area

Page 4  
 Date 6-4-13

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
301	21.5	5.6	7.17	na	15.0	0.1	150	7.0
302	21.5	5.6	7.46	na	15.29	0.1	150	7.0
303	21.5	5.6	10.72	na	18.33	0.1	150	7.0
304	21.5	5.6	15.69	na	22.18	0.1	150	7.0
305	21.5	5.6	8.62	na	16.44	0.1	150	7.0
306	21.5	5.6	9.71	na	17.45	0.1	150	7.0
307	21.5	5.6	12.26	na	19.61	0.1	150	7.0
308	22.0	5.6	13.3	na	20.42	0.15	110	7.0
309	22.0	5.6	14.28	na	21.16	0.15	110	7.0
310	22.0	5.6	8.47	na	16.3	0.15	100	7.0
311	22.0	5.6	8.96	na	16.76	0.15	100	7.0
312	22.0	5.6	11.87	na	19.29	0.15	100	7.0
321	22.0		7.37	na				
322	22.75		7.58	na				
323	22.75		11.14	na				
324	22.75		16.53	na				
325	22.0		8.86	na				
326	22.75		10.05	na				
327	22.75		12.81	na				
328	22.75		13.35	na				
329	22.75		14.79	na				
330	22.75		8.39	na				
331	22.75		9.18	na				
332	22.75		11.64	na				
333	22.75		19.67	na				
334	22.75		19.68	na				
335	22.75		19.92	na				
336	22.75		20.04	na				
337	22.75		31.8	na				
338	22.75		52.89	na				
2FL	22.25		63.43	na				
ST03	11.67		68.45	na				
ST02	11.67		68.54	na				
1FL	11.67		68.58	na	100.0			
TOR	11.67		68.63	na				
BOR	2.0		72.95	na				
SPG	2.0		78.0	na				
TEST	0.0		79.81	na	150.0			

The maximum velocity is 19.86 and it occurs in the pipe between nodes 327 and 333

# Final Calculations - Hazen-Williams - 2007

Hampshire Fire Protection  
 Courtyard by Marriott Area #3 Calc Laundry Area

Page 5  
 Date 6-4-13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
301 to 321	15.00 15.0	1.049 120.0 0.0764	2E	4.0 0.0 0.0	1.380 4.000 5.380	7.175 -0.217 0.411			K Factor = 5.60 Vel = 5.57	
	0.0 15.00						7.369		K Factor = 5.53	
302 to 322	15.29 15.29	1.049 120.0 0.0792	1E 1T	2.0 5.0 0.0	1.380 7.000 8.380	7.457 -0.541 0.664			K Factor = 5.60 Vel = 5.68	
	0.0 15.29						7.580		K Factor = 5.55	
303 to 323	18.33 18.33	1.049 120.0 0.1107	1E 1T	2.0 5.0 0.0	1.750 7.000 8.750	10.717 -0.541 0.969			K Factor = 5.60 Vel = 6.80	
	0.0 18.33						11.145		K Factor = 5.49	
304 to 324	22.18 22.18	1.049 120.0 0.1576	1E 1T	2.0 5.0 0.0	1.750 7.000 8.750	15.693 -0.541 1.379			K Factor = 5.60 Vel = 8.23	
	0.0 22.18						16.531		K Factor = 5.46	
305 to 325	16.44 16.44	1.049 120.0 0.0906	2E	4.0 0.0 0.0	1.000 4.000 5.000	8.622 -0.217 0.453			K Factor = 5.60 Vel = 6.10	
	0.0 16.44						8.858		K Factor = 5.52	
306 to 326	17.45 17.45	1.049 120.0 0.1011	1E 1T	2.0 5.0 0.0	1.750 7.000 8.750	9.707 -0.541 0.885			K Factor = 5.60 Vel = 6.48	
	0.0 17.45						10.051		K Factor = 5.50	
307 to 327	19.61 19.61	1.049 120.0 0.1254	1E 1T	2.0 5.0 0.0	1.750 7.000 8.750	12.257 -0.541 1.097			K Factor = 5.60 Vel = 7.28	
	0.0 19.61						12.813		K Factor = 5.48	
308 to 328	20.42 20.42	1.049 120.0 0.1353	1E	2.0 0.0 0.0	0.750 2.000 2.750	13.302 -0.325 0.372			K Factor = 5.60 Vel = 7.58	
	0.0 20.42						13.349		K Factor = 5.59	
309 to 329	21.16 21.16	1.049 120.0 0.1445	1T	5.0 0.0 0.0	0.750 5.000 5.750	14.281 -0.325 0.831			K Factor = 5.60 Vel = 7.86	
	0.0 21.16						14.787		K Factor = 5.50	
310 to 330	16.30 16.3	1.049 120.0 0.0891	1E	2.0 0.0 0.0	0.750 2.000 2.750	8.469 -0.325 0.245			K Factor = 5.60 Vel = 6.05	

# Final Calculations - Hazen-Williams

Hampshire Fire Protection  
 Courtyard by Marriott Area #3 Calc Laundry Area

Page 6  
 Date 6-4-13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftn'g's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 16.30					8.389		K Factor = 5.63	
311 to 331	16.76	1.049 120.0	1T 0.0	5.0 0.0	0.750 5.000	8.961 -0.325		K Factor = 5.60	
	16.76	0.0939		0.0	5.750	0.540		Vel = 6.22	
	0.0 16.76					9.176		K Factor = 5.53	
312 to 332	19.29	1.049 120.0		0.0 0.0	0.750 0.0	11.869 -0.325		K Factor = 5.60	
	19.29	0.1213		0.0	0.750	0.091		Vel = 7.16	
	0.0 19.29					11.635		K Factor = 5.66	
321 to 322	15.00	1.049 120.0		0.0 0.0	7.000 0.0	7.369 -0.325			
	15.0	0.0766		0.0	7.000	0.536		Vel = 5.57	
322 to 323	15.29	1.049 120.0	2E 0.0	4.0 0.0	8.710 4.000	7.580 0.0			
	30.29	0.2805		0.0	12.710	3.565		Vel = 11.24	
323 to 324	18.33	1.049 120.0		0.0 0.0	8.000 0.0	11.145 0.0			
	48.62	0.6732		0.0	8.000	5.386		Vel = 18.05	
324 to 335	22.19	1.38 120.0	1T 0.0	6.0 0.0	3.540 6.000	16.531 0.0			
	70.81	0.3548		0.0	9.540	3.385		Vel = 15.19	
	0.0 70.81					19.916		K Factor = 15.87	
325 to 326	16.44	1.049 120.0	2E 0.0	4.0 0.0	12.750 4.000	8.858 -0.325			
	16.44	0.0906		0.0	16.750	1.518		Vel = 6.10	
326 to 327	17.45	1.049 120.0		0.0 0.0	8.000 0.0	10.051 0.0			
	33.89	0.3452		0.0	8.000	2.762		Vel = 12.58	
327 to 333	19.61	1.049 120.0	1T 0.0	5.0 0.0	3.540 5.000	12.813 0.0			
	53.5	0.8033		0.0	8.540	6.860		Vel = 19.86	
	0.0 53.50					19.673		K Factor = 12.06	
328 to 329	20.42	1.049 120.0		0.0 0.0	10.630 0.0	13.349 0.0			
	20.42	0.1353		0.0	10.630	1.438		Vel = 7.58	
329 to 336	21.17	1.049 120.0	1T 0.0	5.0 0.0	5.420 5.000	14.787 0.0			
	41.59	0.5041		0.0	10.420	5.253		Vel = 15.44	
	0.0 41.59					20.040		K Factor = 9.29	
330 to 331	16.30	1.049 120.0		0.0 0.0	8.830 0.0	8.389 0.0			
	16.3	0.0891		0.0	8.830	0.787		Vel = 6.05	

# Final Calculations - Hazen-Williams

Hampshire Fire Protection  
 Courtyard by Marriott Area #3 Calc Laundry Area

Page 7  
 Date 6-4-13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
331	16.76	1.049		0.0	7.460	9.176				
to 332	33.06	120.0 0.3296		0.0	0.0	0.0				
332	19.29	1.049	1T	5.0	5.420	11.635				Vel = 12.27
to 334	52.35	120.0 0.7719		0.0	5.000	0.0				Vel = 19.43
	0.0	52.35				19.678				K Factor = 11.80
333	53.50	2.635		0.0	0.540	19.673				
to 334	53.5	120.0 0.0093		0.0	0.0	0.0				Vel = 3.15
334	52.35	2.635		0.0	7.460	19.678				
to 335	105.85	120.0 0.0319		0.0	0.0	0.0				Vel = 6.23
335	70.81	2.635		0.0	1.500	19.916				
to 336	176.66	120.0 0.0827		0.0	0.0	0.0				Vel = 10.39
336	41.58	2.635	1V	5.903	90.460	20.040				
to 337	218.24	120.0 0.1220		0.0	5.903	0.0				Vel = 12.84
337	0.0	2.635	1X	14.827	157.960	31.800				
to 338	218.24	120.0 0.1220		0.0	14.827	0.0				Vel = 12.84
338	0.0	2.635	4V	23.613	15.670	52.887				
to 2FL	218.24	120.0 0.1220	1T	16.474	68.917	0.217				Vel = 12.84
			1S	19.22	84.587	10.322				
			1B	9.61						
2FL	0.0	4.26	2V	17.907	19.500	63.426				
to ST03	218.24	120.0 0.0118		0.0	17.907	4.582				Vel = 4.91
ST03	0.0	6.357	1X	31.433	9.500	68.448				
to ST02	218.24	120.0 0.0017	1B	12.573	44.006	0.0				Vel = 2.21
ST02	0.0	6.357		0.0	24.790	68.538				
to 1FL	218.24	120.0 0.0017		0.0	0.0	0.0				Vel = 2.21
1FL	100.00	6.357	1V	12.573	1.540	68.579				Qa = 100
to TOR	318.24	120.0 0.0034		0.0	12.573	0.0				Vel = 3.22
TOR	0.0	6.357	1X	31.433	9.670	68.627				
to BOR	318.24	120.0 0.0034		0.0	31.433	4.188				Vel = 3.22
BOR	0.0	6.357	1V	12.573	2.000	72.953				
to SPG	318.24	120.0 0.0034		0.0	12.573	5.000				** Fixed Loss = 5
SPG	0.0	6.16	3E	60.252	210.000	78.002				Vel = 3.22
to TEST	318.24	140.0 0.0030	1T	43.037	107.593	0.866				Vel = 3.43
			1G	4.304	317.593	0.937				



# Final Calculations - Hazen-Williams

Hampshire Fire Protection  
 Courtyard by Marriott Area #3 Calc Laundry Area

Page 8  
 Date 6-4-13

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	150.00						Qa = 150.00		
	468.24				79.805		K Factor = 52.41		