

... Fire Protection by Computer Design

Hampshire Fire Protection
8 N Wentworth Ave
Londonderry, NH 03053
603-432-8221

Job Name : Courtyard by Marriott Standpipe Calc
Building : 3 of 8
Location : Portland ME
System : Standpipe Calc
Contract : 4396CME
Data File : Standpipe Calc.WXF

HYDRAULIC CALCULATIONS
for

Project name: Courtyard by Marriott

Location: Portland ME

Drawing no: 3 of 8

Date: 6-5-13

Design

Remote area number: Standpipe Calc

Remote area location: Stair A

Occupancy classification: Class I Manual Wet Standpipe

Density: - Gpm/SqFt

Area of application: - SqFt

Coverage per sprinkler: - SqFt

Type of sprinklers calculated:

No. of sprinklers calculated:

In-rack demand: - GPM

Hose streams: - GPM

Total water required (including hose streams): 750 - GPM @ 142.05 - Psi

Type of system: Wet Manual Wet Standpipe

Volume of dry or preaction system: N/A - Gal

Water supply information

Date: N/A

Location: FDC

Source: NFPA

Name of contractor: Hampshire Fire

Address: N Wentworth Ave Londonderry NH 03053

Phone number: 603-432-8221

Name of designer: E Vance Wooten

Authority having jurisdiction: Portland

Notes: (Include peaking information or gridded systems here.) Calculation provides 250 GPM @ 100 PSI at the top FD Valve at the Remote Standpipe and 250 GPM at the next FD Valve down the remote standpipe and then 250 GPM is added at the connection to the next standpipe and run to the FDC where the Fire Department Pumper Truck will provide 750 GPM @ 150 PSI


Water Supply Curve C

Hampshire Fire Protection
Courtyard by Marriott Standpipe Calc

Page 2
Date 6-4-13

City Water Supply:
C1 - Static Pressure : 150
C2 - Residual Pressure: 150
C2 - Residual Flow : 750

Demand:
D1 - Elevation : 27.430
D2 - System Flow : 250
D2 - System Pressure : 142.054
Hose (Demand) : 500
D3 - System Demand : 750
Safety Margin : 7.946



Fittings Used Summary

Hampshire Fire Protection
 Courtyard by Marriott Standpipe Calc

Page 3
 Date 6-4-13

Fitting Legend

| Abbrev. | Name | 1/2 | 3/4 | 1 | 1 1/4 | 1 1/2 | 2 | 2 1/2 | 3 | 3 1/2 | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|--------------------------|-----|-----|---|-------|-------|-----|-------|----|-------|-----|-----|----|----|----|----|----|----|----|----|----|
| B | NFPA 13 Butterfly Valve | 0 | 0 | 0 | 0 | 0 | 6 | 7 | 10 | 0 | 12 | 9 | 10 | 12 | 19 | 21 | 0 | 0 | 0 | 0 | 0 |
| S | NFPA 13 Swing Check | 0 | 0 | 5 | 7 | 9 | 11 | 14 | 16 | 19 | 22 | 27 | 32 | 45 | 55 | 65 | | | | | |
| V | 90' EII Firelock #001 | 0 | 0 | 0 | 0 | 0 | 3.5 | 4.3 | 5 | 0 | 6.8 | 8.5 | 10 | 13 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| X | 90'Tee-BranchFirelock002 | 0 | 0 | 0 | 0 | 0 | 8.5 | 10.8 | 13 | 0 | 16 | 21 | 25 | 33 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Hampshire Fire Protection
Courtyard by Marriott Standpipe Calc

Page 4
Date 6-4-13

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| FV1 | 68.333 | 25 | 100.0 | na | 250.0 | 1.0 | 250 | 100.0 |
| FV2 | 58.0 | | 105.22 | na | 250.0 | | | |
| ST01 | 11.67 | | 129.54 | na | | | | |
| ST02 | 11.67 | | 131.75 | na | 250.0 | | | |
| 1FL | 11.67 | | 132.16 | na | | | | |
| TOR | 11.67 | | 132.39 | na | | | | |
| BOR | 2.0 | | 137.25 | na | | | | |
| FDC | 5.0 | | 142.05 | na | | | | |

The maximum velocity is 16.88 and it occurs in the pipe between nodes BOR and FDC

Final Calculations - Hazen-Williams - 2007

Hampshire Fire Protection
 Courtyard by Marriott Standpipe Calc

Page 5
 Date 6-4-13

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------------|--------------|----------------------|---------------------------|-------------------------|----------------|----------------|-------|------------------|-------|
| FV1 | 250.00 | 4.26 | 2V 17.907 | 15.630 | 100.000 | | | K Factor = 25.00 | |
| to | | 120.0 | 1B 15.8 | 33.707 | 4.475 | | | | |
| FV2 | 250.0 | 0.0151 | 0.0 | 49.337 | 0.746 | | | Vel = 5.63 | |
| FV2 | 250.00 | 4.26 | 1V 8.954 | 48.000 | 105.221 | | | Qa = 250 | |
| to | | 120.0 | 1X 21.067 | 30.021 | 20.066 | | | | |
| ST01 | 500.0 | 0.0545 | 0.0 | 78.021 | 4.253 | | | Vel = 11.25 | |
| ST01 | 0.0 | 6.357 | 3V 37.72 | 202.670 | 129.540 | | | | |
| to | | 120.0 | 1X 31.433 | 81.726 | 0.0 | | | | |
| ST02 | 500.0 | 0.0078 | 1B 12.573 | 284.396 | 2.207 | | | Vel = 5.05 | |
| ST02 | 250.00 | 6.357 | 0.0 | 24.790 | 131.747 | | | Qa = 250 | |
| to | | 120.0 | 0.0 | 0.0 | 0.0 | | | | |
| 1FL | 750.0 | 0.0165 | 0.0 | 24.790 | 0.408 | | | Vel = 7.58 | |
| 1FL | 0.0 | 6.357 | 1V 12.573 | 1.540 | 132.155 | | | | |
| to | | 120.0 | 0.0 | 12.573 | 0.0 | | | | |
| TOR | 750.0 | 0.0164 | 0.0 | 14.113 | 0.232 | | | Vel = 7.58 | |
| TOR | 0.0 | 6.357 | 1X 31.433 | 9.670 | 132.387 | | | | |
| to | | 120.0 | 0.0 | 31.433 | 4.188 | | | | |
| BOR | 750.0 | 0.0164 | 0.0 | 41.103 | 0.675 | | | Vel = 7.58 | |
| BOR | 0.0 | 4.26 | 1S 28.968 | 6.000 | 137.250 | | | | |
| to | | 120.0 | 2V 17.907 | 46.875 | -1.299 | | | | |
| FDC | 750.0 | 0.1154 | 0.0 | 52.875 | 6.103 | | | Vel = 16.88 | |
| | 0.0 | | | | | | | | |
| | 750.00 | | | | 142.054 | | | K Factor = 62.93 | |