SFC ENGINEERING PARTNERSHIP, INC.
"FROM VISION TO REALIZATION"

RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 08/01/13

Date: June 14, 2013 **Project Name: Marri**

Plan Reviewer: SFC Engineering Partnership, Inc. **Project Number: 588**

SFC Engineering Partnership, Inc. has completed an independent code review of the listed plan set for code compliance. The plan set was reviewed for compliance for all codes indicated.

Plan Set Information
Plan Type: Sprinkler Plans
Plan Set Date: 05/25/13
Prepared By: Hampshire Fire Protection
Revision Dates: N/A

Codes Reviewed		**Compliant?**
IBC 2009	☐	☐Yes ☐No ☐As noted below
NFPA 1, 2009	☐	☐Yes ☐No ☐As noted below
NFPA 13, 2009	☒	☒Yes ☐No ☒As noted below
NFPA 70, 2008	☐	☐Yes ☐No ☐As noted below
NFPA 72, 2009	☐	☐Yes ☐No ☐As noted below
NFPA 101, 2009	☐	☐Yes ☐No ☐As noted below
City of Portland: Code of Ordinances	☐	☐Yes ☐No ☐As noted below
ADA Standards for Accessible Design	☐	☐Yes ☐No ☐As noted below

General Comments:

1. Sheet 7: If sprinkler heads are not being installed at the top of the elevator hoistways, please verify that the elevator cars meet the requirements of ASME A17.1, *the Safety Code for Elevators and Escalators*.

I hereby certify that I have reviewed the above plans for compliance with the applicable codes as listed. To the best of my knowledge this review has identified any and all deficiencies. However, it is the responsibility of the designer and contractor to provide a compliant building or system. SFC has no design responsibility or liability for this project.

Mark Richards

Mark R. Richards, E.I.T
Project Engineer

Nick Cricenti, P.E.
President

STATE OF MAINE
NICHOLAS J. CRICENTI, JR.
6723
LICENSED
PROFESSIONAL ENGINEER

Date:
06/14/13