

GENERAL NOTES

- 1. THESE DRAWINGS DEPICT GENERAL LOCATIONS OF LIFE SAFETY EQUIPMENT & FIELD DEVICES. EXACT ROUTING OF CONDUITS TO BE DETERMINED IN THE FIELD BY THE INSTALLING CONTRACTOR TO SUIT CONDITIONS. ALL CHANGES SHALL BE CLEARLY INDICATED ON THE RECORD DRAWINGS.

SYSTEM DESCRIPTION / SCOPE OF WORK

OCCUPANCY TYPE: B BUSINESS GROUP
SPRINKLER PROTECTION: BUILDING IS FULLY SPRINKLED
PROVIDE AND INSTALL A NEW AUTOMATIC AND MANUAL FIRE ALARM SYSTEM AS SHOWN ON DRAWINGS.

SYMBOL KEY

FIRE ALARM SYMBOLS LEGEND table with columns: SYMBOL, DESCRIPTION, MODEL#, BACKBOX. Includes items like FACP (FIRE ALARM CONTROL PANEL), NAC (NOTIFICATION APPLIANCE), FFA (SERIAL LCD ANNUNCIATOR), etc.

FIRE ALARM APPLICABLE CODES & STANDARDS

- LIFE SAFETY CODE (NFPA 101), 1997 EDITION
NATIONAL ELECTRIC CODE (NFPA 70), 2002 EDITION
ELEVATOR CODE ASHE A.17.1, 2000 ADDENDA A17.1.A, 2002 EDITION

WIRE SCHEDULE

ABBREVIATIONS LEGEND

- AC = ABOVE CEILING
C = CEILING MOUNTED
E = EXISTING TO REMAIN
RC = EXISTING TO REMOVE AND COVER

FIRE ALARM WIRE LIST table with columns: CIRCUIT, CONDUCTOR SIZE, CONDUCTOR AREA, CONDUIT SIZE, CONDUIT AREA. Includes entries for communication, remote test, and visual signal circuits.

DEVICE ADDRESSING LEGEND

- ADDRESSABLE CARD (IDNET OR MAPNET)
CIRCUIT DESIGNATOR
V=VISUAL OR A/V, H=AUDIBLE ONLY
NAC1:V2-1

SEQUENCE OF OPERATION

Sequence of Operation matrix showing SYSTEM INPUTS, SYSTEM OUTPUTS, CONTROL UNIT ANNUNCIATION, NOTIFICATION, and FIRE SAFETY CONTROL. Includes a grid of actions for various fire events like smoke detector activation, manual pull station, and annunciator signals.

FILE PATH: P:\2013\147\Courtyard\REV1 CAD\FA-002.dwg
LAST PRINTED: 11/11/2013 2:54:00 PM LAST SAVED BY: CLORION

Project information sidebar including tyco SimplexGrinnell logo, address (20 THOMAS DRIVE WESTBROOK, ME 04092), phone numbers, and project details like 'FIRE ALARM & AREA OF RESCUE SYSTEMS' and 'MARRIOTT COURTYARD'.