



Portland Fire Department

12/11/2019

CERTIFIED MAIL

RE:

Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 2/26/2019 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 1/15/2020 1:00:00PM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-4.5.3.2, 7.1.10.1	The means of egress shall remain free and unobstructed.	IMMEDIATELY remove all obstructions to the means of egress. This location was in the maintenance shop.	2/27/2019
NFPA 54-9.6.4	No storage 36" in front of or 30" to either side of all electrical panels.	Locations include Pier 1, Maintenance shop, Cooler	3/12/2019
NFPA 101-4.5.8	Exit signs must be kept in good working order.	Exit signs out at exit to the right of main entrance, boiler room, back wall of cooler	3/28/2019
NFPA 10-Ch. 7	Fire extinguishers must be serviced annually, with the date of service on the inspection tag.	Multiple extinguishers had expired inspection.	3/28/2019