UNIT			DWG. #	REV
EVAPORTATIVE CONDENSER		**EVAPCO, INC.**	WLE041208-DRC-002	
MODEL # LSC-135E	SCALE N.T.S.		SERIAL # 17-814777	DAT

Inspections Division
Date: 06/20/17

NOTES:
1. (M)- FAN MOTOR LOCATION
2. MPT DENOTES MALE PIPE THREAD
   FPT DENOTES FEMALE PIPE THREAD
   BFW DENOTES BEVELED FOR WELDING
   GVD DENOTES GROOVED
   FLG DENOTES FLANGE
   PE DENOTES PLAIN END WITH PLUG
   CLOSURE FOR NITROGEN CHARGE
3. +UNIT WEIGHT DOES NOT INCLUDE
   ACCESSORIES (SEE ACCESSORY DRAWINGS)
4. 3/4" [19mm] DIA. MOUNTING HOLES. REFER TO
   RECOMMENDED STEEL SUPPORT DRAWING
5. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT IN
   [METRIC] [mm]
6. * - APPROXIMATE DIMENSIONS DO NOT
   USE FOR PRE-FABRICATION OF CONNECTING PIPING
7. HEAVIEST SECTION IS COIL SECTION
8. THE SPRAY PUMP SHOULD BE SIZED FOR
   245 gpm [15.4 l/s] AND 1.5 psi [10.3 kPa]
   AT THE INLET CONNECTION(S)
9. VENT PROVIDED ON CLOSED CIRCUIT COOLERS
   ONLY

FACE B

PLAN VIEW

FACE B

FACE D

FACE A

FACE A

SHIPPING WEIGHT	OPERATING WEIGHT	HEAVIEST SECTION WEIGHT	NO. OF SHIPPING SECTIONS	DRAWN BY:
5680 Lb+ [2576] Kg+	7180 Lb+ [3257] Kg+	3870 Lb+ [1755] Kg+	2	JTG