

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction:		Owner: X-110		Phone: 857-247184		Permit No: 990579	
Owner Address:		Lessee/Buyer's Name:		Phone:		BusinessName:	
Contractor Name:		Address:		Phone:		Permit Issued: JUN 8 1999	
Past Use:		Proposed Use:		COST OF WORK: \$ FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied INSPECTION: Use Group: Type: Signature: Signature:		PERMIT FEE: \$ INSPECTION: Use Group: Type: Signature: Signature:	
Proposed Project Description:				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/> Signature: Date:			
Permit Taken By:		Date Applied For:					

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

PERMIT ISSUED
WITH REQUIREMENTS


CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT ADDRESS: DATE: PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector



Zone: CBL:

Zoning Approval:

Special Zone or Reviews:

- ☐ Shoreland
- ☐ Wetland
- ☐ Flood Zone
- ☐ Subdivision
- ☐ Site Plan maj ☐ minor ☐ mm ☐

Zoning Appeal

- ☐ Variance
- ☐ Miscellaneous
- ☐ Conditional Use
- ☐ Interpretation
- ☐ Approved
- ☐ Denied

Historic Preservation


- ☐ Not in District or Landmark
- ☐ Does Not Require Review
- ☐ Requires Review

Action:

- ☐ Approved
- ☐ Approved with Conditions
- ☐ Denied

Date:

CEO DISTRICT



COMMENTS

6/10/99 PreConstruction by phone with Loy Mitchell discuss 2nd egress structural analysis of roof support, height of guardrail required 42", 11" tread no work to begin until all issues resolved call back

6/14/99

6/18/99 Single egress ok for occupancy load per SH & GM (DC)

2-22-00 Spoke with Loy Mitchell - This job has been cancelled - no work has been started. We have other permits for this property that will need inspections, so this area will be observed at that time JB

Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____