FLOOR PLAN

1/4"=1'-0"

LEGEND

A — NFPA 12.2.5.7.1 States that an Aisle accessway shall not be less than 12 " clear where measured in accordance with 12.2.5.7.3 and shall be increased as a function of length per 12.2.5.7.4 unless otherwise permitted by 12.2.5.7.2. 12.2.5.7.2 indicates no minimum aisle access dimension if its length does not exceed 6'.

B — Same as 'A' except because non fixed seating is between the table and the aisle access, 19" must be added to the minimum 12" to yield a minimum clear aisle width of 31". However, because the aisle access is less than 6' long, no minimum is required per 12.2.5.7.2.

C — NFPA 12.2.5.8.2 States that the width of aisles serving seating at tables shall not be less than 44" where serving an occupant load exceeding 50 and 36" where serving an occupant load of 50 or fewer. Per 12.2.5.8.3, when non fixed seating is located between a table and an aisle, the aisle shall be made to a line 19" measured perpenducluarly to the table edge. This aisle serves less than 50 people so the clear required width from the edge of table to the opposite wall is 36" + 19" = 55" or 4'-7".

D — NFPA 12.2.5.7.1 States that an Aisle accessway shall not be less than 12 " clear where measured in accordance with 12.2.5.7.3 and shall be increased as a function of length per 12.2.5.7.4. Per 12.2.5.7.5, The path of travel along an aisle accessway shall not exceed 36'. Per 12.2.5.7.4 the minimum aisle accessway width of 12" shall be increased by 1/2" for every 12" beyond 12' of aisle access length. A 20' aisle access with non fixed seating on one side is equal to 12" + 19" + (1/2"* 8) = 35"

E — NFPA 12.2.5.8.2 States that the width of aisles serving seating at tables shall not be less than 44" where serving an occupant load exceeding 50 and 36" where serving an occupant load of 50 or fewer. Per 12.2.5.8.3, when non fixed seating is located between a table and an aisle, the aisle shall be made to a line 19" measured perpenducluarly to the table edge. This aisle serves 17 people so the clear required width from the edge of table to the opposite wall is 36" + 19" = 55" or 4'-7".

F — NFPA 12.2.5.8.2 States that the width of aisles serving seating at tables shall not be less than 44" where serving an occupant load exceeding 50 and 36" where serving an occupant load of 50 or fewer. Per 12.2.5.8.3, when non fixed seating is located between a table and an aisle, the aisle shall be made to a line 19" measured perpenducluarly to the table edge. This aisle serves up to 78 people so the clear required width from the edge of table to the opposite wall is 44" + 19" = 64" or 5'-4".

CITY OF PORTLAND, MAINE — RESURGAM

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 08/20/13

WSA
WINTON SCOTT ARCHITECTS
5 Milk Street
Portland, Maine 04101
207 774 4811
www.wintonscott.com

REGISTERED ARCHITECT — WINTON F. SCOTT, JR. No. 793 — STATE OF MAINE

Winton Scott

KING'S HEAD
Tenant Fit Up

Merrill's Wharf
Portland, Maine

REVISIONS

PERMIT DOCUMENTS
7/29/13

Seating Code Plan

Scale: As Noted

ASK 1