

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
WATERFRONT MAINE

Located at
252 COMMERCIAL ST (Merrill's Wharf)

PERMIT ID: 2015-01503 **ISSUE DATE:** 07/07/2015 **CBL:** 041 A016001

has permission to **Tenant Fit Up/establish use - open up the wall between suite 119A and suite 118 to expand existng CPB2, LLC - marine office**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Keith Gautreau

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
Suite 118 (Unit B) - marine office

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Above Ceiling Inspection

Certificate of Occupancy/Final

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-01503	Date Applied For: 06/24/2015	CBL: 041 A016001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Suite 118 (Unit B) - Marine office - ("CPB2, LLC")		Proposed Project Description: Tenant Fit Up/establish use - open up the wall between suite 119A and suite 118 to expand existing CPB2, LLC - marine office		
Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 07/01/2015				
Note: Suite 118 was vacant. It was counted as part of the 55% marine use of the first floor. It remains a marine use Ok to Issue: <input checked="" type="checkbox"/> since the tenant CPB2, LLC has been determined to be a marine office.				
Conditions:				
1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Tammy Munson Approval Date: 07/01/2015				
Note: Ok to Issue: <input checked="" type="checkbox"/>				
Conditions:				
1) Separate Permits shall be required for any new signage.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Engineering DPS Status: Not Applicable Reviewer: Approval Date: 07/01/2015				
Note: Ok to Issue: <input checked="" type="checkbox"/>				
Conditions:				
Dept: Fire Status: Approved w/Conditions Reviewer: Keith Gautreau Approval Date: 07/01/2015				
Note: Ok to Issue: <input type="checkbox"/>				
Conditions:				
1) Construction or installation shall comply with City Code Chapter 10.				
2) All outstanding code violations shall be corrected prior to final inspection.				
3) Any cutting and welding done will require a Hot Work Permit from Fire Department.				
4) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.				
5) All construction shall comply with City Code Chapter 10. http://www.portlandmaine.gov/citycode/chapter010.pdf A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation. A separate Suppression System Permit is required for all new suppression systems or sprinkler work effecting more than 20 heads. This review does not include approval of sprinkler system design or installation. Shall meet the requirements of 2009 NFPA 1 Fire Code. Shall meet the requirements the most recent NFPA 30 Flammable and Combustible Liquids Code. Shall meet the requirements the most recent NFPA 30A Code for Motor Fuel Dispensing Facilities and Repair Garages. Shall have State Fire Marshall Permit. Shall have DEP Permit.				