

***iO500 Addressable Fire Alarm System  
King's Head  
Tenant Fit Up  
Portland, ME***

[Click Here to Return to  
Bill of Material/Index](#)

**System Narrative**

**In the event of an alarm from an actuated device, the following shall**

**occur:** (Devices reporting an alarm: Manual Station, Smoke, or Waterflow Switch)

- 1) Notify the Portland Fire Department via the Existing Radio Master Box;
- 2) Activate the exterior Strobe/Beacon
- 3) If Waterflow Alarm, activate exterior waterflow bell
- 4) Sound a Code 3 Temporal on all Horn Circuits
- 5) Flash all strobe appliance circuits in a synchronized manner

**In the event of a supervisory condition from an actuated device, the**

**following shall occur:** (Devices reporting as supervisory: Tamper Switch, Sprinkler Supervisory Switch)

- 1) Notify the Portland Fire Department via the Existing Radio Masterbox.
- 2) Annunciate audibly,visually, and in plain english the active initiating device at the fire alarm control panel.

**In the event of a system trouble report, the following shall occur:**

- 1) Annunciate audibly,visually, and in plain english the active initiating device at the fire alarm control panel.