


**iO500 Addressable Fire Alarm System
King's Head
Portland, ME**

SEQUENCE OF OPERATION MATRIX



System Inputs	A	B	C	D	E	System Inputs
System Waterflow	x	x	x	x	x	System Waterflow
System Tamper Switch		x				System Tamper Switch
Low Water Pressure Switch		x				Low Water Pressure Switch
Manual Pull Stations	x	x	x	x		Manual Pull Stations
Area Smoke Detector	x	x	x	x		Area Smoke Detector
Area Heat Detector	x	x	x	x		Area Heat Detector
Area Duct Smoke Detector	x	x	x	x		Area Duct Smoke Detector
Fire Alarm - AC Failure		x				Fire Alarm - AC Failure
Fire Alarm - Low Battery		x				Fire Alarm - Low Battery
Signal Line Open Circuit		x				Signal Line Open Circuit
Signal Line Ground Fault		x				Signal Line Ground Fault
Horn/Strobe Circuit Open		x				Horn/Strobe Circuit Open
Horn/Strobe Circuit Ground		x				Horn/Strobe Circuit Ground
System Ground Fault		x				System Ground Fault
	A	C	D	E	F	