Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

X11S COMMERCIAL

7.5- & 10-TON, THREE-PHASE T SYSTEM AIR CONDITIONER

11.2 EER / R-410A

Cooling Capacity:
88,000 - 112,000 BTU/h

Standard Features

- Energy-efficient compressor
- Quiet operating top discharge
- High-efficiency copper tube / aluminum fin coil
- Brass liquid and suction service valves
- High- and low-pressure switches
- Factory-installed filter drier
- Complies with ASHRAE 90.1-2007
- AHRI Certified; ETL Listed

Cabinet Features

- Innovative sound control top design
- Steel louver coil guard protects the coil from damage and adds strength to unit
- Bottom pan rails elevate unit above slab
- Heavy-gauge galvanized-steel cabinet
- Attractive Nickel Gray powder-paint finish
- When properly anchored, meets the 2001 Florida Building Code unit integrity requirements for hurricane-type winds (Anchor bracket kits available.)

Contents

Nomenclature 2
Product Specifications 3
Expanded Cooling Data 4
AHRI Ratings 12
Dimensions 13
Wiring Diagram 14
Accessories 15

5 YEAR PARTS WARRANTY *

* Complete warranty details available from your local dealer or at www.daikincomfort.com.

NOMENCLATURE

RESURGAM. CITY OF PORTLAND, MAINE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

D	X	11				A	A
1	2	3,4				11	12

Brand
D - Daikin

Type
X - AC R-410A
Z - HP R-410A

EER
11 - 11.2 EER

Compressor
S - Single Stage
T - Two Stage

Feature Set
A - Base

Tonnage Nominal
090 -7½ tons
120 - 10 tons

Voltage
3 - 208/230 V Three-Phase 60 Hz
4 - 460 V Three-Phase 60 Hz

Engineering
Major revision

Engineering
Minor revision

PRODUCT SPECIFICATIONS

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

			DX11SA 1203A*	DX11SA 1204A*
COOLING CAPACITIES				
Nominal Cooling (BTU/h)[1]	[illegible]	[illegible]	114,000	112,000
EER / IEER	11.2 / 11.5	11.2 / 11.5	11.2 / 11.5	11.2 / 11.5
Decibels	84	84	84	84
COMPRESSOR				
RLA	25.0	12.2	30.1	16.7
LRA	164	100	225	114
CONDENSER FAN MOTOR				
Horsepower	1	1	1	1
FLA	5.6	3.5	5.6	3.5
REFRIGERATION SYSTEM				
Liquid Valve Connection Size (“O.D.)	⅝"	⅝"	⅝"	⅝"
Suction Valve Connection Size (“O.D.)	1⅜"	1⅜"	1⅜"	1⅜"
Valve Type	Sweat	Sweat	Sweat	Sweat
Refrigerant Charge	35	35	35	35
ELECTRICAL DATA				
AC Volts	208/230	460	208/230	460
Hz / Phase	60 Hz/3	60 Hz/3	60 Hz/3	60 Hz/3
Minimum Circuit Ampacity [2]	36.9	18.8	43.2	24.4
Max. Overcurrent Protection [3]	60	30	70	40
Min / Max Volts	197/253	414/506	197/253	414/506
Electrical Conduit Size	½" or ¾"	½" or ¾"	½" or ¾"	½" or ¾"
SHIP WEIGHT (LBS)	315	315	334	334

[1] Tested and rated in accordance with ARI Standard 208/230

[2] Wire size should be determined in accordance with National Electrical Codes; extensive wire runs will require larger wire sizes

[3] Must use time-delay fuses or HACR-type circuit breakers of the same size as noted.

NOTES

- Always check the rating plate for electrical data on the unit being installed.
- Installer will need to supply ⅞” to 1⅛” adapters for suction line connections.
- Installation of these units requires the specified TXV Kit to be installed on the indoor coil.
  THE SPECIFIED TXV IS DETERMINED BY THE OUTDOOR UNIT NOT THE INDOOR COIL.

EXPANDED COOLING DATA — D

3642*6D*+TXV

			Outdoor Ambient Temperature																							
			65ºF				75ºF				85ºF				95ºF				105ºF				115ºF			
			Entering Indoor Wet Bulb Temperature																							
IDB	Airflow		59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71
70	2625	MBh	77.3	80.1	87.8	-	75.5	78.2	85.7	-	73.7	76.4	83.7	-	71.9	74.5	81.6	-	68.3	70.8	77.5	-	63.3	65.6	71.8	-
		S/T	0.65	0.54	0.38	-	0.67	0.56	0.39	-	0.69	0.58	0.40	-	0.71	0.59	0.41	-	0.74	0.62	0.43	-	0.74	0.62	0.43	-
		ΔT	18	15	12	-	18	15	12	-	18	15	12	-	18	16	12	-	18	15	12	-	16	14	11	-
		kW	6.62	6.75	6.94	-	7.08	7.21	7.42	-	7.47	7.62	7.85	-	7.83	7.98	8.22	-	8.13	8.29	8.54	-	8.39	8.56	8.82	-
		Amps	18.0	18.3	18.9	-	19.2	19.6	20.2	-	20.7	21.1	21.7	-	21.9	22.4	23.1	-	23.2	23.7	24.4	-	24.4	25.0	25.7	-
		HI PR	216	233	246	-	243	261	276	-	276	297	313	-	314	338	357	-	353	380	402	-	391	420	444	-
		LO PR	100	106	116	-	106	112	123	-	110	117	128	-	115	123	134	-	121	129	140	-	125	133	145	-
	3021	MBh	83.7	86.8	95.1	-	81.8	84.8	92.9	-	79.8	82.7	90.7	-	77.9	80.7	88.4	-	74.0	76.7	84.0	-	68.5	71.0	77.8	-
		S/T	0.67	0.56	0.39	-	0.70	0.58	0.40	-	0.71	0.60	0.41	-	0.74	0.62	0.43	-	0.77	0.64	0.44	-	0.77	0.64	0.45	-
		ΔT	17	15	11	-	17	15	11	-	17	15	11	-	17	15	11	-	17	15	11	-	16	14	11	-
		kW	6.77	6.90	7.09	-	7.23	7.37	7.59	-	7.65	7.80	8.03	-	8.01	8.17	8.42	-	8.32	8.49	8.75	-	8.58	8.76	9.03	-
		Amps	18.4	18.8	19.3	-	19.7	20.1	20.7	-	21.2	21.7	22.3	-	22.5	23.0	23.7	-	23.8	24.3	25.1	-	25.1	25.6	26.4	-
		HI PR	223	240	253	-	250	269	284	-	284	306	323	-	324	349	368	-	364	392	414	-	403	433	458	-
		LO PR	103	110	120	-	109	116	127	-	113	120	132	-	119	127	138	-	125	133	145	-	129	137	[illegible]	[illegible]
	3375	MBh	85.0	88.1	96.5	-	83.0	86.0	94.3	-	81.0	84.0	92.0	-	79.0	81.9	89.8	-	75.1	77.8	85.3	-	69.6	72.1	[illegible]	[illegible]
		S/T	0.70	0.59	0.41	-	0.73	0.61	0.42	-	0.75	0.62	0.43	-	0.77	0.64	0.45	-	0.80	0.67	0.46	-	0.81	0.67	[illegible]	[illegible]
		ΔT	16	14	11	-	16	14	11	-	16	14	11	-	17	14	11	-	16	14	11	-	15	13	[illegible]	[illegible]
		kW	6.80	6.93	7.13	-	7.27	7.41	7.63	-	7.69	7.84	8.07	-	8.05	8.21	8.46	-	8.36	8.53	8.79	-	8.63	8.8[illegible]	[illegible]	[illegible]
		Amps	18.5	18.9	19.4	-	19.8	20.2	20.8	-	21.3	21.8	22.4	-	22.6	23.1	23.8	-	23.9	24.5	25.2	-	25.2	25.8	[illegible]	[illegible]
		HI PR	224	242	255	-	252	271	286	-	286	308	325	-	326	351	371	-	367	395	417	-	405	436	[illegible]	[illegible]
		LO PR	104	111	121	-	110	117	127	-	114	121	132	-	120	127	139	-	126	134	146	-	130	138	[illegible]	[illegible]
75	2625	MBh	78.6	80.9	87.6	94.0	76.8	79.0	85.5	91.8	74.9	77.1	83.5	89.6	73.1	**75.3**	81.5	87.4	69.4	71.5	77.4	83.1	64.3	66.[illegible]	[illegible]	[illegible]
		S/T	0.74	0.66	0.50	0.32	0.76	0.68	0.52	0.33	0.78	0.70	0.53	0.34	0.81	**0.72**	0.55	0.35	0.84	0.75	0.57	0.37	0.85	0.76	[illegible]	[illegible]
		ΔT	20	19	15	11	21	19	15	11	21	19	16	11	21	**19**	16	11	20	19	15	11	19	18	[illegible]	[illegible]
		kW	6.67	6.80	6.99	7.19	7.13	7.27	7.48	7.70	7.53	7.68	7.91	8.14	7.89	**8.05**	8.29	8.54	8.19	8.36	8.61	8.88	8.45	8.62	[illegible]	[illegible]
		Amps	18.1	18.5	19.0	19.6	19.4	19.8	20.4	21.0	20.8	21.3	21.9	22.7	22.1	**22.6**	23.3	24.1	23.4	23.9	24.6	25.5	24.6	25.2	[illegible]	[illegible]
		HI PR	218	235	248	259	245	264	278	290	279	300	317	330	317	**342**	361	376	357	384	406	423	395	425	448	468
		LO PR	101	108	117	125	107	114	124	132	111	118	129	137	117	**124**	135	144	122	130	142	151	126	134	147	156
	3021	MBh	85.1	87.7	94.9	101.8	83.2	85.6	92.7	99.5	81.2	83.6	90.5	97.1	79.2	**81.5**	88.3	94.7	75.2	77.5	83.9	90.0	69.7	71.8	77.7	83.4
		S/T	0.76	0.68	0.52	0.33	0.79	0.71	0.54	0.35	0.81	0.73	0.55	0.35	0.84	**0.75**	0.57	0.37	0.87	0.78	0.59	0.38	0.88	0.78	0.59	0.38
		ΔT	20	18	15	10	20	18	15	10	20	18	15	10	20	**19**	15	11	20	18	15	10	19	17	14	10
		kW	6.82	6.95	7.14	7.35	7.29	7.43	7.65	7.87	7.70	7.86	8.09	8.34	8.07	**8.23**	8.48	8.74	8.38	8.55	8.82	9.09	8.65	8.83	9.10	9.39
		Amps	18.5	18.9	19.5	20.1	19.9	20.3	20.9	21.6	21.4	21.8	22.5	23.2	22.7	**23.2**	23.9	24.7	24.0	24.5	25.3	26.1	25.3	25.9	26.7	27.6
		HI PR	225	242	256	267	253	272	287	299	287	309	326	341	327	**352**	372	388	368	396	418	436	407	438	462	482
		LO PR	104	111	121	129	110	117	128	136	114	122	133	142	120	**128**	140	149	126	134	146	156	130	139	151	161
	3375	MBh	86.4	89.0	96.3	103.4	84.4	86.9	94.1	101.0	82.4	84.8	91.8	98.6	80.4	**82.8**	89.6	96.2	76.4	78.6	85.1	91.3	70.7	72.8	78.8	84.6
		S/T	0.80	0.71	0.54	0.35	0.83	0.74	0.56	0.36	0.85	0.76	0.57	0.37	0.88	**0.78**	0.59	0.38	0.91	0.81	0.62	0.40	0.92	0.82	0.62	0.40
		ΔT	19	17	14	10	19	18	14	10	19	18	14	10	19	**18**	14	10	19	17	14	10	18	16	13	9
		kW	6.85	6.98	7.18	7.39	7.32	7.47	7.69	7.92	7.74	7.90	8.13	8.38	8.11	**8.28**	8.53	8.79	8.43	8.60	8.86	9.14	8.70	8.88	9.15	9.44
		Amps	18.6	19.0	19.6	20.2	20.0	20.4	21.0	21.7	21.5	22.0	22.6	23.4	22.8	**23.3**	24.0	24.8	24.1	24.7	25.4	26.3	25.4	26.0	26.8	27.7
		HI PR	227	244	258	269	254	274	289	302	289	311	329	343	330	**355**	374	391	371	399	421	439	410	441	465	485
		LO PR	105	112	122	130	111	118	129	137	115	123	134	143	121	**129**	141	150	127	135	147	157	131	140	152	162

IDB: Entering Indoor Dry Bulb Temperature
High and low pressures are measured at the liquid and suction service valves.

Shaded area reflects ACCA (TVA) conditions

Amps = outdoor unit amps (comp.+fan)
kW = Total system power

Date: 11/04/13

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

CITY OF PORTLAND, MAINE — RESURGAM

Expanded Cooling Data — D

3642*6D*+TXV (cont.)

Product Specifications

IDB	Airflow		Outdoor Ambient Temperature 65ºF				75ºF				85ºF				95ºF				105ºF				115ºF			
			Entering Indoor Wet Bulb Temperature																							
			59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71
80	2625	MBh	80.0	81.7	87.3	93.3	78.1	79.8	85.3	91.2	76.3	77.9	83.3	89.0	74.4	76.0	81.2	86.8	70.7	72.2	77.2	82.5	65.5	66.9	71.5	76.4
		S/T	0.81	0.76	0.62	0.46	0.84	0.79	0.64	0.48	0.86	0.81	0.66	0.49	0.89	0.83	0.68	0.51	0.92	0.86	0.70	0.53	0.93	0.87	0.71	0.53
		ΔT	23	22	19	15	23	22	19	15	23	22	19	15	23	22	19	15	23	22	19	15	21	20	18	14
		kW	6.72	6.85	7.04	7.24	7.18	7.32	7.53	7.75	7.59	7.74	7.97	8.21	7.95	8.11	8.35	8.61	8.25	8.42	8.68	8.95	8.52	8.69	8.96	9.24
		Amps	18.2	18.6	19.2	19.8	19.5	19.9	20.5	21.2	21.0	21.5	22.1	22.9	22.3	22.8	23.5	24.3	23.6	24.1	24.8	25.7	24.9	25.4	26.2	27.1
		HI PR	221	237	251	261	248	266	281	293	281	303	320	334	321	345	364	380	361	388	410	427	399	429	453	472
		LO PR	102	109	119	126	108	115	125	133	112	119	130	139	118	125	137	146	123	131	143	153	128	136	148	158
	3021	MBh	86.7	88.5	94.6	101.1	84.6	86.5	92.4	98.8	82.6	84.4	90.2	96.4	80.6	82.4	**88.0**	94.1	76.6	78.2	83.6	89.4	70.9	72.5	77.4	82.8
		S/T	0.84	0.79	0.64	0.48	0.87	0.81	0.66	0.50	0.89	0.84	0.68	0.51	0.92	0.86	**0.70**	0.52	0.95	0.90	0.73	0.54	0.96	0.90	0.73	0.55
		ΔT	22	21	18	15	22	21	19	15	22	21	19	15	23	22	**19**	15	22	21	19	15	21	20	17	14
		kW	6.87	7.00	7.20	7.41	7.34	7.49	7.70	7.93	7.76	7.92	8.15	8.40	8.13	8.30	**8.55**	8.81	8.45	8.62	8.88	9.16	8.72	8.90	9.17	9.46
		Amps	18.7	19.1	19.6	20.3	20.0	20.4	21.0	21.7	21.5	22.0	22.7	23.4	22.9	23.4	**24.1**	24.9	24.2	24.7	25.5	26.4	25.5	26.1	26.9	27.8
		HI PR	227	245	258	270	255	275	290	302	290	312	330	344	331	356	**376**	392	372	400	423	441	411	442	467	487
		LO PR	105	112	122	130	111	118	129	138	116	123	134	143	121	129	**141**	150	127	135	148	157	132	140	[illegible]	[illegible]
	3375	MBh	88.0	89.9	96.0	102.6	85.9	87.8	93.8	100.3	83.9	85.7	91.6	97.9	81.8	83.6	89.3	95.5	77.7	79.4	84.9	90.7	72.0	73.6	[illegible]	[illegible]
		S/T	0.88	0.82	0.67	0.50	0.91	0.85	0.69	0.52	0.93	0.87	0.71	0.53	0.96	0.90	0.73	0.55	1.00	0.93	0.76	0.57	1.00	0.94	[illegible]	[illegible]
		ΔT	21	20	17	14	21	20	18	14	21	20	18	14	21	21	18	14	21	20	18	14	20	19	[illegible]	[illegible]
		kW	6.90	7.03	7.23	7.44	7.38	7.52	7.74	7.98	7.80	7.96	8.20	8.45	8.18	8.34	8.59	8.86	8.49	8.67	8.93	9.21	8.77	8.95	[illegible]	[illegible]
		Amps	18.8	19.2	19.7	20.4	20.1	20.6	21.2	21.9	21.7	22.1	22.8	23.6	23.0	23.5	24.2	25.1	24.3	24.9	25.6	26.5	25.7	26.2	[illegible]	[illegible]
		HI PR	229	246	260	271	257	277	292	305	292	314	332	346	333	358	378	394	374	403	426	444	414	445	[illegible]	[illegible]
		LO PR	106	113	123	131	112	119	130	139	116	124	135	144	122	130	142	151	128	136	149	158	133	141	[illegible]	[illegible]
85	2625	MBh	81.4	83.0	86.9	92.7	79.5	81.0	84.9	90.5	77.6	79.1	82.8	88.4	75.7	77.2	80.8	86.2	71.9	73.3	76.8	81.9	66.6	67.9	[illegible]	[illegible]
		S/T	0.85	0.82	0.74	0.60	0.88	0.85	0.76	0.62	0.90	0.87	0.78	0.64	0.93	0.90	0.81	0.66	0.96	0.93	0.84	0.68	0.97	0.94	[illegible]	[illegible]
		ΔT	24	24	22	19	24	24	23	20	24	24	23	20	25	24	23	20	24	24	23	20	23	22	[illegible]	[illegible]
		kW	6.77	6.89	7.09	7.29	7.23	7.37	7.59	7.81	7.64	7.80	8.03	8.27	8.01	8.17	8.41	8.67	8.32	8.49	8.74	9.02	8.58	8.76	[illegible]	[illegible]
		Amps	18.4	18.8	19.3	19.9	19.7	20.1	20.7	21.4	21.2	21.6	22.3	23.0	22.5	23.0	23.7	24.5	23.8	24.3	25.1	25.9	25.1	25.6	[illegible]	[illegible]
		HI PR	223	240	253	264	250	269	284	296	284	306	323	337	324	348	368	384	364	392	414	432	403	433	[illegible]	[illegible]
		LO PR	103	110	120	128	109	116	127	135	113	120	132	140	119	127	138	147	125	133	145	154	129	137	150	159
	3021	MBh	88.2	89.9	94.1	100.4	86.1	87.8	91.9	98.1	84.1	85.7	89.7	95.7	82.0	83.6	87.6	93.4	77.9	79.4	83.2	88.7	72.2	73.6	77.1	82.2
		S/T	0.88	0.85	0.77	0.62	0.91	0.88	0.79	0.64	0.93	0.90	0.81	0.66	0.96	0.93	0.84	0.68	1.00	0.97	0.87	0.71	1.00	0.97	0.88	0.71
		ΔT	24	23	22	19	24	23	22	19	24	24	22	19	24	24	22	19	24	23	22	19	22	22	21	18
		kW	6.91	7.05	7.25	7.46	7.40	7.54	7.76	7.99	7.82	7.98	8.21	8.46	8.19	8.36	8.61	8.88	8.51	8.69	8.95	9.23	8.79	8.97	9.25	9.54
		Amps	18.8	19.2	19.8	20.4	20.2	20.6	21.2	21.9	21.7	22.2	22.9	23.6	23.1	23.6	24.3	25.1	24.4	24.9	25.7	26.6	25.7	26.3	27.1	28.1
		HI PR	230	247	261	272	258	277	293	305	293	315	333	347	334	359	379	396	376	404	427	445	415	447	472	492
		LO PR	106	113	123	131	112	119	130	139	117	124	136	144	123	130	142	152	129	137	149	159	133	141	154	164
	3375	MBh	89.5	91.2	95.5	101.9	87.4	89.1	93.3	99.6	85.3	87.0	91.1	97.2	83.2	84.9	88.9	94.8	79.1	80.6	84.4	90.1	73.3	74.7	78.2	83.4
		S/T	0.92	0.89	0.80	0.65	0.95	0.92	0.83	0.67	0.98	0.94	0.85	0.69	1.00	0.97	0.88	0.71	1.00	1.00	0.91	0.74	1.00	1.00	0.92	0.74
		ΔT	22	22	21	18	23	22	21	18	23	22	21	18	23	22	21	18	22	22	21	18	20	20	20	17
		kW	6.95	7.08	7.29	7.50	7.43	7.58	7.80	8.04	7.86	8.02	8.26	8.51	8.24	8.41	8.66	8.93	8.56	8.73	9.00	9.28	8.84	9.02	9.30	9.59
		Amps	18.9	19.3	19.9	20.6	20.3	20.7	21.3	22.0	21.8	22.3	23.0	23.8	23.2	23.7	24.4	25.3	24.5	25.1	25.9	26.8	25.9	26.5	27.3	28.2
		HI PR	231	249	263	274	260	279	295	308	295	318	335	350	336	362	382	398	378	407	430	448	418	450	475	495
		LO PR	107	114	124	132	113	120	131	140	118	125	137	145	123	131	143	153	129	138	150	160	134	142	155	166

IDB: Entering Indoor Dry Bulb Temperature

High and low pressures are measured at the liquid and suction service valves.

Shaded area reflects AHRI (TVA) conditions

Amps = outdoor unit amps (comp.+fan)

kW = Total system power

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/04/13

EXPANDED COOLING DATA — :3743*6D*+TXV

IDB	Airflow		Outdoor Ambient Temperature 65ºF				75ºF				85ºF				95ºF				105ºF				115ºF			
			Entering Indoor Wet Bulb Temperature																							
			59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71
70	2625	MBh	79.0	81.9	89.7	-	77.2	80.0	87.7	-	75.4	78.1	85.6	-	73.5	76.2	83.5	-	69.8	72.4	79.3	-	64.7	67.1	73.5	-
		S/T	0.65	0.54	0.38	-	0.67	0.56	0.39	-	0.69	0.58	0.40	-	0.71	0.59	0.41	-	0.74	0.62	0.43	-	0.74	0.62	0.43	-
		ΔT	18	16	12	-	18	16	12	-	18	16	12	-	18	16	12	-	18	16	12	-	17	15	11	-
		kW	5.46	5.58	5.77	-	5.91	6.05	6.25	-	6.31	6.46	6.68	-	6.66	6.82	7.05	-	6.96	7.12	7.37	-	7.22	7.39	7.65	-
		Amps	23.7	24.0	24.5	-	24.9	25.3	25.9	-	26.3	26.8	27.4	-	27.6	28.1	28.7	-	28.8	29.3	30.1	-	30.1	30.6	31.4	-
		HI PR	216	233	246	-	243	261	276	-	276	297	313	-	314	338	357	-	353	380	402	-	391	420	444	-
		LO PR	116	123	135	-	122	130	142	-	127	135	148	-	134	142	155	-	140	149	163	-	145	154	168	-
	3032	MBh	85.6	88.7	97.2	-	83.6	86.7	95.0	-	81.6	84.6	92.7	-	79.7	82.6	90.5	-	75.7	78.4	85.9	-	70.1	72.6	79.6	-
		S/T	0.67	0.56	0.39	-	0.70	0.58	0.40	-	0.71	0.60	0.41	-	0.74	0.62	0.43	-	0.77	0.64	0.44	-	0.77	0.64	0.45	-
		ΔT	17	15	11	-	18	15	12	-	18	15	12	-	18	15	12	-	18	15	12	-	16	14	11	-
		kW	5.60	5.73	5.93	-	6.07	6.21	6.42	-	6.48	6.63	6.86	-	6.84	7.00	7.25	-	7.15	7.32	7.57	-	7.41	7.59	7.86	-
		Amps	24.1	24.5	25.0	-	25.4	25.8	26.4	-	26.9	27.3	27.9	-	28.1	28.6	29.3	-	29.4	29.9	30.7	-	30.7	31.2	32.0	-
		HI PR	223	240	253	-	250	269	284	-	284	306	323	-	324	349	368	-	364	392	414	-	403	433	458	-
		LO PR	119	127	139	-	126	134	147	-	131	140	152	-	138	147	160	-	144	154	168	-	149	159	[illegible]	-
	3375	MBh	86.9	90.1	98.7	-	84.9	88.0	96.4	-	82.9	85.9	94.1	-	80.8	83.8	91.8	-	76.8	79.6	87.2	-	71.1	73.7	[illegible]	-
		S/T	0.70	0.59	0.41	-	0.73	0.61	0.42	-	0.75	0.62	0.43	-	0.77	0.64	0.45	-	0.80	0.67	0.46	-	0.81	0.67	[illegible]	-
		ΔT	17	14	11	-	17	15	11	-	17	15	11	-	17	15	11	-	17	14	11	-	16	14	[illegible]	-
		kW	5.64	5.77	5.96	-	6.11	6.25	6.46	-	6.52	6.67	6.90	-	6.88	7.05	7.29	-	7.19	7.36	7.62	-	7.46	7.64	[illegible]	-
		Amps	24.2	24.6	25.1	-	25.5	25.9	26.5	-	27.0	27.4	28.1	-	28.3	28.8	29.4	-	29.6	30.1	30.8	-	30.8	31.4	[illegible]	-
		HI PR	224	242	255	-	252	271	286	-	286	308	325	-	326	351	371	-	367	395	417	-	405	436	[illegible]	-
		LO PR	120	128	140	-	127	135	148	-	132	141	153	-	139	148	161	-	145	155	169	-	150	160	[illegible]	-
75	2625	MBh	80.4	82.7	89.6	96.1	78.5	80.8	87.5	93.9	76.6	78.9	85.4	91.7	74.8	**77.0**	83.3	89.4	71.0	73.1	79.2	85.0	65.8	67.7	[illegible]	[illegible]
		S/T	0.74	0.66	0.50	0.32	0.76	0.68	0.52	0.33	0.78	0.70	0.53	0.34	0.81	**0.72**	0.55	0.35	0.84	0.75	0.57	0.37	0.85	0.76	[illegible]	[illegible]
		ΔT	21	19	16	11	21	19	16	11	21	19	16	11	21	**19**	16	11	21	19	16	11	19	18	[illegible]	[illegible]
		kW	5.51	5.63	5.82	6.02	5.96	6.10	6.31	6.53	6.36	6.51	6.74	6.98	6.72	**6.88**	7.12	7.37	7.02	7.19	7.44	7.70	7.28	7.45	[illegible]	[illegible]
		Amps	23.8	24.2	24.7	25.3	25.1	25.5	26.0	26.7	26.5	27.0	27.6	28.3	27.8	**28.3**	28.9	29.7	29.0	29.5	30.3	31.1	30.3	30.8	[illegible]	[illegible]
		HI PR	218	235	248	259	245	264	278	290	279	300	317	330	317	**342**	361	376	357	384	406	423	395	425	446	468
		LO PR	117	125	136	145	124	132	144	153	129	137	149	159	135	**144**	157	167	142	151	164	175	146	156	170	181
	3032	MBh	87.1	89.7	97.0	104.1	85.1	87.6	94.8	101.7	83.0	85.5	92.5	99.3	81.0	**83.4**	90.3	96.9	77.0	79.2	85.8	92.0	71.3	73.4	79.4	85.3
		S/T	0.76	0.68	0.52	0.33	0.79	0.71	0.54	0.35	0.81	0.73	0.55	0.35	0.84	**0.75**	0.57	0.37	0.87	0.78	0.59	0.38	0.88	0.78	0.59	0.38
		ΔT	20	19	15	11	20	19	15	11	20	19	15	11	21	**19**	16	11	20	19	15	11	19	17	14	10
		kW	5.65	5.78	5.98	6.19	6.12	6.26	6.48	6.71	6.54	6.69	6.92	7.17	6.90	**7.07**	7.31	7.57	7.21	7.38	7.64	7.92	7.48	7.66	7.93	8.22
		Amps	24.2	24.6	25.2	25.8	25.5	25.9	26.5	27.2	27.0	27.5	28.1	28.9	28.3	**28.8**	29.5	30.3	29.6	30.2	30.9	31.8	30.9	31.5	32.3	33.2
		HI PR	225	242	256	267	253	272	287	299	287	309	326	341	327	**352**	372	388	368	396	418	436	407	438	462	482
		LO PR	121	128	140	149	128	136	148	158	133	141	154	164	139	**148**	162	172	146	155	169	180	151	161	175	187
	3375	MBh	88.4	91.0	98.5	105.7	86.3	88.9	96.2	103.3	84.3	86.8	93.9	100.8	82.2	**84.6**	91.6	98.3	78.1	80.4	87.0	93.4	72.3	74.5	80.6	86.5
		S/T	0.80	0.71	0.54	0.35	0.83	0.74	0.56	0.36	0.85	0.76	0.57	0.37	0.88	**0.78**	0.59	0.38	0.91	0.81	0.62	0.40	0.92	0.82	0.62	0.40
		ΔT	19	18	14	10	19	18	15	10	19	18	15	10	20	**18**	15	10	19	18	15	10	18	17	14	9
		kW	5.69	5.82	6.01	6.22	6.16	6.30	6.52	6.75	6.58	6.73	6.96	7.21	6.95	**7.11**	7.36	7.62	7.26	7.43	7.69	7.97	7.53	7.71	7.98	8.27
		Amps	24.3	24.7	25.3	25.9	25.6	26.1	26.7	27.3	27.2	27.6	28.3	29.0	28.5	**29.0**	29.6	30.5	29.8	30.3	31.0	31.9	31.1	31.6	32.4	33.3
		HI PR	227	244	258	269	254	274	289	302	289	311	329	343	330	**355**	374	391	371	399	421	439	410	441	465	485
		LO PR	122	129	141	150	128	137	149	159	133	142	155	165	140	**149**	163	173	147	156	171	182	152	162	176	188

IDB: Entering Indoor Dry Bulb Temperature

Shaded area reflects ACCA (TVA) conditions

Amps = outdoor unit amps (comp.+fan)

High and low pressures are measured at the liquid and suction service valves.

kW = Total system power

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/04/13

CITY OF PORTLAND, MAINE — RESURGAM

Expanded Cooling Data — D

:3743*6D*+TXV (cont.)

Product Specifications

			Outdoor Ambient Temperature																							
			65ºF				75ºF				85ºF				95ºF				105ºF				115ºF			
			Entering Indoor Wet Bulb Temperature																							
IDB	Airflow		59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71
80	2625	MBh	81.8	83.6	89.3	95.5	79.9	81.6	87.2	93.2	78.0	79.7	85.1	91.0	76.1	77.8	83.1	88.8	72.3	73.9	78.9	84.4	67.0	68.4	73.1	78.1
		S/T	0.81	0.76	0.62	0.46	0.84	0.79	0.64	0.48	0.86	0.81	0.66	0.49	0.89	0.83	0.68	0.51	0.92	0.86	0.70	0.53	0.93	0.87	0.71	0.53
		ΔT	23	22	19	15	23	22	20	16	23	22	20	16	24	23	20	16	23	22	19	16	22	21	18	14
		kW	5.55	5.68	5.87	6.08	6.01	6.15	6.37	6.59	6.42	6.57	6.80	7.04	6.78	6.94	7.18	7.44	7.08	7.25	7.51	7.77	7.35	7.52	7.79	8.07
		Amps	23.9	24.3	24.8	25.5	25.2	25.6	26.2	26.9	26.7	27.1	27.8	28.5	28.0	28.4	29.1	29.9	29.2	29.7	30.5	31.3	30.5	31.0	31.8	32.7
		HI PR	221	237	251	261	248	266	281	293	281	303	320	334	321	345	364	380	361	388	410	427	399	429	453	472
		LO PR	118	126	137	146	125	133	145	155	130	138	151	161	136	145	158	169	143	152	166	177	148	157	172	183
	3032	MBh	88.6	90.6	96.8	103.4	86.6	88.5	94.5	101.0	84.5	86.3	92.3	98.6	82.4	84.2	**90.0**	96.2	78.3	80.0	85.5	91.4	72.5	74.1	79.2	84.7
		S/T	0.84	0.79	0.64	0.48	0.87	0.81	0.66	0.50	0.89	0.84	0.68	0.51	0.92	0.86	**0.70**	0.52	0.95	0.90	0.73	0.54	0.96	0.90	0.73	0.55
		ΔT	23	22	19	15	23	22	19	15	23	22	19	15	23	22	**19**	15	23	22	19	15	21	20	18	14
		kW	5.70	5.83	6.03	6.24	6.18	6.32	6.54	6.77	6.59	6.75	6.98	7.23	6.96	7.13	**7.38**	7.64	7.28	7.45	7.71	7.99	7.55	7.73	8.00	8.29
		Amps	24.4	24.8	25.3	25.9	25.7	26.1	26.7	27.4	27.2	27.7	28.3	29.1	28.5	29.0	**29.7**	30.5	29.8	30.4	31.1	32.0	31.1	31.7	32.5	33.4
		HI PR	227	245	258	270	255	275	290	302	290	312	330	344	331	356	**376**	392	372	400	423	441	411	442	467	487
		LO PR	122	130	142	151	129	137	150	159	134	142	155	166	141	150	**163**	174	147	157	171	182	152	162	[illegible]	[illegible]
	3375	MBh	90.0	91.9	98.2	105.0	87.9	89.8	95.9	102.5	85.8	87.6	93.6	100.1	83.7	85.5	91.4	97.7	79.5	81.2	86.8	92.8	73.6	75.2	[illegible]	[illegible]
		S/T	0.88	0.82	0.67	0.50	0.91	0.85	0.69	0.52	0.93	0.87	0.71	0.53	0.96	0.90	0.73	0.55	1.00	0.93	0.76	0.57	1.00	0.94	[illegible]	[illegible]
		ΔT	21	21	18	14	22	21	18	14	22	21	18	14	22	21	18	15	22	21	18	14	20	19	[illegible]	[illegible]
		kW	5.74	5.87	6.07	6.28	6.21	6.36	6.58	6.81	6.64	6.79	7.03	7.28	7.01	7.17	7.42	7.69	7.32	7.50	7.76	8.04	7.60	7.78	[illegible]	[illegible]
		Amps	24.5	24.9	25.4	26.1	25.8	26.2	26.8	27.5	27.3	27.8	28.4	29.2	28.6	29.1	29.8	30.7	30.0	30.5	31.3	32.1	31.3	31.8	[illegible]	[illegible]
		HI PR	229	246	260	271	257	277	292	305	292	314	332	346	333	358	378	394	374	403	426	444	414	445	[illegible]	[illegible]
		LO PR	123	131	143	152	130	138	151	160	135	143	157	167	142	151	164	175	148	158	172	184	153	163	[illegible]	[illegible]
85	2625	MBh	83.2	84.8	88.9	94.8	81.3	82.9	86.8	92.6	79.4	80.9	84.7	90.4	77.4	78.9	82.7	88.2	73.6	75.0	78.5	83.8	68.1	69.4	[illegible]	[illegible]
		S/T	0.85	0.82	0.74	0.60	0.88	0.85	0.76	0.62	0.90	0.87	0.78	0.64	0.93	0.90	0.81	0.66	0.96	0.93	0.84	0.68	0.97	0.94	[illegible]	[illegible]
		ΔT	25	24	23	20	25	25	23	20	25	25	23	20	25	25	23	20	25	24	23	20	23	23	[illegible]	[illegible]
		kW	5.60	5.73	5.92	6.13	6.07	6.21	6.42	6.65	6.48	6.63	6.86	7.10	6.84	7.00	7.24	7.50	7.15	7.32	7.57	7.84	7.41	7.59	[illegible]	[illegible]
		Amps	24.1	24.5	25.0	25.6	25.4	25.8	26.4	27.0	26.9	27.3	27.9	28.7	28.1	28.6	29.3	30.1	29.4	29.9	30.7	31.5	30.7	31.2	[illegible]	[illegible]
		HI PR	223	240	253	264	250	269	284	296	284	306	323	337	324	348	368	384	364	392	414	432	403	433	457	477
		LO PR	119	127	139	148	126	134	147	156	131	140	152	162	138	147	160	170	144	154	168	179	149	159	173	185
	3032	MBh	90.2	91.9	96.3	102.7	88.1	89.8	94.0	100.3	86.0	87.6	91.8	97.9	83.9	85.5	89.6	95.5	79.7	81.2	85.1	90.8	73.8	75.2	78.8	84.1
		S/T	0.88	0.85	0.77	0.62	0.91	0.88	0.79	0.64	0.93	0.90	0.81	0.66	0.96	0.93	0.84	0.68	1.00	0.97	0.87	0.71	1.00	0.97	0.88	0.71
		ΔT	24	24	22	19	24	24	23	20	24	24	23	20	25	24	23	20	24	24	22	19	22	22	21	18
		kW	5.75	5.88	6.08	6.29	6.23	6.37	6.59	6.83	6.65	6.81	7.05	7.30	7.03	7.19	7.44	7.71	7.34	7.52	7.78	8.06	7.62	7.80	8.07	8.36
		Amps	24.5	24.9	25.5	26.1	25.8	26.3	26.9	27.6	27.4	27.8	28.5	29.3	28.7	29.2	29.9	30.7	30.0	30.6	31.3	32.2	31.3	31.9	32.7	33.6
		HI PR	230	247	261	272	258	277	293	305	293	315	333	347	334	359	379	396	376	404	427	445	415	447	472	492
		LO PR	123	131	143	152	130	138	151	161	135	144	157	167	142	151	165	176	149	158	173	184	154	164	179	190
	3375	MBh	91.5	93.3	97.7	104.2	89.4	91.1	95.4	101.8	87.3	89.0	93.2	99.4	85.1	86.8	90.9	97.0	80.9	82.4	86.3	92.1	74.9	76.4	80.0	85.3
		S/T	0.92	0.89	0.80	0.65	0.95	0.92	0.83	0.67	0.98	0.94	0.85	0.69	1.00	0.97	0.88	0.71	1.00	1.00	0.91	0.74	1.00	1.00	0.92	0.74
		ΔT	23	23	21	18	23	23	22	19	23	23	22	19	23	23	22	19	22	22	21	19	20	21	20	17
		kW	5.79	5.92	6.12	6.33	6.27	6.41	6.63	6.87	6.69	6.85	7.09	7.34	7.07	7.24	7.49	7.76	7.39	7.56	7.83	8.11	7.66	7.85	8.13	8.42
		Amps	24.6	25.0	25.6	26.2	26.0	26.4	27.0	27.7	27.5	28.0	28.6	29.4	28.8	29.3	30.0	30.9	30.2	30.7	31.5	32.4	31.5	32.1	32.9	33.8
		HI PR	231	249	263	274	260	279	295	308	295	318	335	350	336	362	382	398	378	407	430	448	418	450	475	495
		LO PR	124	132	144	153	131	139	152	162	136	145	158	168	143	152	166	177	150	159	174	185	155	165	180	192

IDB: Entering Indoor Dry Bulb Temperature
High and low pressures are measured at the liquid and suction service valves.

Shaded area reflects AHRI (TVA) conditions

Amps = outdoor unit amps (comp.+fan)
kW = Total system power

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/04/13

CITY OF PORTLAND, MAINE — RESURGAM

EXPANDED COOLING DATA — D

4860*6D*+TXV

IDB	Airflow		Outdoor Ambient Temperature 65ºF				75ºF				85ºF				95ºF				105ºF				115ºF			
			Entering Indoor Wet Bulb Temperature																							
			59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71
70	3063	MBh	100.1	103.8	113.7	-	97.8	101.3	111.0	-	95.4	98.9	108.4	-	93.1	96.5	105.7	-	88.5	91.7	100.5	-	81.9	84.9	93.1	-
		S/T	0.63	0.52	0.36	-	0.65	0.54	0.38	-	0.67	0.56	0.39	-	0.69	0.57	0.40	-	0.71	0.60	0.41	-	0.72	0.60	0.42	-
		ΔT	19	16	12	-	19	16	13	-	19	17	13	-	19	17	13	-	19	16	12	-	18	15	12	-
		kW	6.80	6.96	7.20	-	7.37	7.55	7.81	-	7.88	8.06	8.35	-	8.32	8.52	8.82	-	8.70	8.91	9.23	-	9.03	9.25	9.58	-
		Amps	22.2	22.7	23.4	-	23.8	24.4	25.1	-	25.8	26.3	27.2	-	27.4	28.0	28.9	-	29.1	29.7	30.7	-	30.7	31.4	32.4	-
		HI PR	231	249	263	-	260	280	295	-	295	318	336	-	336	362	382	-	379	407	430	-	418	450	475	-
		LO PR	95	101	110	-	100	106	116	-	104	111	121	-	109	116	127	-	114	122	133	-	118	126	137	-
	3529	MBh	108.5	112.4	123.2	-	105.9	109.8	120.3	-	103.4	107.2	117.4	-	100.9	104.6	114.6	-	95.8	99.3	108.8	-	88.8	92.0	100.8	-
		S/T	0.65	0.54	0.38	-	0.67	0.56	0.39	-	0.69	0.58	0.40	-	0.71	0.60	0.41	-	0.74	0.62	0.43	-	0.75	0.62	0.43	-
		ΔT	18	16	12	-	19	16	12	-	19	16	12	-	19	16	12	-	18	16	12	-	17	15	11	-
		kW	6.98	7.15	7.39	-	7.57	7.75	8.02	-	8.09	8.29	8.58	-	8.55	8.76	9.07	-	8.94	9.16	9.49	-	9.28	9.51	9.85	-
		Amps	22.8	23.3	24.0	-	24.5	25.0	25.8	-	26.4	27.0	27.9	-	28.1	28.8	29.7	-	29.8	30.5	31.5	-	31.5	32.2	33.3	-
		HI PR	239	257	271	-	268	288	304	-	305	328	346	-	347	373	394	-	390	420	443	-	431	464	490	-
		LO PR	98	104	113	-	103	110	120	-	107	114	124	-	113	120	131	-	118	125	137	-	122	130		
	3938	MBh	110.1	114.1	125.0	-	107.5	111.4	122.1	-	105.0	108.8	119.2	-	102.4	106.1	116.3	-	97.3	100.8	110.5	-	90.1	93.4		
		S/T	0.68	0.57	0.39	-	0.70	0.59	0.41	-	0.72	0.60	0.42	-	0.74	0.62	0.43	-	0.77	0.64	0.45	-	0.78	0.65		
		ΔT	17	15	11	-	18	15	12	-	18	15	12	-	18	15	12	-	18	15	12	-	16	14		
		kW	7.03	7.19	7.44	-	7.62	7.80	8.07	-	8.14	8.34	8.63	-	8.61	8.81	9.13	-	9.00	9.22	9.55	-	9.34	9.57		
		Amps	22.9	23.4	24.1	-	24.6	25.2	25.9	-	26.6	27.2	28.0	-	28.3	29.0	29.9	-	30.0	30.7	31.7	-	31.7	32.4		
		HI PR	240	259	273	-	270	290	306	-	307	330	348	-	349	376	397	-	393	423	447	-	434	467		
		LO PR	98	105	114	-	104	110	121	-	108	115	125	-	113	121	132	-	119	126	138	-	123	131		
75	3063	MBh	101.8	104.8	113.5	121.8	99.4	102.4	110.8	118.9	97.1	99.9	108.2	116.1	94.7	**97.5**	105.5	113.3	90.0	92.6	100.3	107.6	83.3	85.8		
		S/T	0.71	0.64	0.48	0.31	0.74	0.66	0.50	0.32	0.76	0.68	0.51	0.33	0.78	**0.70**	0.53	0.34	0.81	0.72	0.55	0.35	0.82	0.73		
		ΔT	22	20	16	11	22	20	17	11	22	20	17	11	22	**20**	17	12	22	20	17	11	20	19		
		kW	6.86	7.02	7.26	7.52	7.44	7.61	7.88	8.16	7.95	8.14	8.42	8.73	8.40	**8.60**	8.90	9.23	8.78	8.99	9.31	9.65	9.11	9.33		
		Amps	22.4	22.9	23.6	24.4	24.0	24.6	25.3	26.2	26.0	26.6	27.4	28.4	27.6	**28.3**	29.2	30.2	29.3	30.0	30.9	32.0	31.0	31.7		
		HI PR	234	252	266	277	262	282	298	311	298	321	339	354	340	**366**	386	403	382	411	435	453	422	455	480	501
		LO PR	96	102	111	118	101	107	117	125	105	112	122	130	110	**117**	128	136	116	123	134	143	120	127	139	148
	3529	MBh	110.3	113.6	122.9	131.9	107.7	110.9	120.1	128.9	105.2	108.3	117.2	125.8	102.6	**105.6**	114.3	122.7	97.5	100.4	108.6	116.6	90.3	93.0	100.6	108.0
		S/T	0.74	0.66	0.50	0.32	0.77	0.68	0.52	0.33	0.78	0.70	0.53	0.34	0.81	**0.72**	0.55	0.35	0.84	0.75	0.57	0.37	0.85	0.76	0.57	0.37
		ΔT	21	20	16	11	21	20	16	11	21	20	16	11	22	**20**	16	11	21	20	16	11	20	18	15	10
		kW	7.04	7.21	7.46	7.72	7.64	7.82	8.09	8.38	8.17	8.36	8.66	8.97	8.63	**8.84**	9.15	9.48	9.03	9.24	9.57	9.92	9.37	9.59	9.94	10.30
		Amps	23.0	23.5	24.2	25.0	24.7	25.2	26.0	26.9	26.7	27.3	28.1	29.1	28.4	**29.0**	29.9	31.0	30.1	30.8	31.8	32.9	31.8	32.5	33.6	34.8
		HI PR	241	259	274	286	271	291	307	321	308	331	350	365	350	**377**	398	415	394	424	448	467	436	469	495	516
		LO PR	99	105	115	122	104	111	121	129	108	115	126	134	114	**121**	132	141	119	127	138	147	123	131	143	152
	3938	MBh	111.9	115.3	124.8	133.9	109.3	112.6	121.9	130.8	106.7	109.9	119.0	127.7	104.1	**107.2**	116.1	124.6	98.9	101.9	110.3	118.3	91.6	94.4	102.1	109.6
		S/T	0.77	0.69	0.52	0.34	0.80	0.71	0.54	0.35	0.82	0.73	0.55	0.36	0.85	**0.76**	0.57	0.37	0.88	0.79	0.59	0.38	0.89	0.79	0.60	0.39
		ΔT	20	19	15	10	20	19	15	11	20	19	15	11	21	**19**	16	11	20	19	15	11	19	17	14	10
		kW	7.09	7.25	7.50	7.77	7.69	7.87	8.15	8.44	8.22	8.41	8.71	9.02	8.69	**8.89**	9.21	9.54	9.08	9.30	9.63	9.98	9.43	9.65	10.00	10.37
		Amps	23.1	23.6	24.3	25.2	24.8	25.4	26.2	27.1	26.8	27.4	28.3	29.3	28.6	**29.2**	30.1	31.2	30.3	31.0	32.0	33.1	32.0	32.7	33.8	35.0
		HI PR	243	261	276	288	272	293	310	323	310	333	352	367	353	**380**	401	418	397	427	451	470	439	472	498	520
		LO PR	99	106	115	123	105	112	122	130	109	116	127	135	115	**122**	133	142	120	128	139	148	124	132	144	154

IDB: Entering Indoor Dry Bulb Temperature
High and low pressures are measured at the liquid and suction service valves.

Shaded area reflects ACCA (TVA) conditions

Amps = outdoor unit amps (comp.+fan)
kW = Total system power

Date: 11/04/13

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

CITY OF PORTLAND, MAINE — RESURGAM

Expanded Cooling Data — D

4860*6D*+TXV (cont.)

Product Specifications

			Outdoor Ambient Temperature																							
			65ºF				75ºF				85ºF				95ºF				105ºF				115ºF			
			Entering Indoor Wet Bulb Temperature																							
IDB	Airflow		59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71
80	3063	MBh	103.6	105.9	113.1	120.9	101.2	103.4	110.5	118.1	98.8	100.9	107.9	115.3	96.4	98.5	105.2	112.5	91.6	93.6	100.0	106.9	84.8	86.7	92.6	99.0
		S/T	0.78	0.73	0.60	0.45	0.81	0.76	0.62	0.46	0.83	0.78	0.63	0.47	0.86	0.80	0.65	0.49	0.89	0.83	0.68	0.51	0.90	0.84	0.68	0.51
		ΔT	24	23	20	16	25	24	20	16	25	24	21	16	25	24	21	16	24	23	20	16	23	22	19	15
		kW	6.92	7.08	7.33	7.58	7.50	7.68	7.95	8.23	8.02	8.21	8.50	8.80	8.48	8.68	8.99	9.31	8.86	9.08	9.40	9.74	9.20	9.42	9.75	10.11
		Amps	22.6	23.1	23.8	24.6	24.3	24.8	25.6	26.4	26.2	26.8	27.6	28.6	27.9	28.5	29.4	30.5	29.6	30.3	31.2	32.3	31.2	32.0	33.0	34.2
		HI PR	236	254	268	280	265	285	301	314	301	324	343	357	343	369	390	407	386	416	439	458	427	459	485	506
		LO PR	97	103	112	119	102	109	119	126	106	113	123	131	111	119	129	138	117	124	136	144	121	128	140	149
	3529	MBh	112.3	114.7	122.6	131.0	109.6	112.0	119.7	128.0	107.0	109.4	116.9	124.9	104.4	106.7	**114.0**	121.9	99.2	101.4	108.3	115.8	91.9	93.9	100.3	107.2
		S/T	0.81	0.76	0.62	0.46	0.84	0.79	0.64	0.48	0.86	0.81	0.66	0.49	0.89	0.83	**0.68**	0.51	0.92	0.86	0.70	0.53	0.93	0.87	0.71	0.53
		ΔT	24	23	20	16	24	23	20	16	24	23	20	16	24	23	**20**	16	24	23	20	16	22	21	19	15
		kW	7.11	7.27	7.52	7.79	7.71	7.89	8.17	8.46	8.24	8.44	8.74	9.05	8.71	8.92	**9.24**	9.57	9.11	9.33	9.66	10.01	9.45	9.68	10.03	10.39
		Amps	23.1	23.7	24.4	25.2	24.9	25.4	26.2	27.1	26.9	27.5	28.4	29.4	28.6	29.3	**30.2**	31.3	30.4	31.1	32.1	33.2	32.1	32.8	33.9	35.1
		HI PR	244	262	277	289	273	294	310	324	311	334	353	368	354	381	**402**	419	398	428	452	472	440	473	500	521
		LO PR	100	106	116	123	105	112	122	130	109	116	127	135	115	122	**133**	142	120	128	140	149	125	132	[illegible]	[illegible]
	3938	MBh	113.9	116.4	124.4	133.0	111.3	113.7	121.5	129.9	108.6	111.0	118.6	126.8	106.0	108.3	115.7	123.7	100.7	102.9	109.9	117.5	93.3	95.3	[illegible]	[illegible]
		S/T	0.85	0.79	0.65	0.48	0.88	0.82	0.67	0.50	0.90	0.84	0.69	0.51	0.93	0.87	0.71	0.53	0.96	0.90	0.73	0.55	0.97	0.9[illegible]	[illegible]	[illegible]
		ΔT	22	22	19	15	23	22	19	15	23	22	19	15	23	22	19	15	23	22	19	15	21	20	[illegible]	[illegible]
		kW	7.15	7.32	7.57	7.84	7.76	7.94	8.22	8.51	8.29	8.49	8.79	9.11	8.76	8.98	9.29	9.63	9.17	9.39	9.72	10.08	9.51	9.74	[illegible]	[illegible]
		Amps	23.3	23.8	24.5	25.4	25.0	25.6	26.4	27.3	27.1	27.7	28.5	29.5	28.8	29.5	30.4	31.5	30.5	31.3	32.3	33.4	32.3	33.0	[illegible]	[illegible]
		HI PR	245	264	279	291	275	296	313	326	313	337	356	371	356	384	405	422	401	431	456	475	443	477	[illegible]	[illegible]
		LO PR	100	107	116	124	106	113	123	131	110	117	128	136	116	123	134	143	121	129	141	150	125	133	[illegible]	[illegible]
85	3063	MBh	105.4	107.5	112.5	120.1	103.0	105.0	109.9	117.3	100.5	102.5	107.3	114.5	98.1	100.0	104.7	111.7	93.2	95.0	99.5	106.1	86.3	88.0	[illegible]	[illegible]
		S/T	0.82	0.79	0.71	0.58	0.85	0.82	0.74	0.60	0.87	0.84	0.76	0.61	0.90	0.87	0.78	0.63	0.93	0.90	0.81	0.66	0.94	0.9[illegible]	[illegible]	[illegible]
		ΔT	26	25	24	21	26	26	24	21	26	26	24	21	26	26	25	21	26	26	24	21	24	24	[illegible]	[illegible]
		kW	6.98	7.14	7.39	7.65	7.57	7.75	8.02	8.31	8.09	8.28	8.58	8.88	8.55	8.76	9.07	9.39	8.94	9.16	9.48	9.83	9.28	9.50	[illegible]	[illegible]
		Amps	22.8	23.3	24.0	24.8	24.5	25.0	25.8	26.7	26.4	27.0	27.9	28.9	28.1	28.8	29.7	30.7	29.8	30.5	31.5	32.6	31.5	32.2	[illegible]	[illegible]
		HI PR	239	257	271	283	268	288	304	317	304	328	346	361	347	373	394	411	390	420	443	462	431	464	490	511
		LO PR	98	104	113	121	103	110	120	127	107	114	124	133	113	120	131	139	118	125	137	146	122	130	142	151
	3529	MBh	114.2	116.4	121.9	130.1	111.6	113.7	119.1	127.1	108.9	111.0	116.3	124.0	106.2	108.3	113.4	121.0	100.9	102.9	107.8	115.0	93.5	95.3	99.8	106.5
		S/T	0.85	0.82	0.74	0.60	0.88	0.85	0.77	0.62	0.90	0.87	0.79	0.64	0.93	0.90	0.81	0.66	0.97	0.93	0.84	0.68	0.97	0.94	0.85	0.69
		ΔT	25	25	23	20	26	25	24	21	26	25	24	21	26	25	24	21	25	25	24	20	24	23	22	19
		kW	7.17	7.34	7.59	7.86	7.78	7.96	8.24	8.53	8.31	8.51	8.81	9.13	8.79	9.00	9.32	9.66	9.19	9.41	9.75	10.10	9.54	9.77	10.12	10.49
		Amps	23.3	23.9	24.6	25.4	25.1	25.7	26.5	27.4	27.1	27.7	28.6	29.6	28.9	29.5	30.5	31.6	30.6	31.3	32.3	33.5	32.4	33.1	34.2	35.4
		HI PR	246	265	279	291	276	297	314	327	314	338	357	372	357	385	406	424	402	433	457	477	444	478	505	527
		LO PR	101	107	117	124	106	113	123	131	110	117	128	137	116	123	135	143	122	129	141	150	126	134	146	156
	3938	MBh	115.9	118.2	123.8	132.0	113.2	115.4	120.9	129.0	110.5	112.7	118.0	125.9	107.8	109.9	115.1	122.8	102.4	104.4	109.4	116.7	94.9	96.7	101.3	108.1
		S/T	0.89	0.86	0.77	0.63	0.92	0.89	0.80	0.65	0.94	0.91	0.82	0.67	0.97	0.94	0.85	0.69	1.00	0.97	0.88	0.71	1.00	0.98	0.89	0.72
		ΔT	24	24	22	19	24	24	23	20	24	24	23	20	24	24	23	20	24	24	22	19	22	22	21	18
		kW	7.21	7.38	7.64	7.91	7.83	8.01	8.29	8.59	8.37	8.57	8.87	9.19	8.84	9.06	9.38	9.72	9.25	9.47	9.81	10.17	9.60	9.83	10.18	10.56
		Amps	23.5	24.0	24.7	25.6	25.2	25.8	26.6	27.5	27.3	27.9	28.8	29.8	29.1	29.7	30.7	31.8	30.8	31.5	32.5	33.7	32.6	33.3	34.4	35.6
		HI PR	248	267	281	294	278	299	316	329	316	340	359	375	360	387	409	427	405	436	460	480	447	482	508	530
		LO PR	101	108	118	125	107	114	124	132	111	118	129	138	117	124	136	144	122	130	142	151	127	135	147	157

IDB: Entering Indoor Dry Bulb Temperature

High and low pressures are measured at the liquid and suction service valves.

Shaded area reflects AHRI (TVA) conditions

Amps = outdoor unit amps (comp.+fan)

kW = Total system power

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/04/13

EXPANDED COOLING DATA — D

4961*6D*+TXV

IDB	Airflow		Outdoor Ambient Temperature 65ºF				75ºF				85ºF				95ºF				105ºF				115ºF			
			Entering Indoor Wet Bulb Temperature																							
			59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71
70	3063	MBh	101.2	104.9	115.0	-	98.9	102.5	112.3	-	96.5	100.0	109.6	-	94.2	97.6	106.9	-	89.5	92.7	101.6	-	82.9	85.9	94.1	-
		S/T	0.63	0.53	0.36	-	0.65	0.54	0.38	-	0.67	0.56	0.39	-	0.69	0.58	0.40	-	0.72	0.60	0.41	-	0.72	0.60	0.42	-
		ΔT	19	17	13	-	19	17	13	-	19	17	13	-	20	17	13	-	19	17	13	-	18	16	12	-
		kW	6.60	6.78	7.05	-	7.25	7.44	7.74	-	7.82	8.03	8.36	-	8.33	8.55	8.90	-	8.76	9.00	9.36	-	9.13	9.38	9.75	-
		Amps	28.1	28.6	29.4	-	29.8	30.4	31.2	-	31.8	32.4	33.2	-	33.5	34.1	35.0	-	35.2	35.9	36.8	-	36.9	37.6	38.6	-
		HI PR	228	245	259	-	256	275	291	-	291	313	331	-	332	357	377	-	373	401	424	-	412	443	468	-
		LO PR	99	105	115	-	105	111	121	-	109	116	126	-	114	121	133	-	120	127	139	-	124	132	144	-
	3438	MBh	106.6	110.4	121.0	-	104.1	107.9	118.2	-	101.6	105.3	115.4	-	99.1	102.7	112.6	-	94.2	97.6	106.9	-	87.2	90.4	99.1	-
		S/T	0.66	0.55	0.38	-	0.68	0.57	0.39	-	0.70	0.58	0.40	-	0.72	0.60	0.42	-	0.75	0.62	0.43	-	0.75	0.63	0.44	-
		ΔT	19	16	12	-	19	16	12	-	19	16	12	-	19	17	13	-	19	16	12	-	18	15	12	-
		kW	6.74	6.92	7.20	-	7.40	7.60	7.90	-	7.98	8.20	8.53	-	8.50	8.73	9.08	-	8.94	9.18	9.55	-	9.32	9.57	9.95	-
		Amps	28.5	29.0	29.8	-	30.3	30.8	31.6	-	32.3	32.9	33.7	-	34.0	34.6	35.6	-	35.7	36.4	37.4	-	37.4	38.2	39.2	-
		HI PR	233	250	265	-	261	281	297	-	297	320	338	-	338	364	384	-	381	410	433	-	421	453	478	-
		LO PR	101	107	117	-	107	113	124	-	111	118	129	-	116	124	135	-	122	130	142	-	126	134	[illegible]	[illegible]
	3938	MBh	109.8	113.8	124.6	-	107.2	111.1	121.7	-	104.6	108.5	118.8	-	102.1	105.8	115.9	-	97.0	100.5	110.1	-	89.8	93.[illegible]		
		S/T	0.69	0.58	0.40	-	0.71	0.60	0.41	-	0.73	0.61	0.42	-	0.76	0.63	0.44	-	0.78	0.66	0.45	-	0.79	0.66		
		ΔT	18	15	12	-	18	15	12	-	18	15	12	-	18	16	12	-	18	15	12	-	17	14		
		kW	6.80	6.99	7.27	-	7.47	7.68	7.98	-	8.07	8.28	8.62	-	8.59	8.82	9.17	-	9.03	9.28	9.65	-	9.41	9.67		
		Amps	28.7	29.2	30.0	-	30.5	31.0	31.8	-	32.5	33.1	34.0	-	34.2	34.9	35.8	-	36.0	36.7	37.7	-	37.7	38.5		
		HI PR	235	253	267	-	264	284	300	-	300	323	341	-	342	368	388	-	384	414	437	-	425	457		
		LO PR	102	108	118	-	108	115	125	-	112	119	130	-	118	125	137	-	123	131	143	-	127	136		
75	3063	MBh	102.9	106.0	114.7	123.1	100.5	103.5	112.1	120.3	98.2	101.1	109.4	117.4	95.8	**98.6**	106.7	114.5	91.0	93.7	101.4	108.8	84.3	86.8		
		S/T	0.72	0.64	0.48	0.31	0.74	0.66	0.50	0.32	0.76	0.68	0.51	0.33	0.78	**0.70**	0.53	0.34	0.81	0.73	0.55	0.35	0.82	0.73		
		ΔT	22	20	17	12	22	21	17	12	22	21	17	12	23	**21**	17	12	22	20	17	12	21	19		
		kW	6.67	6.85	7.12	7.41	7.32	7.52	7.82	8.14	7.90	8.12	8.44	8.78	8.41	**8.64**	8.99	9.35	8.85	9.09	9.45	9.84	9.23	9.47		
		Amps	28.3	28.8	29.6	30.4	30.1	30.6	31.4	32.3	32.0	32.6	33.5	34.5	33.7	**34.4**	35.3	36.4	35.5	36.1	37.1	38.3	37.1	37.9		
		HI PR	230	248	262	273	259	278	294	306	294	316	334	349	335	**360**	381	397	377	405	428	447	416	448	473	493
		LO PR	100	106	116	124	106	112	123	131	110	117	127	136	115	**123**	134	143	121	129	140	149	125	133	145	155
	3438	MBh	108.4	111.6	120.8	129.6	105.8	109.0	118.0	126.6	103.3	106.4	115.1	123.6	100.8	**103.8**	112.3	120.6	95.8	98.6	106.7	114.5	88.7	91.3	98.9	106.1
		S/T	0.75	0.67	0.51	0.33	0.77	0.69	0.52	0.34	0.79	0.71	0.54	0.35	0.82	**0.73**	0.55	0.36	0.85	0.76	0.58	0.37	0.86	0.77	0.58	0.37
		ΔT	22	20	16	11	22	20	17	11	22	20	17	11	22	**20**	17	12	22	20	16	11	20	19	15	11
		kW	6.80	6.99	7.27	7.57	7.48	7.68	7.99	8.31	8.07	8.29	8.62	8.97	8.59	**8.82**	9.17	9.55	9.03	9.28	9.65	10.04	9.42	9.67	10.06	10.46
		Amps	28.7	29.2	30.0	30.8	30.5	31.0	31.8	32.7	32.5	33.1	34.0	35.0	34.2	**34.9**	35.8	36.9	36.0	36.7	37.7	38.9	37.7	38.5	39.5	40.8
		HI PR	235	253	267	279	264	284	300	313	300	323	341	356	342	**368**	388	405	384	414	437	456	425	457	483	504
		LO PR	102	108	118	126	108	115	125	133	112	119	130	139	118	**125**	137	146	123	131	143	152	128	136	148	158
	3938	MBh	111.6	114.9	124.4	133.5	109.0	112.2	121.5	130.4	106.4	109.6	118.6	127.3	103.8	**106.9**	115.7	124.2	98.6	101.6	109.9	118.0	91.4	94.1	101.8	109.3
		S/T	0.78	0.70	0.53	0.34	0.81	0.73	0.55	0.35	0.83	0.74	0.56	0.36	0.86	**0.77**	0.58	0.37	0.89	0.80	0.60	0.39	0.90	0.80	0.61	0.39
		ΔT	20	19	15	11	21	19	16	11	21	19	16	11	21	**19**	16	11	21	19	15	11	19	18	14	10
		kW	6.87	7.06	7.34	7.64	7.55	7.76	8.07	8.39	8.15	8.37	8.70	9.06	8.68	**8.91**	9.27	9.64	9.12	9.37	9.75	10.14	9.51	9.77	10.16	10.57
		Amps	28.9	29.4	30.2	31.0	30.7	31.3	32.1	33.0	32.7	33.3	34.2	35.2	34.5	**35.2**	36.1	37.2	36.3	37.0	38.0	39.1	38.0	38.8	39.8	41.1
		HI PR	237	256	270	281	266	287	303	316	303	326	344	359	345	**371**	392	409	388	418	441	460	429	462	488	509
		LO PR	103	110	120	127	109	116	126	135	113	120	131	140	119	**126**	138	147	125	132	145	154	129	137	150	159

IDB: Entering Indoor Dry Bulb Temperature
High and low pressures are measured at the liquid and suction service valves.

Shaded area reflects ACCA (TVA) conditions

Amps = outdoor unit amps (comp.+fan)
kW = Total system power

Date: 11/04/13

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

CITY OF PORTLAND, MAINE — RESURGAM

Expanded Cooling Data — D

4961*6D*+TXV (cont.)

Product Specifications

IDB	Airflow		Outdoor Ambient Temperature																							
			65ºF				75ºF				85ºF				95ºF				105ºF				115ºF			
			Entering Indoor Wet Bulb Temperature																							
			59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71	59	63	67	71
80	3063	MBh	104.8	107.1	114.4	122.3	102.3	104.6	111.7	119.4	99.9	102.1	109.1	116.6	97.5	99.6	106.4	113.7	92.6	94.6	101.1	108.1	85.8	87.6	93.6	100.1
		S/T	0.78	0.74	0.60	0.45	0.81	0.76	0.62	0.46	0.83	0.78	0.64	0.48	0.86	0.81	0.66	0.49	0.89	0.84	0.68	0.51	0.90	0.84	0.69	0.51
		ΔT	25	24	21	16	25	24	21	17	25	24	21	17	25	24	21	17	25	24	21	17	23	22	19	15
		kW	6.74	6.92	7.20	7.49	7.40	7.60	7.90	8.22	7.98	8.20	8.53	8.87	8.50	8.73	9.08	9.45	8.94	9.18	9.55	9.94	9.32	9.57	9.95	10.36
		Amps	28.5	29.0	29.8	30.6	30.3	30.8	31.6	32.5	32.3	32.9	33.7	34.7	34.0	34.6	35.6	36.6	35.7	36.4	37.4	38.6	37.4	38.2	39.2	40.4
		HI PR	233	250	265	276	261	281	297	310	297	320	338	352	338	364	384	401	381	410	433	451	421	453	478	498
		LO PR	101	107	117	125	107	113	124	132	111	118	129	137	116	124	135	144	122	130	142	151	126	134	147	156
	3438	MBh	110.3	112.7	120.4	128.7	107.7	110.1	117.6	125.7	105.2	107.5	114.8	122.7	102.6	104.8	**112.0**	119.7	97.5	99.6	106.4	113.7	90.3	92.3	98.6	105.4
		S/T	0.82	0.77	0.63	0.47	0.85	0.80	0.65	0.48	0.87	0.82	0.66	0.50	0.90	0.84	**0.69**	0.51	0.93	0.87	0.71	0.53	0.94	0.88	0.72	0.54
		ΔT	24	23	20	16	24	23	20	16	24	23	20	16	25	24	**21**	16	24	23	20	16	23	22	19	15
		kW	6.87	7.06	7.34	7.64	7.55	7.76	8.07	8.39	8.15	8.37	8.71	9.06	8.68	8.91	**9.27**	9.64	9.13	9.37	9.75	10.14	9.51	9.77	10.16	10.57
		Amps	28.9	29.4	30.2	31.0	30.7	31.3	32.1	33.0	32.7	33.4	34.2	35.2	34.5	35.2	**36.1**	37.2	36.3	37.0	38.0	39.2	38.0	38.8	39.8	41.1
		HI PR	238	256	270	282	267	287	303	316	303	326	344	359	345	372	**392**	409	388	418	441	460	429	462	488	509
		LO PR	103	110	120	127	109	116	126	135	113	120	131	140	119	126	**138**	147	125	132	145	154	129	137	[illegible]	[illegible]
	3938	MBh	113.6	116.1	124.0	132.6	111.0	113.4	121.1	129.5	108.3	110.7	118.2	126.4	105.7	108.0	115.4	123.3	100.4	102.6	109.6	117.2	93.0	95.[illegible]		
		S/T	0.86	0.81	0.66	0.49	0.89	0.83	0.68	0.51	0.91	0.86	0.70	0.52	0.94	0.88	0.72	0.54	1.00	0.92	0.75	0.56	1.00	0.9[illegible]		
		ΔT	23	22	19	15	23	22	19	15	23	22	19	15	23	22	19	15	23	22	19	15	22	21		
		kW	6.94	7.13	7.42	7.72	7.63	7.83	8.15	8.48	8.23	8.45	8.79	9.15	8.76	9.00	9.36	9.74	9.22	9.47	9.85	10.24	9.61	9.8[illegible]		
		Amps	29.1	29.6	30.4	31.3	30.9	31.5	32.3	33.2	33.0	33.6	34.5	35.5	34.7	35.4	36.4	37.5	36.5	37.2	38.3	39.5	38.3	39.[illegible]		
		HI PR	240	258	273	284	269	290	306	319	306	329	348	363	349	375	396	413	392	422	446	465	433	466		
		LO PR	104	111	121	129	110	117	128	136	114	122	133	141	120	128	139	148	126	134	146	156	130	138		
85	3063	MBh	106.6	108.7	113.8	121.4	104.1	106.1	111.2	118.6	101.6	103.6	108.5	115.8	99.2	101.1	105.9	112.9	94.2	96.0	100.6	107.3	87.3	89.[illegible]		
		S/T	0.82	0.79	0.72	0.58	0.85	0.82	0.74	0.60	0.87	0.84	0.76	0.62	0.90	0.87	0.79	0.64	0.94	0.90	0.82	0.66	0.94	0.9[illegible]		
		ΔT	26	26	24	21	27	26	25	21	27	26	25	21	27	26	25	22	26	26	25	21	25	24		
		kW	6.80	6.99	7.27	7.56	7.47	7.68	7.98	8.31	8.07	8.28	8.62	8.96	8.59	8.82	9.17	9.54	9.03	9.28	9.65	10.04	9.41	9.6[illegible]		
		Amps	28.7	29.2	30.0	30.8	30.5	31.0	31.8	32.7	32.5	33.1	34.0	35.0	34.2	34.9	35.8	36.9	36.0	36.7	37.7	38.8	37.7	38.[illegible]		
		HI PR	235	253	267	279	264	284	300	313	300	323	341	356	342	368	388	405	384	414	437	456	425	457	483	503
		LO PR	102	108	118	126	108	115	125	133	112	119	130	138	118	125	137	145	123	131	143	152	127	136	148	158
	3438	MBh	112.2	114.4	119.8	127.8	109.6	111.7	117.0	124.8	107.0	109.1	114.2	121.9	104.4	106.4	111.4	118.9	99.2	101.1	105.9	112.9	91.9	93.6	98.1	104.6
		S/T	0.86	0.83	0.75	0.61	0.89	0.86	0.78	0.63	0.91	0.88	0.79	0.64	0.94	0.91	0.82	0.67	0.98	0.94	0.85	0.69	0.99	0.95	0.86	0.70
		ΔT	26	25	24	21	26	26	24	21	26	26	24	21	26	26	24	21	26	26	24	21	24	24	23	19
		kW	6.94	7.13	7.42	7.72	7.63	7.83	8.15	8.48	8.23	8.45	8.79	9.15	8.76	9.00	9.36	9.74	9.22	9.47	9.85	10.24	9.61	9.87	10.26	10.68
		Amps	29.1	29.6	30.4	31.3	30.9	31.5	32.3	33.2	33.0	33.6	34.5	35.5	34.7	35.4	36.4	37.5	36.5	37.2	38.3	39.5	38.3	39.1	40.1	41.4
		HI PR	240	258	273	284	269	290	306	319	306	329	348	363	349	375	396	413	392	422	446	465	433	466	493	514
		LO PR	104	111	121	129	110	117	128	136	114	122	133	141	120	128	139	148	126	134	146	156	130	138	151	161
	3938	MBh	115.6	117.8	123.4	131.6	112.9	115.1	120.5	128.6	110.2	112.3	117.7	125.5	107.5	109.6	114.8	122.5	102.1	104.1	109.0	116.3	94.6	96.4	101.0	107.8
		S/T	0.90	0.87	0.78	0.64	0.93	0.90	0.81	0.66	0.96	0.92	0.83	0.68	0.99	0.95	0.86	0.70	1.00	0.99	0.89	0.72	1.00	1.00	0.90	0.73
		ΔT	24	24	23	20	25	24	23	20	25	24	23	20	25	24	23	20	24	24	23	20	22	22	21	18
		kW	7.02	7.21	7.49	7.80	7.71	7.91	8.23	8.57	8.32	8.54	8.88	9.24	8.85	9.09	9.46	9.84	9.31	9.56	9.94	10.35	9.71	9.97	10.37	10.78
		Amps	29.3	29.9	30.6	31.5	31.1	31.7	32.5	33.5	33.2	33.8	34.7	35.8	35.0	35.7	36.6	37.8	36.8	37.5	38.6	39.8	38.6	39.3	40.4	41.7
		HI PR	242	261	275	287	272	293	309	322	309	333	351	366	352	379	400	417	396	426	450	470	438	471	497	519
		LO PR	105	112	122	130	111	118	129	137	115	123	134	143	121	129	141	150	127	135	148	157	131	140	153	163

IDB: Entering Indoor Dry Bulb Temperature

High and low pressures are measured at the liquid and suction service valves.

Shaded area reflects AHRI (TVA) conditions

Amps = outdoor unit amps (comp.+fan)

kW = Total system power

Date: 11/04/13

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

AHRI PERFORMANCE RATINGS

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

Outdoor Unit	Indoor Unit			EER / IEER[2]	AHRI #
DX11SA0903A*	DAR0904A*			11.2 / 11.5	6334521
	(2)CA*F4961*6D+TXV			11.2 / 11.5	6334520
DX11SA0904A*	DAR0904A*	88,000	63,000	11.2 / 11.5	6334523
	(2)CA*F4961*6D+TXV	88,000	62,000	11.2 / 11.5	6334522
DX11SA1203A*	DAR1204A*	114,000	82,000	11.2 / 11.5	6334525
	(2)CA*F4961*6D+TXV	110,000	76,000	11.2 / 11.5	6334524
DX11SA1204A*	DAR1204A*	112,000	80,000	11.2 / 11.5	6334527
	(2)CA*F4961*6D+TXV	110,000	76,000	11.2 / 11.5	6334526

[1] BTU/h

[2] EER = Energy Efficiency Ratio; IEER = Integrated Energy Efficiency Ratio

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

DIMENSIONS

MODEL	DIMENSIONS		
	W"	D"	H"
DX11SA0903A*	35½	35½	37½
DX11SA0904A*	35½	35½	37½
DX11SA1203A*	35½	35½	41½
DX11SA1204A*	35½	35½	41½

WIRING DIAGRAM

WARNING **High Voltage:** Disconnect all power before servicing or installing this unit. Multiple power sources may be present. Failure to do so may cause property damage, personal injury, or death.

Wiring is subject to change. Always refer to the wiring diagram or the unit for the most up-to-date wiring.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

ACCESSORIES

MODEL	
ABK-20	Anchor Bracket Kit ◊
HPTD18-60	Digital room thermostat wit
HPT18-60	Standard room thermostat with 1-stage cool/1-stage heat
FSK01A	Freeze Protection Kit [1]
LA-01	Low Ambient Kit

◊ Contains 20 brackets; four brackets needed to anchor unit to pad

[1] Installed on indoor coil

NOTES

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

Our continuing commitment to quality products may mean a change in specifications without notice.
© 2013 • DAIKIN MANUFACTURING COMPANY, L.P. • Houston, Texas • Printed in the USA.