RESURGAM. CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/04/13

HVAC HEATING PRODUCTS

Application Manual

SF/SC Series

TF/TC Series

QVSD Series

GAS-FIRED HEATING EQUIPMENT

- Tubular Unit Heaters
- Duct Furnaces
- Cabinet Blowers

STERLING®
HVAC PRODUCTS

MADE IN THE USA

Contents

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

GENERAL INFORMATION – Tubular

APPLICATIONS

GG SERIES
- Standard/Optional Features 5
- Unit Number Description 5
- Performance Data and Dimensional Data 6
- Dimensional Data 7

TF/TC SERIES
- Standard/Optional Features 8
- Unit Number Description 8
- Performance and Dimensional Data – TF Series 9
- Performance and Dimensional Data – TC Series 10
- Performance Data – TC Series 11

SF/SC SERIES
- Standard/Optional Features 12
- Unit Number Description 12
- Performance and Dimensional Data – SF Series 13
- Performance and Dimensional Data – SC Series 14
- Performance Data – SC Series 15

GENERAL INFORMATION – Duct Furnace 16

QVED/QVES/QVSD SERIES
- Standard Features 17
- Unit Number Description 17
- Performance and Dimensional Data – QVSD Series 18
- Performance and Dimensional Data – QVED Series 19
- Performance and Dimensional Data – QVES Series 19
- Dimensional Data – QVED/QVES Series 20

CAB SERIES
- Standard Features 21
- Unit Number Description 21
- Motor Data 21
- Dimensional Data – CAB Series 22
- Performance Data – CAB Series 23

OPTIONAL ACCESSORIES – All Series 24-25

HEAT THROW DATA – All Series 26-27

NOZZLE DIMENSIONS 28

TYPICAL STANDARD SPECIFICATIONS
- GG Series 29
- TF/TC Series 29
- SF/SC Series 30
- QVED/QVES/QVSD Series 30
- CAB Series 30

WARRANTY – All Series 31

GG Series

TF Series

TC Series

SF Series

SC Series

Tubular Unit Heater

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

- GG SERIES
- TF SERIES
- TC SERIES
- SF SERIES
- SC SERIES

General Information

STERLING TUBULAR DESIGN GAS FIRED UNIT HEATER
The Sterling Tubular gas-fired unit heaters offer a highly efficient, extremely durable alternative to the traditional clam shell design. These units combine the latest tubular heat exchanger and inshot burner technology with the quality and reliability you have come to know from Sterling.

HIGH EFFICIENCY
Standard energy saving features like the direct spark ignition and power venting reduce standby losses and offer improved seasonal efficiencies. Tubular units certified by ETL as providing 83% thermal (combustion) efficiency.

TUBULAR HEAT EXCHANGER
The Sterling tubular heat exchanger has been designed to provide maximum and uniform heat transfer. The low pressure drop associated with this design enables heated air to be evenly distributed to the conditioned space. This curved, non-welded serpentine design experiences less thermally induced stress making it highly durable for significantly longer service life. All Sterling tubular heat exchangers are constructed of heavy duty 20-gauge aluminized steel. Optional 409 stainless steel heat exchangers are also available.

K IGNITION SYSTEM
ar units utilize a direct spark pilotless ignition providing fast heat delivery. This highly reliable gnition system incorporates an integrated ıtrol board to regulate the system sequence including an onboard LED indicator for simple ng.

VENTING
The Sterling Tubular unit heaters are ETL certified in accordance with categories I and III venting requirements. This certification allows units to be vented both vertically and horizontally using either single wall or double wall venting materials. This venting flexibility of the unit heater makes installation easier and more cost effective by allowing the installer to utilize existing venting components.

CONTROL ACCESSIBILITY
Designed with the service person in mind, every component of the Sterling unit heaters is easily accessible. Ignition and fan controls are located in one centrally located control panel. The access door provides control isolation as well as a pleasing exterior appearance.

10-YEAR WARRANTY
Sterling warranties the heat exchanger, flue collector and burners of each unit heater to be free from defects in materials and workmanship for a period of 10 years from the date of manufacture.

SEPARATED COMBUSTION - SF/SC SERIES
The SF/SC series heater “separates” the combustion process from the environment where the unit is installed. A power venting system draws a controlled quantity of combustion air from outside the building. The same system exhausts flue products to the outside. The burners, pilot and flue system are enclosed within the unit; thus, the entire combustion process is unaffected by the atmosphere in the space where the heater is located. Separated combustion units are designed to be installed where dusty, dirty or mildly corrosive conditions exist or where high humidity or slightly negative pressure prevail.

Applications

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

UNIT HEATER PLACEMENT

Gas-fired unit heaters are used primarily in com
such as warehouses, manufacturing areas, gar
Placement is typically determined by air distrib
distributions should have air directed toward a
units may be used to greatest effect by positioning units around the perimeter. Several units near the center and with air discharging toward outside walls may also satisfy the heating requirements. Direct air discharge on occupants should be avoided.

TYPICAL APPLICATIONS

A large square area with exposed walls and roof; units are blanketing all exposed surfaces.

A narrow area with four exposed walls either with or without roof exposure.

A small area with exposed walls requiring one unit.

HOW TO CALCULATE HEAT LOSS

It is suggested that when calculating heat loss for a building, reference be made to procedures outlined in the **ASHRAE Handbook.** As an easy reference, however, the following abbreviated method may be used with a good degree of reliability.

1. Determine inside temperature to be maintained and the design outside temperature for your locality. The difference between these two figures is the design temperature difference.
2. Calculate net areas in square feet of glass, wall, floor, and roof exposed to outside temperature or unheated spaces. Calculate door as all glass.
3. Select heat-transfer coefficients from the table below (or the **ASHRAE Handbook**) and compute the heat-transmission loss for each area in BTU/HR by multiplying each area by the heat-transfer coefficient and the temperature difference.
4. Add 10% to the heat-loss figures for areas exposed to prevailing winds.
5. Calculate the volume of the room or area in cubic feet and multiply by the estimated number of air changes per hour due to infiltration (usually from one to two). Determine the number of cubic feet per hour of air exhausted by ventilating fans or industrial processes. Substitute the larger of these two figures in the formula to determine the heat required to raise the air from outside to room temperature —

$$\frac{\text{BTU/HR} = \text{cubic feet per hour x temperature difference}}{55}$$

6. The totals of BTU/HR losses from 3, 4 and 5 (above) will give the total BTU/HR to be supplied by unit heaters. (Note: If processes performed in the room liberate considerable amounts of heat, this may be determined as accurately as possible and subtracted from the total).

Building Material	"U" Factor
WALLS	
Poured concrete 80#/cu. ft.	
8-inch	0.25
12-inch	0.18
Concrete Block, hollow cinder aggregate	
8-inch	0.39
12-inch	0.36
Gravel aggregate	
8-inch	0.52
12-inch	0.47
Concrete Block, w/4-inch facebrick	
Gravel, 8-inch	0.41
Cinder, 8-inch	0.33
Metal	
(un-insulated)	1.17
w/1-inch blanket insulation	0.22
w/3-inch blanket insulation	0.08
ROOFING	
Corrugated Metal (un-insulated)	1.50
w/1-inch bolt or blanket	0.23
w/$1^1/_2$-inch bolt or blanket	0.16
w/3-inch bolt or blanket	0.08
Flat Metal	
w/$^3/_8$-inch built-up roofing	0.90
w/1-inch blanket insulation under deck	0.21
w/2-inch blanket insulation under deck	0.12
Wood/ 1" / (un-insulated) w/$^3/_8$-inch built-up roofing	0.48
w/1-inch blanket insulation	0.17
Wood/ 2" / (un-insulated) w/$^3/_8$-inch built-up roofing	0.32
w/1-inch blanket insulation	0.15
Concrete slab/ 2" / (un-insulated) w/$^3/_8$-inch built-up roofing	0.30
w/1-inch insulation board	0.16
Concrete slab/ 3" / (un-insulated) w/$^3/_8$-inch built-up roofing	0.23
w/1-inch insulation board	0.14
Gypsum slab/ 2" / (un-insulated) w/$^1/_2$-inch gypsum board	0.36
w/1-inch insulation board	0.20
Gypsum slab/ 3" / (Un-insulated) w/$^1/_2$-inch gypsum board	0.30
w/1-inch insulation board	0.18
WINDOWS	
Vertical, single-glass	1.13
Vertical, double-glass, $^3/_{16}$- inch air space	0.69
Horizontal, single-glass (sky light)	1.40
DOORS	
Metal — single sheet	1.20
Wood, 1-inch	0.64
2-inch	0.43

GG Series — Low P er

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

RESIDENTIAL AND COMMERCIAL CERTIFICATIONS

The Sterling "GG" Series unit heater conforms with the latest ETL certification standards. Design certified under ANSI Z83.8 for Industrial/Commercial use and the more demanding requirements of CSA 10.96 USA (2nd ed.) "Unit Heaters for Residential Installation", make this low profile unit heater the ideal selection.

ith
rload

- Redundant Single-Stage Gas Valve
- Residential Certification
- 120/24V Control Transformer
- OSHA Fan Guard
- Direct Spark Ignition
- 20-Gauge Cabinet with Baked Enamel Finish
- 10 Year Heat Exchanger Warranty
- Right Hand Control Access - Field Convertible to Left Hand
- High Limit Switch
- Air Pressure Switch
- Natural or Propane Gas
- Gas Conversion Kit Included
- Field Convertible to Separated Combustion
- Easy Access Control Panel
- 321 Stainless Steel Burner Box
- 20-Gauge Aluminized Heat Exchanger
- Power Vented

OPTIONAL FEATURES

- 409 Stainless Steel Heat Exchanger
- Two-Stage Gas Control (Sizes 60-120 Only)
- Stainless Steel Flue Collector
- Supply Voltage (Field Mounted Transformers):
  - 208/1/60
  - 230/1/60
  - 208/3/60
  - 230/3/60
  - 460/3/60
  - 575/3/60
- Vent Caps
- Totally Enclosed Motors (Sizes 60-120 Only)
- Pressure Regulator (1/2 – 2 psi)
- Single & Two-Stage Mercury Free Thermostats
- Line Volt Thermostat
- Locking Thermostat Cover
- 24V SPST Relay
- Concentric Vent Kits (For All Separated Combustion Installations)

Unit Number Description

Digit	G	X	X	X	–	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	+
Item	Prefix (Internal use Only)					UT		CA			FT	FM	GT	AL	GC	SV	MT	DL	AS		

1, 2 - Unit Type [UT]
GG - Residential Low Profile Tubular Propeller
Note: Field conversion to Separated Combustion requires a Combustion Air Inlet Kit.
See Accessory Options X7-4 and X7-5 for proper unit selection.

3, 4, 5 - Capacity [CA]
030 - 30,000 BTU/HR
045 - 45,000 BTU/HR
060 - 60,000 BTU/HR
075 - 75,000 BTU/HR
090 - 90,000 BTU/HR
105 - 105,000 BTU/HR
120 - 120,000 BTU/HR

6 - Furnace Type [FT]
A - Right Hand Access

7 - Furnace Material [FM]*
1 - Standard (Aluminized) Steel
2 - 409 Stainless Steel
**Heat exchanger tube material only.*

8 - Gas Type [GT]
N - Natural Gas
P - Propane (LP) Gas

9 - Altitude [AL]
S - 0–4,999 ft.
T - 5,000–11,999 ft.
Note: Installations over 2,000 ft. require gas input deration in the field.
Refer to unit installation instructions.

10 - Gas Control [GC]
A - Single Stage (Standard)
B - Two Stage (Capacities [CA] 060 through 120 only)

11 - Supply Voltage [SV]
1 - 115/1/60
2 - 208/1/60
3 - 230/1/60
4 - 208/3/60
5 - 230/3/60
6 - 460/3/60
7 - 575/3/60
Z - Other
Note: Supply Voltage [SV] 2-7 include field mounted step down transformer.

12 - Motor Type [MT]
1 - Open Drip Proof (Standard)
2 - Totally Enclosed (Capacities [CA] 060 through 120 only)

13 - Development Level [DL]
C - Production Onset

14, 15+ - Accessories [AS]

FACTORY INSTALLED
S3 - Stainless Steel Flue Collector
Z1 - Special
All Field Installed Accessories are to be entered as a separate line item using catalog number which places "AS" as a prefix. i.e: A7 becomes AS-A7.

FIELD INSTALLED (AS-____)
A7 - Pressure Regulator 1/2-2 psi

G1 - 1-Stage T87K Mercury Free Thermostat w/Subbase Kit
G2 - 1-Stage T87K Mercury Free Thermostat w/TG511A Guard Kit
G3 - 1-Stage T834N Mercury Free Thermostat/Fan Switch
G5 - 2-Stage TH5220D Mercury Free Thermostat w/Subbase
G6 - Locking Thermostat Cover
G8 - 1-Stage T6169C Line Voltage Thermostat w/Subbase
G9 - 1-Stage T822K Mercury Free Thermostat

P5 - 24V SPST Relay-Specify Purpose

VC-4 - 4" Vent Cap

X2 - 30 Degree Downturn Nozzle
X3 - 60 Degree Downturn Nozzle
X4 - 90 Degree Downturn Nozzle
X7-4 - Combustion Air Inlet Kit (Capacities [CA] 030-075)
X7-5 - Combustion Air Inlet Kit (Capacities [CA] 090-120)

GG Series — Low Pro
Performance and Dim

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

Intertek

ENERGY PERFORMANCE VERIFIED
RENDEMENT ENERGETIQUE VERIFIE

UNIT CAPACITY (MBH)	30				90	105	120
PERFORMANCE DATA†							
Input - BTU/Hr	30,000	45,000	60,000	75,000	90,000	105,000	120,000
(kW)	(8.8)	(13.2)	(17.6)	(22.0)	(26.4)	(30.8)	(35.2)
Output - BTU/Hr	24,900	37,350	49,800	61,500	73,800	86,100	98,400
(kW)	(7.2)	(10.9)	(14.5)	(18.0)	(21.6)	(25.2)	(28.8)
Thermal Efficiency - %	83	83	83	82	82	82	82
Free Air Delivery - CFM	370	550	740	920	1,100	1,300	1,475
(cu. m/s)	(.175)	(.260)	(.349)	(.434)	(.519)	(.614)	(.696)
Air Temperature Rise - °F	60	60	60	60	60	60	60
(°C)	(15)	(15)	(15)	(15)	(15)	(15)	(15)
Full Load Amps at 120V	3.0	3.0	4.1	4.1	6.4	6.4	6.4
Maximum Circuit Ampacity	3.5	3.5	4.8	4.8	7.5	7.5	7.5
MOTOR DATA: Motor HP	1/20	1/20	1/12	1/12	1/10	1/10	1/10
Motor (kW)	(0.04)	(0.04)	(0.06)	(0.06)	(0.075)	(0.075)	(0.075)
Motor Type	SP	SP	SP	SP	SP	SP	SP
RPM	1650	1650	1050	1050	1050	1050	1050
Motor Amps @ 115V	1.9	1.9	2.6	2.6	4.2	4.2	4.2
DIMENSIONAL DATA - Inches (mm)							
"A" Jacket Height	12-3/8	12-3/8	15-7/8	15-7/8	22-5/8	22-5/8	22-5/8
	(314)	(314)	(403)	(403)	(574)	(574)	(574)
"B" Overall Height	13-1/4	13-1/4	16-13/16	16-13/16	23-9/16	23-9/16	23-9/16
	(337)	(337)	(427)	(427)	(598)	(598)	(598)
"C" Overall Depth	25-7/8	25-7/8	26-3/16	26-3/16	26-3/8	26-3/8	26-3/8
	(632)	(632)	(665)	(665)	(670)	(670)	(670)
"D1" Center Line Height of Flue*	8-1/2	8-1/2	10-3/8	10-3/8	13-5/8	13-5/8	13-5/8
	(216)	(216)	(263)	(263)	(346)	(346)	(346)
"D2" Center Line Height of Air Intake	8-1/2	8-1/2	8	8	8-5/8	8-5/8	8-5/8
	(216)	(216)	(203)	(203)	(219)	(219)	(219)
"E" Fan Diameter	10	10	14	14	16	16	16
	(254)	(254)	(356)	(356)	(406)	(406)	(406)
"F" Discharge Opening Height	10-13/16	10-13/16	14-7/16	14-7/16	21-3/16	21-3/16	21-3/16
	(275)	(275)	(367)	(367)	(538)	(538)	(538)
"G" Vent Connection Diameter	4	4	4	4	4	4	4
	(102)	(102)	(102)	(102)	(102)	(102)	(102)
"H1" Center Line of Flue Connection From Side	7-1/4	7-1/4	7-1/4	7-1/4	7-3/4	7-3/4	7-3/4
	(184)	(184)	(184)	(184)	(197)	(197)	(197)
"H2" Center Line of Air Intake From Side	2-3/4	2-3/4	2-3/4	2-3/4	3-1/2	3-1/2	3-1/2
	(70)	(70)	(70)	(70)	(89)	(89)	(89)
VENT SIZE REQUIREMENTS - STANDARD COMBUSTION							
Category III Horizontal - Inches (mm)	4	4	4	4	4	4	4
	(102)	(102)	(102)	(102)	(102)	(102)	(102)
Category I & III Vertical - Inches (mm)	4	4	4	4	4	4	4
	(102)	(102)	(102)	(102)	(102)	(102)	(102)
VENT SIZE REQUIRMENTS - SEPARATED COMBUSTION							
Exhaust Diameter** - Inches (mm)	4	4	4	4	5	5	5
	(102)	(102)	(102)	(102)	(127)	(127)	(127)
Intake Air Diameter - Inches (mm)	4	4	4	4	5	5	5
	(102)	(102)	(102)	(102)	(127)	(127)	(127)
Unit Weight - Lbs	60	65	80	85	95	105	110
(kgs)	(27)	(29)	(36)	(39)	(43)	(48)	(50)
Shipping Weight - Lbs	70	75	90	95	110	115	120
(kgs)	(32)	(34)	(41)	(43)	(50)	(52)	(54)

*For all installations, the flue collar is included with the unit and should be field installed per the instructions included with the unit.

**4-5" reducer supplied where required.

† Ratings shown are for unit installations at elevations between 0 and 2,000 ft (0 to 610m). For unit installations in USA above 2,000 ft. (610m), the unit input must be field derated 4% for each 1,000 ft. (305m) above sea level; refer to local codes, or in absence of local codes, refer to the latest edition of the National Fuel Gas Code, ANSI Standard Z223.1 (NFPA No. 54).

For installations in Canada, any reference to deration at altitudes in excess of 2,000 ft. (610m) are to be ignored. At altitudes of 2,000 ft. to 4,500 ft. (610 to 1372m), the unit must be field derated to 90% of the normal altitude rating, and be so marked in accordance with the ETL certification. See unit installation, operation and maintenance manual for deration information.

GG Series — Low P er
Dimensional Data

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

D8597

DIMENSIONS .XXX STANDARD UNITS
DIMENSIONS IN PARENTHESIS (XXX) MILLIMETERS

TF/TC Series — Tubu

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

STANDARD FEATURES

- In-Shot Burner Design
- 20-Gauge Steel Jacket with Baked Enamel Finish
- Main Control Panel
- 115/1/60 Supply Voltage
- Direct Spark Ignition
- Re
  Sir
  Ga
- 11 /24 volt Control Transformer
- Power Vented
- 115/1/60 Volt Motor with Internal Overload Protection
- 10 Year Heat Exchanger, Flue Collector and Burner Warranty
- 82+% Thermal Efficiency

OPTIONAL FEATURES

- Stainless Steel Heat Exchanger, Burners and/or Flue Collector
- Supply Voltages: 208 & 230/1/60 and 230, 460, 575/3/60
- Premium Efficiency Blower Motors in ODP and TE Types
- Two-Stage and Various Electronic Modulation Gas Controls
- Discharge Nozzles (30°, 60° & 90°) or Duct Flange Assembly

Unit Number Description

TF Series

Digit	T	X	X	X	–	1	2	3	4	5	6	7	8	9	10	11	12	13	+
Item	Prefix					UT		CA			FT	FM	GT	AL	GC	SV	MT	AS	

(Internal use Only)

TC Series

Digit	T	X	X	X	–	1	2	3	4	5	6	7	8	9	10	11	12	13	14	+
Item	Prefix					UT		CA			FT	FM	GT	AL	GC	SV	MT	MS	AS	

(Internal use Only)

1, 2 - Unit Type [UT]
TF - Tubular Propeller
TC - Tubular Blower

3, 4, 5 - Capacity [CA]
100 - 100,000 BTU/HR
125 - 125,000 BTU/HR
150 - 150,000 BTU/HR
175 - 175,000 BTU/HR
200 - 200,000 BTU/HR
250 - 250,000 BTU/HR
300 - 300,000 BTU/HR
350 - 350,000 BTU/HR
400 - 400,000 BTU/HR

6 - Furnace Type [FT]
A - Right Side Access

7 - Heat Exchanger Construction Material [FM]
1 - Standard (Aluminized) Steel
2 - 409 Stainless Steel

8 - Gas Type [GT]
N - Natural Gas
P - Propane Gas (LP)

9 - Altitude [AL]
S - 0–4,999 ft.
T - 5,000–11,999 ft.
Note: Installations over 2,000 ft. require gas input deration in the field.
Refer to unit installation instructions.

10 - Direct Spark Gas Control [GC]
1 - Single Stage
2 - Two Stage
3 - Electronic Modulation w/Room Sensing
4 - Electronic Modulation w/Duct Sensing
5 - Electronic Modulation w/Duct Sensing & Room Ovrd. Stat
6 - Electronic Modulation w/External 4-20 mA Input
7 - Electronic Modulation w/External 0-10 VDC Input

11 - Supply Voltage [SV]
1 - 115/1/60
2 - 208/1/60
3 - 230/1/60
4 - 208/3/60
5 - 230/3/60
6 - 460/3/60
7 - 575/3/60
Z - Special
Note: Supply Voltages [SV] 2-7 include step down transformer.
Field mounted for propeller units, factory mounted for blower units.

12 - Motor Type [MT]
1 - Open Drip Proof (Standard)
2 - Totally Enclosed
3 - Premium Efficiency, Open Drip Proof (Blowers only)
4 - Premium Efficiency, Totally Enclosed (Blowers only)

13 - Blower Motor Sizes [MS]**
A - 1/4 HP w/Contactor
C - 1/2 HP w/Contactor
D - 3/4 HP w/Contactor
F - 1 HP w/Contactor
G - 1-1/2 HP w/Contactor
H - 2 HP w/Contactor
J - 1/4 HP
L - 1/2 HP
P - 1/2 HP w/Magnetic Starter
R - 3/4 HP w/Magnetic Starter
S - 1 HP w/Magnetic Starter
T - 1-1/2 HP w/Magnetic Starter
U - 2 HP w/Magnetic Starter
W - 1/4 HP w/Magnetic Starter

**Notes: 1. All 3-phase units [SV = 4, 5, 6, 7] include a contactor as standard.
2. All single phase units [SV = 1, 2, 3] include a contactor for units equipped with 3/4 HP. motor or higher [MS =D, F, G, H]
3. [MS] options J, L only available with [SV] option 1 (115/1/60).

13/14 - Accessories [AS]

FACTORY INSTALLED
M6 - OSHA Type Fan Guard (Propellers only)
M8 - Discharge Duct Flange Assembly (Blowers only)
P4 - Terminal Block Wiring
P6 - Summer/Winter Switch
S3 - 409 Stainless Steel Flue Collector
S5 - 304L Stainless Steel Burners

† FIELD INSTALLED (AS-____)
† All Field Installed Accessories are to be entered as a separate line item using catalog number which utilizes "AS" as a prefi x. i.e: A7 becomes AS-A7.

A7 - Pressure Regulator 1/2-2 psi

F1 - 1-Stage T675A Ductstat
F2 - 2-Stage T678A Ductstat

G1 - 1-Stage T87K Mercury Free Thermostat w/Subase Kit
G2 - 1-Stage T87K Mercury Free Thermostat w/TG511A Guard Kit
G3 - 1-Stage T834N Mercury Free Thermostat/Fan Switch
G5 - 2-Stage TH5220D Mercury Free Thermostat w/Subbase
G6 - Locking Thermostat Cover
G8 - 1-Stage T6169C Line Voltage Stat w/Subbase
G9 - 1-Stage T822K Mercury Free Thermostat

M2-2 - Vent Caps (5") (Unit Capacity 100-250)
M2-3 - Vent Caps (6") (Unit Capacity 300-400)
M7 - 2 to 4 Point Suspension Kit (Propeller Only)

P5 - 24V SPST Relay-Specify Purpose

X2 - 30 Degree Downturn Nozzle
X3 - 60 Degree Downturn Nozzle
X4 - 90 Degree Downturn Nozzle
X5 - Vertical Louver Kit

TF Series — Tubula Heater
Performance and D a

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

ENERGY PERFORMANCE VERIFIED
RENDEMENT ENERGETIQUE VERIFIE

UNIT CAPACITY (MBH)	100				0	250	300	350	400
PERFORMANCE DATA†									
Input - BTU/Hr	100,000	125,000	150,000	175,000	200,000	250,000	300,000	350,000	400,000
(kW)	(29.3)	(36.6)	(43.9)	(51.2)	(58.6)	(73.2)	(87.8)	(102.5)	(117.1)
Output - BTU/Hr	83,000	103,750	124,500	145,250	166,000	207,500	249,000	290,500	332,000
(kW)	(24.3)	(30.4)	(36.4)	(42.5)	(48.6)	(60.7)	(72.9)	(85.1)	(97.2)
Thermal Efficiency - %	83	83	83	83	83	83	83	83	83
Free Air Delivery - CFM	1,600	2,200	2,400	2,850	3,200	3,450	5,000	5,600	5,800
(cu. m/s)	(0.756)	(1.039)	(1.133)	(1.346)	(1.511)	(1.629)	(2.361)	(2.644)	(2.738)
Air Temperature Rise - °F	47	42	47	46	47	54	45	47	51
(°C)	(26)	(23)	(26)	(26)	(26)	(30)	(24)	(26)	(28)
Full Load Amps at 120V	5.3	5.8	5.8	8.0	8.0	8.0	11.3	13.5	13.5
MOTOR DATA: Motor HP (Qty.)	1/10	1/4	1/4	1/3	1/3	1/3	(2) 1/4	(2) 1/3	(2) 1/3
Motor kW	(0.080)	(0.19)	(0.19)	(0.25)	(0.25)	(0.25)	(0.19)	(0.25)	(0.25)
Motor Type**	SP	PSC	PSC	PSC	PSC	PSC	PSC	PSC	PSC
RPM	1,150	1,140	1,140	1,140	1,140	1,140	1,140	1,140	1,140
Amps @ 115V	4.7	4.7	4.7	5.8	5.8	5.8	9.4	11.6	11.6
DIMENSIONAL DATA - Inches (mm)									
"A" Overall Height to Top of Flue	33-3/4	33-3/4	33-3/4	33-3/4	33-3/4	33-3/4	34	34	34
	(857)	(857)	(857)	(857)	(857)	(857)	(864)	(864)	(864)
"B" Jacket Width of Unit	20-3/4	20-3/4	20-3/4	32-3/4	32-3/4	32-3/4	50-3/4	50-3/4	50-3/4
	(527)	(527)	(527)	(831)	(831)	(831)	(1289)	(1289)	(1289)
"C" Width to CL Flue	13-3/8	13-3/8	13-3/8	19-3/8	19-3/8	19-3/8	28-3/8	28-3/8	28-3/8
	(340)	(340)	(340)	(492)	(492)	(492)	(721)	(721)	(721)
"D" Depth to Rear of Housing	11	11	11	11	11	11	12-1/4	12-1/4	12-1/4
	(279)	(279)	(279)	(279)	(279)	(279)	(311)	(311)	(311)
"E" Hanging Distance Width	18-5/8	18-5/8	18-5/8	30-5/8	30-5/8	30-5/8	48-5/8	48-5/8	48-5/8
	(473)	(473)	(473)	(778)	(778)	(778)	(1235)	(1235)	(1235)
"F" Discharge Opening Width	18-3/4	18-3/4	18-3/4	30-3/4	30-3/4	30-3/4	48-3/4	48-3/4	48-3/4
	(476)	(476)	(476)	(781)	(781)	(781)	(1238)	(1238)	(1238)
"G" Depth to CL Flue	4-3/4	4-3/4	4-3/4	4-3/4	4-3/4	4-3/4	5-1/8	5-1/8	5-1/8
	(121)	(121)	(121)	(121)	(121)	(121)	(130)	(130)	(130)
"H" Discharge Opening Height	24-1/2	24-1/2	24-1/2	24-1/2	24-1/2	24-1/2	24-1/2	24-1/2	24-1/2
	(622)	(622)	(622)	(622)	(622)	(622)	(622)	(622)	(622)
"L" Overall Unit Width	25-1/4	25-1/4	25-1/4	37-1/4	37-1/4	37-1/4	55-1/4	55-1/4	55-1/4
	(641)	(641)	(641)	(946)	(946)	(946)	(1403)	(1403)	(1403)
*Vent Size Diameter - Inches	5	5	5	5	5	5	6	6	6
(mm)	(127)	(127)	(127)	(127)	(127)	(127)	(152)	(152)	(152)
Fan Diameter - Inches (Qty.)	16	16	16	18	18	18	(2) 16	(2) 18	(2) 18
Gas Inlet-Natural Gas (Inches)	1/2	1/2	1/2	1/2	1/2	3/4	3/4	3/4	3/4
Gas Inlet- LP Gas (Inches)	1/2	1/2	1/2	1/2	1/2	1/2 OR 3/4	1/2 OR 3/4	1/2 OR 3/4	1/2 OR 3/4
Approximate Unit Weight - Lbs	133	145	155	191	201	211	307	321	335
(kg)	(60)	(66)	(70)	(87)	(91)	(96)	(139)	(145)	(152)
Approximate Ship Weight - Lbs	173	185	195	241	251	261	367	381	395
(kg)	(78)	(84)	(88)	(109)	(114)	(118)	(166)	(173)	(179)

† Ratings shown are for unit installations at elevations between 0 and 2,000 ft (0 to 610m). For unit installations in USA above 2,000 ft. (610m), the unit input must be field derated 4% for each 1,000 ft. (305m) above sea level; refer to local codes, or in absence of local codes, refer to the latest edition of the National Fuel Gas Code, ANSI Standard Z223.1 (NFPA No. 54).

For installations in Canada, any reference to deration at altitudes in excess of 2,000 ft. (610m) are to be ignored. At altitudes of 2,000 ft. to 4,500 ft. (610 to 1372m), the unit must be field derated to 90% of the normal altitude rating, and be so marked in accordance with the ETL certification. See unit installation, operation and maintenance manual for deration information.

* Flue collar is factory supplied with unit; to be field installed per included instructions. ** LEGEND: SP = SHADED POLE PSC = PERMANENT SPLIT CAPACITOR

D4617

DIMENSIONS .XXX STANDARD UNITS
DIMENSIONS IN PARENTHESIS (XXX) MILLIMETERS

TC Series — Tubular [illegible] ater
Performance and Dim[illegible]

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

Intertek

ENERGY PERFORMANCE VERIFIED
RENDEMENT ENERGETIQUE VERIFIE

UNIT CAPACITY (MBH)	100	125	[illegible]	[illegible]	[illegible]	250	300	350	400
PERFORMANCE DATA†									
Input - BTU/Hr	100,000	125,000	150,000	175,000	200,000	250,000	300,000	350,000	400,000
(kW)	(29.3)	(36.6)	(44.0)	(51.3)	(58.6)	(73.3)	(87.9)	(102.6)	(117.2)
Output - BTU/Hr	83,000	103,750	124,500	145,250	166,000	207,500	246,000	290,500	332,000
(kW)	(24.3)	(30.4)	(36.5)	(42.6)	(48.6)	(60.8)	(72.1)	(85.1)	(97.3)
Thermal Efficiency - %	83	83	83	83	83	83	82	83	83
Free Air Delivery - CFM	1,181	1,476	1,771	2,067	2,362	2,953	3,501	4,134	4,724
(cu. m/s)	(0.557)	(0.697)	(0.836)	(0.976)	(1.115)	(1.394)	(1.652)	(1.951)	(2.230)
Air Temperature Rise - °F	65	65	65	65	65	65	65	65	65
(°C)	(36)	(36)	(36)	(36)	(36)	(36)	(36)	(36)	(36)
Outlet Velocity - FPM	370	463	555	395.0	451.0	564.0	422	498	570
(m/s)	(1.879)	(2.351)	(2.819)	(2.006)	(2.291)	(2.864)	(2.143)	(2.529)	(2.895)
Full Load Amps at 115V	7.3	9.4	9.4	14.2	14.2	15.6	15.6	20.8	20.8
Maximum Circuit Ampacity	8.6	11.2	11.2	17.1	17.1	18.9	18.9	25.4	25.4
MOTOR DATA Motor HP	1/4	1/2	1/2	3/4	3/4	1	1	1-1/2	1-1/2
Motor kW	0.19	0.37	0.37	0.56	0.56	0.75	0.75	1.11	1.11
Motor Type**	SPH	SPH	SPH	SPH	SPH	Cap. Start	Cap. Start	Cap. Start	Cap. Start
RPM	1,725	1,725	1,725	1,725	1,725	1,725	1,725	1,725	1,725
Amps @ 115V	5.1	7.2	7.2	11.6	11.6	13.0	13.0	18.2	18.2
DIMENSIONAL DATA - Inches (mm)									
"A" Height to Top of Flue	33-3/4	33-3/4	33-3/4	33-3/4	33-3/4	33-3/4	34	34	34
	(857)	(857)	(857)	(857)	(857)	(857)	(864)	(864)	(864)
"B" Jacket Width of Unit	20-3/4	20-3/4	20-3/4	32-3/4	32-3/4	32-3/4	50-3/4	50-3/4	50-3/4
	(527)	(527)	(527)	(832)	(832)	(832)	(1289)	(1289)	(1289)
"C" Width to Centerline Flue	13-3/8	13-3/8	13-3/8	19-3/8	19-3/8	19-3/8	28-3/8	28-3/8	28-3/8
	(340)	(340)	(340)	(492)	(492)	(492)	(721)	(721)	(721)
"D" Depth to Front Hanger	21	21	21	21	21	21	21	21	21
	(533)	(533)	(533)	(533)	(533)	(533)	(533)	(533)	(533)
"E" Hanging Distance Width	18-5/8	18-5/8	18-5/8	30-5/8	30-5/8	30-5/8	48-5/8	48-5/8	48-5/8
	(473)	(473)	(473)	(778)	(778)	(778)	(1235)	(1235)	(1235)
"F" Hanging Distance Depth	19	19-1/2	19-1/2	32-3/4	32-3/4	32-3/4	23-1/2	32-3/4	32-3/4
	(483)	(495)	(495)	(832)	(832)	(832)	(597)	(832)	(832)
"G" Discharge Opening Width	18-3/4	18-3/4	18-3/4	30-3/4	30-3/4	30-3/4	48-3/4	48-3/4	48-3/4
	(476)	(476)	(476)	(781)	(781)	(781)	(1238)	(1238)	(1238)
"H" Depth to Centerline Flue	4-3/4	4-3/4	4-3/4	4-3/4	4-3/4	4-3/4	5-1/8	5-1/8	5-1/8
	(121)	(121)	(121)	(121)	(121)	(121)	(130)	(130)	(130)
"L" Discharge Opening Height	24-1/2	24-1/2	24-1/2	24-1/2	24-1/2	24-1/2	24-1/2	24-1/2	24-1/2
	(622)	(622)	(622)	(622)	(622)	(622)	(622)	(622)	(622)
"M" Overall Unit Width	25-1/4	25-1/4	25-1/4	37-1/4	37-1/4	37-1/4	55-1/4	55-1/4	55-1/4
	(641)	(641)	(641)	(946)	(946)	(946)	(1403)	(1403)	(1403)
"P" Overall Unit Depth	49-3/4	49-3/8	49-3/8	56-1/8	56-1/8	56-1/8	53-3/8	56-1/8	56-1/8
	(1264)	(1254)	(1254)	(1426)	(1426)	(1426)	(1356)	(1426)	(1426)
*Vent Size Diameter - Inches	5	5	5	5	5	5	6	6	6
(mm)	(127)	(127)	(127)	(127)	(127)	(127)	(152)	(152)	(152)
Blower Size - Inches (Qty)	9	10	10	12	12	12	10 (2)	12 (2)	12 (2)
Gas Inlet, Natural Gas - Inches	1/2	1/2	1/2	1/2	1/2	3/4	3/4	3/4	3/4
Gas Inlet, LP Gas - Inches	1/2	1/2	1/2	1/2	1/2	1/2 OR 3/4	1/2 OR 3/4	1/2 OR 3/4	1/2 OR 3/4
Approximate Unit Weight - Lbs	171	175	202	245	264	289	370	390	429
(kg)	(78)	(79)	(92)	(111)	(120)	(131)	(168)	(177)	(195)
Approximate Ship Weight - Lbs	256	261	289	381	400	425	520	547	595
(kg)	(116)	(118)	(131)	(173)	(181)	(193)	(236)	(248)	(270)

† Ratings shown are for unit installations at elevations between 0 and 2,000 ft (0 to 610m). For unit installations in USA above 2,000 ft. (610m), the unit input must be field derated 4% for each 1,000 ft. (305m) above sea level; refer to local codes, or in absence of local codes, refer to the latest edition of the National Fuel Gas Code, ANSI Standard Z223.1 (NFPA No. 54).

For installations in Canada, any reference to deration at altitudes in excess of 2,000 ft. (610m) are to be ignored. At altitudes of 2,000 ft. to 4,500 ft. (610 to 1372m), the unit must be field derated to 90% of the normal altitude rating, and be so marked in accordance with the ETL certification. See unit installation, operation and maintenance manual for deration information.

* Flue collar is factory supplied with unit; to be field installed per included instructions.

** LEGEND: SPH = SPLIT PHASE
CAP. START = CAPACITOR START

Rear View

Side View

Front View

D8931B

TC Series — Tubula eater Performance Data

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

Unit	Temp.Rise °F (°C)	CFM (cu. m/s)	ıre Inches W.C. (kPa) 0.1" (0.02)		0.07)			0.4" (0.10)			0.5" (0.12)	
			RPM	HP (kW)	RPM	HP (kW)	RPM	HP (kW)	RPM	HP (kW)	RPM	HP (kW)
TC100	**50** (10)	1535 (0.724)	804	1/2 (0.37)	860	1/2 (0.37)	927	1/2 (0.37)	989	1/2 (0.37)	1045	1/2 (0.37)
	60 (15.5)	1279 (0.603)	649	1/4 (0.19)	760	1/4 (0.19)	821	1/4 (0.19)	890	1/4 (0.19)	963	1/4 (0.19)
	70 (21.1)	1096 (0.517)	633	1/4 (0.19)	700	1/4 (0.19)	779	1/4 (0.19)	858	1/4 (0.19)	920	1/4 (0.19)
	80 (26.6)	959 (0.452)	591	1/4 (0.19)	665	1/4 (0.19)	733	1/4 (0.19)	801	1/4 (0.19)	869	1/4 (0.19)
TC125	**50** (10)	1919 (0.905)	703	1/2 (0.37)	758	1/2 (0.37)	810	1/2 (0.37)	863	1/2 (0.37)	918	1/2 (0.37)
	60 (15.5)	1599 (0.754)	608	1/2 (0.37)	685	1/2 (0.37)	741	1/2 (0.37)	790	1/2 (0.37)	843	1/2 (0.37)
	70 (21.1)	1371 (0.647)	558	1/2 (0.37)	626	1/2 (0.37)	694	1/2 (0.37)	755	1/2 (0.37)	798	1/2 (0.37)
	80 (26.6)	1199 (0.565)	580	1/2 (0.37)	597	1/2 (0.37)	649	1/2 (0.37)	720	1/2 (0.37)	779	1/2 (0.37)
TC150	**50** (10)	2303 (1.087)	853	1/2 (0.37)	927	1/2 (0.37)	962	1/2 (0.37)	988	1/2 (0.37)	1040	1/2 (0.37)
	60 (15.5)	1919 (0.905)	755	1/2 (0.37)	810	1/2 (0.37)	845	1/2 (0.37)	894	1/2 (0.37)	939	1/2 (0.37)
	70 (21.1)	1645 (0.776)	649	1/2 (0.37)	726	1/2 (0.37)	790	1/2 (0.37)	836	1/2 (0.37)	876	1/2 (0.37)
	80 (26.6)	1439 (0.679)	616	1/2 (0.37)	670	1/2 (0.37)	720	1/2 (0.37)	785	1/2 (0.37)	840	1/2 (0.37)
TC175	**50** (10)	2687 (1.26)	522	3/4 (0.56)	566	3/4 (0.56)	612	3/4 (0.56)	652	3/4 (0.56)	688	3/4 (0.56)
	60 (15.5)	2239 (1.05)	468	3/4 (0.56)	514	3/4 (0.56)	564	3/4 (0.56)	609	3/4 (0.56)	654	3/4 (0.56)
	70 (21.1)	1919 (0.905)	423	3/4 (0.56)	471	3/4 (0.56)	527	3/4 (0.56)	582	3/4 (0.56)	624	3/4 (0.56)
	80 (26.6)	1697 (0.8)	402	3/4 (0.56)	482	3/4 (0.56)	515	3/4 (0.56)	567	3/4 (0.56)	609	3/4 (0.56)
TC200	**50** (10)	3071 (1.44)	592	3/4 (0.56)	627	3/4 (0.56)	670	3/4 (0.56)	702	3/4 (0.56)	748	3/4 (0.56)
	60 (15.5)	2559 (1.2)	526	3/4 (0.56)	561	3/4 (0.56)	597	3/4 (0.56)	647	3/4 (0.56)	688	3/4 (0.56)
	70 (21.1)	2193 (1.03)	468	3/4 (0.56)	519	3/4 (0.56)	556	3/4 (0.56)	612	3/4 (0.56)	653	3/4 (0.56)
	80 (26.6)	1919 (0.905)	432	3/4 (0.56)	481	3/4 (0.56)	537	3/4 (0.56)	593	3/4 (0.56)	638	3/4 (0.56)
TC250	**50** (10)	3839 (1.81)	734	1 (0.75)	766	1 (0.75)	802	1 1/2 (1.11)	836	1 1/2 (1.11)	863	1 1/2 (1.11)
	60 (15.5)	3199 (1.51)	626	1 (0.75)	668	1 (0.75)	700	1 (0.75)	749	1 (0.75)	780	1 (0.75)
	70 (21.1)	2742 (1.29)	545	1 (0.75)	593	1 (0.75)	633	1 (0.75)	680	1 (0.75)	718	1 (0.75)
	80 (26.6)	2399 (1.13)	494	1 (0.75)	555	1 (0.75)	590	1 (0.75)	642	1 (0.75)	680	1 (0.75)
TC300	**50** (10)	4551 (2.14)	734	1 (0.75)	766	1 (0.75)	802	1 1/2 (1.11)	836	1 1/2 (1.11)	863	1 1/2 (1.11)
	60 (15.5)	3792 (1.79)	626	1 (0.75)	668	1 (0.75)	700	1 (0.75)	749	1 (0.75)	780	1 (0.75)
	70 (21.1)	3259 (1.53)	545	1 (0.75)	593	1 (0.75)	633	1 (0.75)	680	1 (0.75)	718	1 (0.75)
	80 (26.6)	2844 (1.34)	494	1 (0.75)	555	1 (0.75)	590	1 (0.75)	642	1 (0.75)	680	1 (0.75)
TC350	**50** (10)	5374 (2.54)	558	1 1/2 (1.11)	598	1 1/2 (1.11)	638	1 1/2 (1.11)	676	1 1/2 (1.11)	727	1 1/2 (1.11)
	60 (15.5)	4478 (2.11)	484	1 1/2 (1.11)	532	1 1/2 (1.11)	588	1 1/2 (1.11)	653	1 1/2 (1.11)	680	1 1/2 (1.11)
	70 (21.1)	3839 (1.81)	451	1 1/2 (1.11)	503	1 1/2 (1.11)	559	1 1/2 (1.11)	609	1 1/2 (1.11)	654	1 1/2 (1.11)
	80 (26.6)	3359 (1.59)	408	1 1/2 (1.11)	480	1 1/2 (1.11)	536	1 1/2 (1.11)	589	1 1/2 (1.11)	621	1 1/2 (1.11)
TC400	**50** (10)	6142 (2.9)	647	1 1/2 (1.11)	659	1 1/2 (1.11)	670	1 1/2 (1.11)	713	1 1/2 (1.11)	751	2 (1.49)
	60 (15.5)	5118 (2.41)	553	1 1/2 (1.11)	570	1 1/2 (1.11)	618	1 1/2 (1.11)	653	1 1/2 (1.11)	697	1 1/2 (1.11)
	70 (21.1)	4387 (2.07)	483	1 1/2 (1.11)	523	1 1/2 (1.11)	568	1 1/2 (1.11)	615	1 1/2 (1.11)	660	1 1/2 (1.11)
	80 (26.6)	3839 (1.81)	437	1 1/2 (1.11)	490	1 1/2 (1.11)	547	1 1/2 (1.11)	589	1 1/2 (1.11)	655	1 1/2 (1.11)

SF/SC Series — Sepa ion Unit Heater

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

STANDARD FEATURES

- Enclosed Combustion System
- 20-Gauge Aluminized Steel Tubular Heat Exchanger
- 115/24 Volt Control Transformer
- 83% Thermal Efficiency
- Combustion Air Pressure Switch
- OD (w Pr
- Redundant Single-Stage Gas Valve
- Direct Spark Ignition System
- 115/1/60 Supply Voltage
- Rear Burner Access
- Power Vented
- Individually Adjustable and Removable Horizontal Louvers
- Complete Belt/Fan Guard
- Main Control Panel
- 10 Year Heat Exchanger, Flue Collector and Burner Warranty

OPTIONAL FEATURES

- Stainless Steel Heat Exchanger, Burners, and/or Flue Collector
- Supply Voltages: 208 & 230/1/60 and 208, 230, 460, 575/3/60
- Two-Stage and Various Electronic Modulation Gas Controls
- Premium Efficiency Blower Motors in ODP & TE Types
- Discharge Nozzles (30°, 60° & 90°) or Duct Flange Assembly
- Combustion Air Inlet Kits (allows concentric venting with horizontal or vertical termination)

Unit Number Description

Digit	T	X	X	X	–	1	2	3	4	5	6	7	8	9	10	11	12	13	14	+
Item	Prefix					UT		CA			FT	FM	GT	AL	GC	SV	MT	MS	AS	

(Internal use Only)

1, 2 - Unit Type [UT]
SF - Separated Combustion Tubular Propeller
SC - Separated Combustion Tubular Blower

3, 4, 5 - Capacity [CA]
100 - 100,000 BTU/HR
125 - 125,000 BTU/HR
150 - 150,000 BTU/HR
175 - 175,000 BTU/HR
200 - 200,000 BTU/HR
250 - 250,000 BTU/HR
300 - 300,000 BTU/HR
350 - 350,000 BTU/HR
400 - 400,000 BTU/HR

6 - Furnace Type [FT]
A - Right Side Access

7 - Heat Exchanger Construction Material [FM]
1 - Standard (Aluminized) Steel
2 - 409 Stainless Steel

8 - Gas Type [GT]
N - Natural Gas
P - Propane Gas (LP)

9 - Altitude [AL]
S - 0–4,999 ft.
T - 5,000–11,999 ft.
Note: Installations over 2,000 ft. require gas input deration in the field.
Refer to unit installation instructions.

10 - Direct Spark Gas Control [GC]
1 - Single Stage
2 - Two Stage
3 - Electronic Modulation w/Room Sensing
4 - Electronic Modulation w/Duct Sensing
5 - Electronic Modulation w/Duct Sensing & Room Ovrd. Stat
6 - Electronic Modulation w/External 4-20 mA Input
7 - Electronic Modulation w/External 0-10 VDC Input

11 - Supply Voltage [SV]
1 - 115/1/60
2 - 208/1/60
3 - 230/1/60
4 - 208/3/60
5 - 230/3/60
6 - 460/3/60
7 - 575/3/60
Z - Special
Note: Supply Voltages [SV] 2-7 include step down transformer.
Field mounted for propeller units, factory mounted for blower units.

12 - Motor Type [MT]
1 - Open Drip Proof (Standard)
2 - Totally Enclosed
3 - Premium Efficiency, Open Drip Proof (Blowers Only)
4 - Premium Efficiency, Totally Enclosed (Blowers Only)

13 - Blower Motor Sizes [MS]**
A - 1/4 HP w/Contactor
C - 1/2 HP w/Contactor
D - 3/4 HP w/Contactor
F - 1 HP w/Contactor
G - 1-1/2 HP w/Contactor
H - 2 HP w/Contactor
J - 1/4 HP
L - 1/2 HP
P - 1/2 HP w/Magnetic Starter
R - 3/4 HP w/Magnetic Starter
S - 1 HP w/Magnetic Starter
T - 1-1/2 HP w/Magnetic Starter
U - 2 HP w/Magnetic Starter
W - 1/4 HP w/Magnetic Starter
0 - None/Not Applicable

**Notes: 1. All 3-phase units [SV = 4, 5, 6, 7] include a contactor as standard.
2. All single phase units [SV = 1, 2, 3] include a contactor for units equipped with 3/4 HP. motor or higher [MS =D, F, G, H]
3. [MS] options J, L only available with [SV] option 1 (115/1/60).

14 - Accessories [AS]

FACTORY INSTALLED
M6 - OSHA Type Fan Guard (Propellers Only)
M8 - Discharge Duct Flange (Blowers Only)
P4 - Terminal Block Wiring
P6 - Summer/Winter Switch
S3 - 409 Stainless Steel Flue Collector
S5 - 304L Stainless Steel Burners

† FIELD INSTALLED (AS-____)
† All Field Installed Accessories are to be entered as a separate line item using catalog number which utilizes "AS" as a prefi x. i.e: A7 becomes AS-A7.

A7 - Pressure Regulator 1/2-2 psi

F1 - 1-Stage T675A Ductstat (Blowers Only)
F2 - 2-Stage T678A Ductstat (Blowers Only)

G1 - 1-Stage T87K Mercury Free Thermostat w/Subase Kit
G2 - 1-Stage T87K Mercury Free Thermostat w/TG511A Guard Kit
G3 - 1-Stage T834N Mercury Free Thermostat/Fan Switch
G5 - 2-Stage TH5220D Mercury Free Thermostat w/Subbase
G6 - Locking Thermostat Cover
G8 - 1-Stage T6169C Line Voltage Stat w/Subbase
G9 - 1-Stage T822K Mercury Free Thermostat

M2-2 - Vent Caps (5") (Unit Capacity 100-250)
M2-3 - Vent Caps (6") (Unit Capacity 300-400)
M7 - 2 to 4 Point Suspension Kit (Propellers Only)

P5 - 24V SPST Relay-Specify Purpose

X2 - 30 Degree Downturn Nozzle
X3 - 60 Degree Downturn Nozzle
X4 - 90 Degree Downturn Nozzle
X5 - Vertical Louver Kit

X7-H5 - Horiz. Combustion Air Inlet Kit, 5 inch (Unit Capacity 100-250)
X7-H6 - Horiz. Combustion Air Inlet Kit, 6 inch (Unit Capacity 300-400)
X7-V5 - Vert. Combustion Air Inlet Kit, 5 inch (Unit Capacity 100-250)
X7-V6 - Vert. Combustion Air Inlet Kit, 6 inch (Unit Capacity 300-400)

SF Series — Separa Propeller Performance and Di a

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

Intertek

ENERGY PERFORMANCE VERIFIED
RENDEMENT ENERGETIQUE VERIFIE

UNIT CAPACITY (MBH)	100	12				250	300	350	400
PERFORMANCE DATA†									
Input - BTU/Hr	100,000	125,000	150,000	175,000	200,000	250,000	300,000	350,000	400,000
(kW)	(29.3)	(36.6)	(43.9)	(51.2)	(58.6)	(73.2)	(87.8)	(102.5)	(117.1)
Output - BTU/Hr	83,000	103,750	124,500	145,250	166,000	207,500	249,000	290,500	332,000
(kW)	(24.3)	(30.4)	(36.4)	(42.5)	(48.6)	(60.7)	(72.9)	(85.1)	(97.2)
Thermal Efficiency - %	83	83	83	83	83	83	83	83	83
Free Air Delivery - CFM	1,600	2,200	2,400	2,850	3,200	3,450	5,000	5,600	5,800
(cu. m/s)	(0.756)	(1.039)	(1.133)	(1.346)	(1.511)	(1.629)	(2.361)	(2.644)	(2.738)
Air Temperature Rise - °F	47	42	47	46	47	54	45	47	51
(°C)	(26)	(23)	(26)	(26)	(26)	(30)	(24)	(26)	(28)
Full Load Amps at 120V	6.4	6.9	6.9	8.0	8.0	8.0	11.3	13.5	13.5
MOTOR DATA: Motor HP (Qty)	1/10	1/4	1/4	1/3	1/3	1/3	1/4 (2)	1/3 (2)	1/3 (2)
Motor kW	(0.080)	(0.19)	(0.19)	(0.25)	(0.25)	(0.25)	(0.19)	(0.25)	(0.25)
Motor Type**	SP	PSC	PSC	PSC	PSC	PSC	PSC	PSC	PSC
RPM	1,050	1,140	1,140	1,140	1,140	1,140	1,140	1,140	1,140
Amps @ 115V	4.2	4.7	4.7	5.8	5.8	5.8	9.4	11.6	11.6
DIMENSIONAL DATA - Inches (mm)									
"A" Overall Height to Top of Flue	33-3/4	33-3/4	33-3/4	33-3/4	33-3/4	33-3/4	34	34	34
	(857)	(857)	(857)	(857)	(857)	(857)	(864)	(864)	(864)
"B" Jacket Width of Unit	20-3/4	20-3/4	20-3/4	32-3/4	32-3/4	32-3/4	50-3/4	50-3/4	50-3/4
	(527)	(527)	(527)	(831)	(831)	(831)	(1289)	(1289)	(1289)
"C" Width to CL Flue	13-3/8	13-3/8	13-3/8	19-3/8	19-3/8	19-3/8	28-3/8	28-3/8	28-3/8
	(340)	(340)	(340)	(492)	(492)	(492)	(721)	(721)	(721)
"D" Depth to Rear of Housing	11	11	11	11	11	11	12-1/4	12-1/4	12-1/4
	(279)	(279)	(279)	(279)	(279)	(279)	(311)	(311)	(311)
"E" Hanging Distance Width	18-5/8	18-5/8	18-5/8	30-5/8	30-5/8	30-5/8	48-5/8	48-5/8	48-5/8
	(473)	(473)	(473)	(778)	(778)	(778)	(1235)	(1235)	(1235)
"F" Discharge Opening Width	18-3/4	18-3/4	18-3/4	30-3/4	30-3/4	30-3/4	48-3/4	48-3/4	48-3/4
	(476)	(476)	(476)	(781)	(781)	(781)	(1238)	(1238)	(1238)
"G" Depth to CL Flue	4-3/4	4-3/4	4-3/4	4-3/4	4-3/4	4-3/4	5-1/8	5-1/8	5-1/8
	(121)	(121)	(121)	(121)	(121)	(121)	(130)	(130)	(130)
"L" Overall Unit Width	25-1/4	25-1/4	25-1/4	37-1/4	37-1/4	37-1/4	55-1/4	55-1/4	55-1/4
	(641)	(641)	(641)	(946)	(946)	(946)	(1403)	(1403)	(1403)
"M" Vent Size Diameter* - Inches	5	5	5	5	5	5	6	6	6
(mm)	(127)	(127)	(127)	(127)	(127)	(127)	(152)	(152)	(152)
Gas Inlet, Natural Gas - Inches	1/2	1/2	1/2	1/2	1/2	3/4	3/4	3/4	3/4
Gas Inlet, LP Gas - Inches	1/2	1/2	1/2	1/2	1/2	1/2 OR 3/4	1/2 OR 3/4	1/2 OR 3/4	1/2 OR 3/4
Approximate Unit Weight - Lbs	135	147	157	194	204	214	311	325	339
(kg)	(61)	(67)	(71)	(88)	(93)	(97)	(141)	(147)	(154)
Approximate Ship Weight - Lbs	175	187	197	244	254	264	371	385	399
(kg)	(79)	(85)	(89)	(111)	(115)	(120)	(168)	(175)	(181)

† Ratings shown are for unit installations at elevations between 0 and 2,000 ft (0 to 610m). For unit installations in USA above 2,000 ft. (610m), the unit input must be field derated 4% for each 1,000 ft. (305m) above sea level; refer to local codes, or in absence of local codes, refer to the latest edition of the National Fuel Gas Code, ANSI Standard Z223.1 (NFPA No. 54).

For installations in Canada, any reference to deration at altitudes in excess of 2,000 ft. (610m) are to be ignored. At altitudes of 2,000 ft. to 4,500 ft. (610 to 1372m), the unit must be field derated to 90% of the normal altitude rating, and be so marked in accordance with the ETL certification. See unit installation, operation and maintenance manual for deration information.

* Flue collar is factory supplied with unit; to be field installed per included instructions.

** LEGEND: SP = SHADED POLE PSC = PERMANENT SPLIT CAPACITOR

Rear View

Side View

Front View

SC Series — Separate lower Performance and Dim

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

UNIT CAPACITY (MBH)	100	125				250	300	350	400
PERFORMANCE DATA†									
Input - BTU/Hr	100,000	125,000	150,000	175,000	200,000	250,000	300,000	350,000	400,000
(kW)	(29.3)	(36.6)	(44.0)	(51.3)	(58.6)	(73.3)	(87.9)	(102.6)	(117.2)
Output - BTU/Hr	83,000	103,750	124,500	145,250	166,000	207,500	246,000	290,500	332,000
(kW)	(24.3)	(30.4)	(36.5)	(42.6)	(48.6)	(60.8)	(72.1)	(85.1)	(97.3)
Thermal Efficiency - %	83	83	83	83	83	83	82	83	83
Free Air Delivery - CFM	1,181	1,476	1,771	2,067	2,362	2,953	3,501	4,134	4,724
(cu. m/s)	(0.557)	(0.697)	(0.836)	(0.976)	(1.115)	(1.394)	(1.652)	(1.951)	(2.230)
Air Temperature Rise - °F	65	65	65	65	65	65	65	65	65
(°C)	(36)	(36)	(36)	(36)	(36)	(36)	(36)	(36)	(36)
Outlet Velocity - FPM	370	463	555	395.0	451.0	564.0	422	498	570
(m/s)	(1.879)	(2.351)	(2.819)	(2.006)	(2.291)	(2.864)	(2.143)	(2.529)	(2.895)
Full Load Amps at 115V	7.3	9.4	9.4	14.2	14.2	15.6	15.6	20.8	20.8
Maximum Circuit Ampacity	8.6	11.2	11.2	17.1	17.1	18.9	18.9	25.4	25.4
MOTOR DATA: Motor HP	1/4	1/2	1/2	3/4	3/4	1	1	1-1/2	1-1/2
Motor kW	0.19	0.37	0.37	0.56	0.56	0.75	0.75	1.11	1.11
Motor Type**	SPH	SPH	SPH	SPH	SPH	CAP. START	CAP. START	CAP. START	CAP. START
RPM	1,725	1,725	1,725	1,725	1,725	1,725	1,725	1,725	1,725
Amps @ 115V	5.1	7.2	7.2	11.6	11.6	13.0	13.0	18.2	18.2
DIMENSIONAL DATA - Inches (mm)									
"A" Height to Top of Flue	33-3/4	33-3/4	33-3/4	33-3/4	33-3/4	33-3/4	34	34	34
	(857)	(857)	(857)	(857)	(857)	(857)	(864)	(864)	(864)
"B" Jacket Width of Unit	20-3/4	20-3/4	20-3/4	32-3/4	32-3/4	32-3/4	50-3/4	50-3/4	50-3/4
	(527)	(527)	(527)	(832)	(832)	(832)	(1289)	(1289)	(1289)
"C" Width to Centerline Flue	13-3/8	13-3/8	13-3/8	19-3/8	19-3/8	19-3/8	28-3/8	28-3/8	28-3/8
	(340)	(340)	(340)	(492)	(492)	(492)	(721)	(721)	(721)
"D" Depth to Front Hanger	21	21	21	21	21	21	21	21	21
	(533)	(533)	(533)	(533)	(533)	(533)	(533)	(533)	(533)
"E" Hanging Distance Width	18-5/8	18-5/8	18-5/8	30-5/8	30-5/8	30-5/8	48-5/8	48-5/8	48-5/8
	(473)	(473)	(473)	(778)	(778)	(778)	(1235)	(1235)	(1235)
"F" Hanging Distance Depth	19	19-1/2	19-1/2	32-3/4	32-3/4	32-3/4	23-1/2	32-3/4	32-3/4
	(483)	(495)	(495)	(832)	(832)	(832)	(597)	(832)	(832)
"G" Discharge Opening Width	18-3/4	18-3/4	18-3/4	30-3/4	30-3/4	30-3/4	48-3/4	48-3/4	48-3/4
	(476)	(476)	(476)	(781)	(781)	(781)	(1238)	(1238)	(1238)
"H" Depth to Centerline Flue	4-3/4	4-3/4	4-3/4	4-3/4	4-3/4	4-3/4	5-1/8	5-1/8	5-1/8
	(121)	(121)	(121)	(121)	(121)	(121)	(130)	(130)	(130)
"M" Overall Unit Width	25-1/4	25-1/4	25-1/4	37-1/4	37-1/4	37-1/4	55-1/4	55-1/4	55-1/4
	(641)	(641)	(641)	(946)	(946)	(946)	(1403)	(1403)	(1403)
"P" Overall Unit Depth	49-3/4	49-3/8	49-3/8	56-1/8	56-1/8	56-1/8	53-3/8	56-1/8	56-1/8
	(1264)	(1254)	(1254)	(1426)	(1426)	(1426)	(1356)	(1426)	(1426)
*Vent Size Diameter - Inches	5	5	5	5	5	5	6	6	6
(mm)	(127)	(127)	(127)	(127)	(127)	(127)	(152)	(152)	(152)
Gas Inlet, Natural Gas - Inches	1/2	1/2	1/2	1/2	1/2	3/4	3/4	3/4	3/4
Gas Inlet, LP Gas - Inches	1/2	1/2	1/2	1/2	1/2	1/2 OR 3/4	1/2 OR 3/4	1/2 OR 3/4	1/2 OR 3/4
Approximate Unit Weight - Lbs	173	177	204	248	267	292	374	394	433
(kg)	(78)	(80)	(92)	(112)	(121)	(132)	(170)	(179)	(196)
Approximate Ship Weight - Lbs	258	263	291	384	403	428	524	551	599
(kg)	(117)	(119)	(132)	(174)	(183)	(194)	(238)	(250)	(272)

† Ratings shown are for unit installations at elevations between 0 and 2,000 ft (0 to 610m). For unit installations in USA above 2,000 ft. (610m), the unit input must be field derated 4% for each 1,000 ft. (305m) above sea level; refer to local codes, or in absence of local codes, refer to the latest edition of the National Fuel Gas Code, ANSI Standard Z223.1 (NFPA No. 54).

For installations in Canada, any reference to deration at altitudes in excess of 2,000 ft. (610m) are to be ignored. At altitudes of 2,000 ft. to 4,500 ft. (610 to 1372m), the unit must be field derated to 90% of the normal altitude rating, and be so marked in accordance with the ETL certification. See unit installation, operation and maintenance manual for deration information.

* Flue collar is factory supplied with unit; to be field installed per included instructions.

** LEGEND: SPH = SPLIT PHASE
CAP. START = CAPACITOR START

Rear View

Side View

Front View

SC Series — Separa n Blower Performance Data

RESURGAM. CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/04/13

Unit	Temp.Rise °F (°C)	CFM (cu. m/s)	ıre Inches W.C. (kPa)									
			0.1" (0.02)				0.07)		0.4" (0.10)		0.5" (0.12)	
			RPM	HP (kW)	RPM	HP (kW)	RPM	HP (kW)	RPM	HP (kW)	RPM	HP (kW)
SC100	**50** (10)	1535 (0.724)	804	1/2 (0.37)	860	1/2 (0.37)	927	1/2 (0.37)	989	1/2 (0.37)	1045	1/2 (0.37)
	60 (15.5)	1279 (0.603)	649	1/4 (0.19)	760	1/4 (0.19)	821	1/4 (0.19)	890	1/4 (0.19)	963	1/4 (0.19)
	70 (21.1)	1096 (0.517)	633	1/4 (0.19)	700	1/4 (0.19)	779	1/4 (0.19)	858	1/4 (0.19)	920	1/4 (0.19)
	80 (26.6)	959 (0.452)	591	1/4 (0.19)	665	1/4 (0.19)	733	1/4 (0.19)	801	1/4 (0.19)	869	1/4 (0.19)
SC125	**50** (10)	1919 (0.905)	703	1/2 (0.37)	758	1/2 (0.37)	810	1/2 (0.37)	863	1/2 (0.37)	918	1/2 (0.37)
	60 (15.5)	1599 (0.754)	608	1/2 (0.37)	685	1/2 (0.37)	741	1/2 (0.37)	790	1/2 (0.37)	843	1/2 (0.37)
	70 (21.1)	1371 (0.647)	558	1/2 (0.37)	626	1/2 (0.37)	694	1/2 (0.37)	755	1/2 (0.37)	798	1/2 (0.37)
	80 (26.6)	1199 (0.565)	580	1/2 (0.37)	597	1/2 (0.37)	649	1/2 (0.37)	720	1/2 (0.37)	779	1/2 (0.37)
SC150	**50** (10)	2303 (1.087)	853	1/2 (0.37)	927	1/2 (0.37)	962	1/2 (0.37)	988	1/2 (0.37)	1040	1/2 (0.37)
	60 (15.5)	1919 (0.905)	755	1/2 (0.37)	810	1/2 (0.37)	845	1/2 (0.37)	894	1/2 (0.37)	939	1/2 (0.37)
	70 (21.1)	1645 (0.776)	649	1/2 (0.37)	726	1/2 (0.37)	790	1/2 (0.37)	836	1/2 (0.37)	876	1/2 (0.37)
	80 (26.6)	1439 (0.679)	616	1/2 (0.37)	670	1/2 (0.37)	720	1/2 (0.37)	785	1/2 (0.37)	840	1/2 (0.37)
SC175	**50** (10)	2687 (1.26)	522	3/4 (0.56)	566	3/4 (0.56)	612	3/4 (0.56)	652	3/4 (0.56)	688	3/4 (0.56)
	60 (15.5)	2239 (1.05)	468	3/4 (0.56)	514	3/4 (0.56)	564	3/4 (0.56)	609	3/4 (0.56)	654	3/4 (0.56)
	70 (21.1)	1919 (0.905)	423	3/4 (0.56)	471	3/4 (0.56)	527	3/4 (0.56)	582	3/4 (0.56)	624	3/4 (0.56)
	80 (26.6)	1697 (0.8)	402	3/4 (0.56)	482	3/4 (0.56)	515	3/4 (0.56)	567	3/4 (0.56)	609	3/4 (0.56)
SC200	**50** (10)	3071 (1.44)	592	3/4 (0.56)	627	3/4 (0.56)	670	3/4 (0.56)	702	3/4 (0.56)	748	3/4 (0.56)
	60 (15.5)	2559 (1.2)	526	3/4 (0.56)	561	3/4 (0.56)	597	3/4 (0.56)	647	3/4 (0.56)	688	3/4 (0.56)
	70 (21.1)	2193 (1.03)	468	3/4 (0.56)	519	3/4 (0.56)	556	3/4 (0.56)	612	3/4 (0.56)	653	3/4 (0.56)
	80 (26.6)	1919 (0.905)	432	3/4 (0.56)	481	3/4 (0.56)	537	3/4 (0.56)	593	3/4 (0.56)	638	3/4 (0.56)
SC250	**50** (10)	3839 (1.81)	734	1 (0.75)	766	1 (0.75)	802	1 1/2 (1.11)	836	1 1/2 (1.11)	863	1 1/2 (1.11)
	60 (15.5)	3199 (1.51)	626	1 (0.75)	668	1 (0.75)	700	1 (0.75)	749	1 (0.75)	780	1 (0.75)
	70 (21.1)	2742 (1.29)	545	1 (0.75)	593	1 (0.75)	633	1 (0.75)	680	1 (0.75)	718	1 (0.75)
	80 (26.6)	2399 (1.13)	494	1 (0.75)	555	1 (0.75)	590	1 (0.75)	642	1 (0.75)	680	1 (0.75)
SC300	**50** (10)	4551 (2.14)	734	1 (0.75)	766	1 (0.75)	802	1 1/2 (1.11)	836	1 1/2 (1.11)	863	1 1/2 (1.11)
	60 (15.5)	3792 (1.79)	626	1 (0.75)	668	1 (0.75)	700	1 (0.75)	749	1 (0.75)	780	1 (0.75)
	70 (21.1)	3259 (1.53)	545	1 (0.75)	593	1 (0.75)	633	1 (0.75)	680	1 (0.75)	718	1 (0.75)
	80 (26.6)	2844 (1.34)	494	1 (0.75)	555	1 (0.75)	590	1 (0.75)	642	1 (0.75)	680	1 (0.75)
SC350	**50** (10)	5374 (2.54)	558	1 1/2 (1.11)	598	1 1/2 (1.11)	638	1 1/2 (1.11)	676	1 1/2 (1.11)	727	1 1/2 (1.11)
	60 (15.5)	4478 (2.11)	484	1 1/2 (1.11)	532	1 1/2 (1.11)	588	1 1/2 (1.11)	653	1 1/2 (1.11)	680	1 1/2 (1.11)
	70 (21.1)	3839 (1.81)	451	1 1/2 (1.11)	503	1 1/2 (1.11)	559	1 1/2 (1.11)	609	1 1/2 (1.11)	654	1 1/2 (1.11)
	80 (26.6)	3359 (1.59)	408	1 1/2 (1.11)	480	1 1/2 (1.11)	536	1 1/2 (1.11)	589	1 1/2 (1.11)	621	1 1/2 (1.11)
SC400	**50** (10)	6142 (2.9)	647	1 1/2 (1.11)	659	1 1/2 (1.11)	670	1 1/2 (1.11)	713	1 1/2 (1.11)	751	2 (1.49)
	60 (15.5)	5118 (2.41)	553	1 1/2 (1.11)	570	1 1/2 (1.11)	618	1 1/2 (1.11)	653	1 1/2 (1.11)	697	1 1/2 (1.11)
	70 (21.1)	4387 (2.07)	483	1 1/2 (1.11)	523	1 1/2 (1.11)	568	1 1/2 (1.11)	615	1 1/2 (1.11)	660	1 1/2 (1.11)
	80 (26.6)	3839 (1.81)	437	1 1/2 (1.11)	490	1 1/2 (1.11)	547	1 1/2 (1.11)	589	1 1/2 (1.11)	655	1 1/2 (1.11)

Duct Furnaces

- **QVED SERIES**
- **QVES SERIES**
- **QVSD SERIES**

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

QVED/QVES Series

Indoor Duct Furnace

Sterling HVAC's line of high efficient indoor duct furnaces are designed for ducted air applications. Indoor duct furnaces are designed for use with existing systems for heating, heating / cooling or make-up air systems. Sterling's indoor duct furnaces are available in 10 sizes (100 – 400 MBH) and equipped with electronic spark ignition (100% safety shutoff on LP models), 115 volt power, vent system pressure switch, high limit switch and 24 volt control transformer.

All duct furnaces are ETL certified for installation upstream or downstream from cooling coils (stainless steel heat exchangers are recommended).

Sterling HVAC's products are proudly manufactured in the USA.

HEAT EXCHANGERS
All heat exchangers feature 20-gauge tubes and 18-gauge headers and are available in 3 types of steel:

- Aluminized Steel (Standard)
- 409 Grade Stainless Steel (Optional)
- 321 Grade Stainless Steel (Optional)
- Stainless steel heat exchangers recommended for applications where entering air is below 40°F (4.4°C) and/or duct furnaces are located downstream from cooling coils.

APPLICATIONS
Sterling's duct furnaces are available in variable configurations to meet all application needs. QVED (bottom burner access) and QVES (side burner access) models offer integral power venting through a concentric vent for both outside combustion air and flue gas exhaust.

The QVSD (separated combustion) is designed to be installed in dusty, dirty or mildly corrosive environments, or where high humidity or slightly negative pressures exist. All critical components including the burners, pilot and flue systems are fully enclosed within the unit and protected from the elements insuring clean and efficient combustion. QVSD units are perfect for manufacturing and automotive facilities and greenhouse applications.

QVSD Series

QVED/QVES Series ed Duct Furnace
QVSD — Seperated uct Furnace

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

STANDARD FEATURES

- QVED – Bottom Access Panel
- QVES – Side Access Panel, Right Side
- QVSD – Separated Combustion
- 80% Thermal Efficiency
- Aluminized Steel Heat Exchanger – 20-gauge
- Aluminized Steel Burners with Stainless "Burner Shade Port Protector"
- For Natural and Propane Gases
- Flue Collector
- 115/1/60 Supply Voltage
- Spark Ignited Intermittent Pilot with Electronic Flame Supervision
- Redundant Single Stage Combustion Gas Valve
- High Limit Switch
- Control Transformer, 115/24V
- Combustion Air Pressure Switch
- Adjustable Burner Air Shutters
- Four Point Suspension
- QVSD – Enclosed Combustion System
- 20-Gauge Steel Cabinet with Baked Enamel Finish
- QVSD – Combustion Air/ Flue Connections (see Vent Caps; Two Required per Unit)

Unit Number Description

Digit	X	X	X	X	–	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	+
Item	Prefix					UT		CA			FT	FM	GT	IC	AL	GC	SV	MT	MS	AS	

(Internal use Only)

Digit #1, 2 - Unit Type [UT]
QVED (D2) - Power Vented Duct Furnace
QVSD (D3) - Separated Combustion Duct Furnace
QVES (D6) - Side Service Power Vented Duct Furnace

Digit #3, 4, 5 - Capacity [CA]
100 - 100,000 BTU/HR
125 - 125,000 BTU/HR
150 - 150,000 BTU/HR
175 - 175,000 BTU/HR
200 - 200,000 BTU/HR
225 - 225,000 BTU/HR
250 - 250,000 BTU/HR
300 - 300,000 BTU/HR
350 - 350,000 BTU/HR
400 - 400,000 BTU/HR

Digit #6 - Furnace Type [FT]
A - Right Side Access (Standard)
B - Left Side Access

Digit #7 - Heat Exchanger Construction Material [FM]
1 - Aluminized Steel
2 - 409 Stainless Steel
3 - 321 Stainless Steel

Digit #8 - Gas Type [GT]
N - Natural Gas
P - Propane Gas (LP)
K - Natural Gas w/100% Shutoff

Digit #9 - Ignition Control [IC]
2 - Spark Ignition

Digit #10 - Altitude [AL]
A - 0-1,999 ft.
B - 2,000-2,999 ft.
C - 3,000-3,999 ft.
D - 4,000-4,999 ft.
F - 5,000-5,999 ft.
G - 6,000-6,999 ft.
H - 7,000-7,999 ft.
J - 8,000-8,999 ft.
K - 9,000-9,999 ft.
L - 10,000-10,999 ft.
M - 11,000-11,999 ft.
N - Local Gas Supplier Derate
P - Canadian High Altitude 2,000-4,500 ft.

Digit #11 - Gas Control [GC]
A - Single Stage
B - Two Stage
H - Electronic Modulation w/Room Sensing
J - Electronic Modulation w/Duct Sensing
K - Electronic Modulation w/Duct Sensing & Room Ovrd. Stat
L - Electronic Modulation w/External 4-20 mA Input
N - Electronic Modulation w/External 0-10 VDC Input

Digit #12 - Supply Voltage [SV]
1 - 115/1/60
2 - 208/1/60
3 - 230/1/60
4 - 208/3/60
5 - 230/3/60
6 - 460/3/60
7 - 575/3/60
Z - Special

Note: Supply Voltages [SV] 2-7 include field mounted step down transformer.

Digit #13 - Motor Type [MT]
0 - None/Not Applicable

Digit #14 - Motor Sizes [MS]
0 - None/Not Applicable

Digit #15 - Accessories [AS]

FACTORY INSTALLED
A8 - Input Derate
K4 - Fan Time Delay
K5 - Air Flow Prove Switch
P4 - Terminal Block Wiring
P6 - Summer/Winter Switch
S1 - 409 Stainless Steel Burners
S3 - 409 Stainless Steel Flue Collector

† FIELD INSTALLED (AS-____)
†Field Installed Accessories are not included in the Unit Number. All Field Installed Accessories are entered as a separate line item using the catalog number which utilizes "AS" as a prefix. i.e: A7 becomes AS-A7.

A7 - Pressure Regulator 1/2-2 psi
F1 - 1-Stage T675A Ductstat
F2 - 2-Stage T678A Ductstat
G1 - 1-Stage T87K Mercury Free Thermostat w/Subbase Kit
G2 - 1-Stage T87K Mercury Free Thermostat w/TG511A Guard Kit
G3 - 1-Stage T834N Mercury Free Thermostat w/Fan Switch
G6 - Locking Thermostat Cover
G8 - 1-Stage T6169C Line Voltage Stat w/Subbase
G9 - 1-Stage T822K Mercury Free Thermostat
H5 - Low Ambient Control
M2-1 - Vent Caps (4") (Unit Capacity 100-175)
M2-2 - Vent Caps (5") (Unit Capacity 200-250
M2-3 - Vent Caps (6") (Unit Capacity 300-400)
M3-1 - Adaptors (5"-4") (Unit Capacity 100-175)
M4 - Vertical Combustion Air Inlet Kit
M5 - Horizontal Combustion Air Inlet Kit
P2 - Adjustable High Limit Switch
P3 - Adjustable Fan Switch
P5 - 24V SPST Relay- Specify Purpose
Q7 - Horizontal/Vertical Louvers
S4 - 409 Stainless Drip Pan (Only available on QVED and QVES)

QVSD Series — Separ on Duct Furnace
Performance and Dim

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

UNIT CAPACITY (MBH)	100	125					250	300	350	400
PERFORMANCE DATA†										
Input (Maximum) - BTU/Hr.	100,000	125,000	150,000	175,000	200,000	225,000	250,000	300,000	350,000	400,000
(kW)	(29.3)	(36.6)	(44.0)	(51.3)	(58.6)	(65.9)	(73.3)	(87.9)	(102.6)	(117.2)
Input (Minimum) - BTU/Hr.	50,000	62,500	75,000	87,500	100,000	112,500	125,000	150,000	175,000	200,000
(kW)	(14.6)	(18.3)	(22.0)	(25.6)	(29.3)	(33.0)	(36.6)	(44.0)	(51.3)	(58.6)
Output - BTU/Hr.	80,000	100,000	120,000	140,000	160,000	180,000	200,000	240,000	280,000	320,000
(kW)	(23.4)	(29.3)	(35.1)	(41.0)	(46.9)	(52.7)	(58.6)	(70.3)	(82.0)	(93.7)
Thermal Efficiency - %	80	80	80	80	80	80	80	80	80	80
Free Air Delivery (Minimum) - CFM	822	1,028	1,233	1,439	1,645	1,850	2,056	2,467	2,878	3,289
(cu. m/s)	(0.388)	(0.485)	(0.582)	(0.679)	(0.776)	(0.873)	(0.970)	(1.164)	(1.358)	(1.552)
Air Temperature Rise - °F	90	90	90	90	90	90	90	90	90	90
(°C)	(50)	(50)	(50)	(50)	(50)	(50)	(50)	(50)	(50)	(50)
Pressure Drop - Inches W.C.	0.10	0.09	0.09	0.09	0.09	0.09	0.09	0.10	0.10	0.10
(kPa)	(0.02)	(0.02)	(0.02)	(0.02)	(0.02)	(0.02)	(0.02)	(0.02)	(0.02)	(0.02)
Free Air Delivery (Maximum) - CFM	3,700	4,625	5,550	6,475	7,401	8,326	9,251	11,101	12,951	14,801
(cu. m/s)	(1.746)	(2.183)	(2.620)	(3.056)	(3.493)	(3.930)	(4.366)	(5.240)	(6.113)	(6.986)
Air Temperature Rise - °F	20	20	20	20	20	20	20	20	20	20
(°C)	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)
Pressure Drop - Inches W.C.	2.03	1.92	1.81	1.86	1.90	1.93	1.96	2.00	2.02	2.05
(kPa)	(0.51)	(0.48)	(0.45)	(0.46)	(0.47)	(0.48)	(0.49)	(0.50)	(0.50)	(0.51)
DIMENSIONAL DATA - Inches (mm)										
"A" Overall Unit Width	17-7/8	20-5/8	20-5/8	23-3/8	26-1/8	28-7/8	31-5/8	37-1/8	42-5/8	48-1/8
	(454)	(524)	(524)	(594)	(664)	(733)	(803)	(943)	(1083)	(1222)
"B" Discharge Opening	15-1/2	18-1/4	18-1/4	21	23-3/4	26-1/2	29-1/4	34-3/4	40-1/4	45-3/4
	(394)	(464)	(464)	(533)	(603)	(673)	(743)	(883)	(1022)	(1162)
"C" Hanging Distance Width	17-1/8	19-7/8	19-7/8	22-5/8	25-3/8	28-1/8	30-7/8	36-3/8	41-7/8	47-3/8
	(435)	(505)	(505)	(575)	(645)	(714)	(784)	(924)	(1064)	(1203)
"D" Flue Opening Diameter*	4	4	4	4	5	5	5	6	6	6
	(102)	(102)	(102)	(102)	(127)	(127)	(127)	(152)	(152)	(152)
Gas Inlet, Natural Gas - Inches	1/2	1/2	1/2	1/2	1/2	3/4	3/4	3/4	3/4	3/4
Gas Inlet, LP Gas - Inches	1/2	1/2	1/2	1/2	1/2	3/4	3/4	3/4	3/4	3/4
Approximate Ship Weight - lb	161	180	188	207	227	246	266	305	344	383
(kg)	(73)	(82)	(85)	(93)	(103)	(116)	(121)	(138)	(156)	(174)

† Ratings shown are for unit installations at elevations between 0 and 2,000 ft (0 to 610m). For unit installations in U.S.A. above 2,000 ft. (610m), the unit input must be derated 4% for each 1,000 ft. (305m) above sea level; refer to local codes, or in absence of local codes, refer to the latest edition of the National Fuel Gas Code, ANSI Standard Z223.1 (N.F.P.A. No. 54).

For installations in Canada, any reference to deration at altitudes in excess of 2,000 ft. (610m) are to be ignored. At altitudes of 2,000 ft. to 4,500 ft. (610 to 1372m), the unit must be derated to 90% of the normal altitude rating, and be so marked in accordance with the ETL certification.

* Flue collar is factory supplied with unit; to be field installed per included instructions.

QVSD Separated Combustion Duct Furnace — Bottom Service Access Only

100/250 MBTU/HR UNIT SIZES

300/400 MBTU/HR UNIT SIZES
† OVAL CONNECTOR SHOWN
ACCEPTS 6" DIA (152) PIPE

DIMENSIONS XXX STANDARD UNITS
DIMENSIONS IN PARENTHESIS (XXX) MILLIMETERS

QVED/QVES Series d Duct Furnace
Performance and Di

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

UNIT CAPACITY (MBH)	100	125				225	250	300	350	400
PERFORMANCE DATA†										
Input (Maximum) - BTU/Hr.	100,000	125,000	150,000	175,000	200,000	225,000	250,000	300,000	350,000	400,000
(kW)	(29.3)	(36.6)	(44.0)	(51.3)	(58.6)	(65.9)	(73.3)	(87.9)	(102.6)	(117.2)
Input (Minimum) - BTU/Hr.	50,000	62,500	75,000	87,500	100,000	112,500	125,000	150,000	175,000	200,000
(kW)	(14.6)	(18.3)	(22.0)	(25.6)	(29.3)	(33.0)	(36.6)	(44.0)	(51.3)	(58.6)
Output - BTU/Hr.	80,000	100,000	120,000	140,000	160,000	180,000	200,000	240,000	280,000	320,000
(kW)	(23.4)	(29.3)	(35.1)	(41.0)	(46.9)	(52.7)	(58.6)	(70.3)	(82.0)	(93.7)
Thermal Efficiency - %	80	80	80	80	80	80	80	80	80	80
Free Air Delivery (Minimum) - CFM	929	1,157	1,389	1,620	1,852	2,083	2,315	2,778	3,241	3,704
(cu. m/s)	(0.438)	(0.546)	(0.656)	(0.765)	(0.874)	(0.983)	(1.093)	(1.311)	(1.530)	(1.748)
Air Temperature Rise - °F	80	80	80	80	80	80	80	80	80	80
(°C)	(44)	(44)	(44)	(44)	(44)	(44)	(44)	(44)	(44)	(44)
Pressure Drop - Inches W.C.	0.12	0.13	0.15	0.14	0.14	0.14	0.14	0.13	0.13	0.14
(kPa)	(0.03)	(0.03)	(0.04)	(0.03)	(0.03)	(0.03)	(0.03)	(0.03)	(0.03)	(0.03)
Free Air Delivery (Maximum) - CFM	2,469	3,086	3,704	4,321	4,938	5,556	6,173	7,407	8,642	9,877
(cu. m/s)	(1.165)	(1.457)	(1.748)	(2.040)	(2.331)	(2.622)	(2.914)	(3.496)	(4.079)	(4.662)
Air Temperature Rise - °F	30	30	30	30	30	30	30	30	30	30
(°C)	(17)	(17)	(17)	(17)	(17)	(17)	(17)	(17)	(17)	(17)
Pressure Drop - Inches W.C.	0.90	0.80	0.75	0.75	0.75	0.75	0.80	0.90	0.90	0.90
(kPa)	(0.22)	(0.20)	(0.19)	(0.19)	(0.19)	(0.19)	(0.20)	(0.22)	(0.22)	(0.22)
DIMENSIONAL DATA - Inches (mm)										
"A" Overall Unit Width	17-7/8	20-5/8	20-5/8	23-3/8	26-1/8	28-7/8	31-5/8	37-1/8	42-5/8	48-1/8
	(454)	(524)	(524)	(594)	(664)	(733)	(803)	(943)	(1083)	(1222)
"B" Discharge Opening	15-1/2	18-1/4	18-1/4	21	23-3/4	26-1/2	29-1/4	34-3/4	40-1/4	45-3/4
	(394)	(464)	(464)	(533)	(603)	(673)	(743)	(883)	(1022)	(1162)
"C" Hanging Distance Width	17-1/8	19-7/8	19-7/8	22-5/8	25-3/8	28-1/8	30-7/8	36-3/8	41-7/8	47-3/8
	(435)	(505)	(505)	(575)	(645)	(714)	(784)	(924)	(1064)	(1203)
"D" Flue Opening Diameter*	4	4	4	4	5	5	5	6	6	6
	(102)	(102)	(102)	(102)	(127)	(127)	(127)	(152)	(152)	(152)
"F" Clearance for Burner Drawer	23-7/8	25-5/8	26-5/8	29-3/8	32-1/8	34-7/8	37-5/8	43-1/8	48-5/8	54-1/8
Access (Side Access Type Only)	(606)	(651)	(676)	(746)	(816)	(886)	(956)	(1095)	(1235)	(1375)
Gas Inlet, Natural Gas - Inches	1/2	1/2	1/2	1/2	1/2	3/4	3/4	3/4	3/4	3/4
Gas Inlet, LP Gas - Inches	1/2	1/2	1/2	1/2	1/2	3/4	3/4	3/4	3/4	3/4
Approximate Ship Weight - lb	173	186	197	216	232	254	263	312	389	403
(kg)	(78)	(84)	(89)	(98)	(105)	(115)	(119)	(142)	(176)	(183)

† Ratings shown are for unit installations at elevations between 0 and 2,000 ft (0 to 610m). For unit installations in U.S.A. above 2,000 ft. (610m), the unit input must be derated 4% for each 1,000 ft. (305m) above sea level; refer to local codes, or in absence of local codes, refer to the latest edition of the National Fuel Gas Code, ANSI Standard Z223.1 (N.F.P.A. No. 54).

For installations in Canada, any reference to deration at altitudes in excess of 2,000 ft. (610m) are to be ignored. At altitudes of 2,000 ft. to 4,500 ft. (610 to 1372m), the unit must be derated to 90% of the normal altitude rating, and be so marked in accordance with the ETL certification.

* Flue collar is factory supplied with unit; to be field installed per included instructions.

Temperature Rise and Pressure Drop Graph

QVED/QVED Series – Dimensional Data

Duct Furnace

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

QVED Power Vented Duct Furnace — Bottom Service Acccess

REAR VENT POSITION SHOWN SEE DETAIL G FOR OPTIONAL TOP VENT POSITION

QVES Power Vented Duct Furnace — Side Service Access

* CANADIAN UNITS INCLUDE VENT CAP AND REDUCER (IF REQ'D).
REAR VENT POSITION SHOWN SEE DETAIL G FOR OPTIONAL TOP VENT POSITION

Detail G

DETAIL G

POSITIONS - FRONT - REAR - RIGHT - LEFT

DIMENSIONS XX" STANDARD UNITS
DIMENSIONS IN PARENTHESIS (XX) MILLIMETERS

CAB Series — Cabi

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

STANDARD FEATURES

- Sterling Cabinet Blowers have been especially designed for use with Sterling Duct Furnaces.
- Duct Flange at rear to facilitate attaching Ductwork.
- Side panels removable for inspection, servicing and motor maintenance.
- Four sizes provide CFM capacities ranging from 1,250 to 8,000 CFM (0.59 to 3.78 m^3/s).
- Sheet metal duct pieces for connecting Cabinet Blower to Duct Furnace are furnished only with Sterling Cabinet Blower-Duct Furnace combinations.
- Cabinet finished in baked enamel.

Unit Number Description

Digit	C	X	X	X	–	1	2	3	4	5	6	7	8	9	10	11	+
Item	Prefix (Internal use Only)					UT				CA			SV	MT	MS	AS	

1, 2, 3, 4 - Unit Type [UT]
CAB1 - Cabinet Blower Size 1
CAB2 - Cabinet Blower Size 2
CAB3 - Cabinet Blower Size 3
CAB4 - Cabinet Blower Size 4

5, 6, 7 - Furnace Capacity [CA]*
100 - 100,000 BTU/HR
125 - 125,000 BTU/HR
150 - 150,000 BTU/HR
175 - 175,000 BTU/HR
200 - 200,000 BTU/HR
225 - 225,000 BTU/HR
250 - 250,000 BTU/HR
300 - 300,000 BTU/HR
350 - 350,000 BTU/HR
400 - 400,000 BTU/HR
000 - No Transition Required
* Indicates transition duct size needed for corresponding QVED or QVES Duct Furnace. Refer to "Compatible Duct Furnace Capacity" indicated in the table on page 22.

8 - Supply Voltage [SV]
1 - 115/1/60
2 - 208/1/60
3 - 230/1/60
4 - 208/3/60
5 - 230/3/60
6 - 460/3/60
7 - 575/3/60
Z - Other

9 - Motor Type [MT]
1 - Open Drip Proof
2 - Totally Enclosed
3 - Premium Efficiency, Open Drip Proof
4 - Premium Efficiency, Totally Enclosed

10 - Blower Motor Sizes [MS]
B - 1/3 HP. w /Contactor
C - 1/2 HP. w/Contactor
D - 3/4 HP. w/Contactor
F - 1 HP. w/Contactor
G - 1-1/2 HP. w/Contactor
H - 2 HP. w/Contactor
J - 3 HP. w/Contactor
K - 1/3 HP.
L - 1/2 HP.
M - 3/4 HP.
N - 1 HP.
P - 1/2 HP w/Magnetic Starter
R - 3/4 HP w/Magnetic Starter
S - 1 HP w/Magnetic Starter
T - 1-1/2 HP w/Magnetic Starter
U - 2 HP w/Magnetic Starter
W - 3 HP w/Magnetic Starter
Y - 1/3 HP w/Magnetic Starter

11 - Accessories [AS]

All Field Installed Accessories are to be entered as a separate line item using the catalog number which utilizes "AS" as a prefix. i.e: F1 becomes AS-F1.

FACTORY INSTALLED
B1 - 1 in. Washable Filters
B6 - 1 in. Throwaway Filters

K4 - Fan Time Delay

P4 - Terminal Block Wiring

Y5 - Cabinet Insulation
Y6 - Transition Insulation

FIELD INSTALLED (AS-____)
F1 - 1-Stage T675A Ductstat
F2 - 2-Stage T678A Ductstat

G1 - 1-Stage T87K Mercury Free Thermostat w/Subbase
G2 - 1-Stage T87K Mercury Free Thermostat w/TG511A Guard Kit
G3 - 1-Stage T834N Mercury Free Thermostat/Fan Switch
G5 - 2-Stage TH5220D Mercury Free Thermostat w/Subbase
G6 - Locking Thermostat Cover
G8 - 1-Stage T6169C Line Voltage Stat w/Subbase
G9 - 1-Stage T822K Mercury Free Thermostat

Motor Data

CURRENT CHARACTERISTICS	1/3 H.P. R.P.M.	1/3 H.P. AMPS	1/2 H.P. R.P.M.	1/2 H.P. AMPS	3/4 H.P. R.P.M.	3/4 H.P. AMPS	1 H.P. R.P.M.	1 H.P. AMPS	1-1/2 H.P. R.P.M.	1-1/2 H.P. AMPS	2 H.P. R.P.M.	2 H.P. AMPS	3 H.P. R.P.M.	3 H.P. AMPS
115-1-60	1725	5.9	1725	7.2										
115/230-1-60					1725	11 / 5.5	1725	15.4 / 7.7	1725	16.4 / 8.2	1725	26 / 13		
Approx. Ship Wt.	16#		21#		25#		31#		41#		44#			
208/230/460-3-60			1725	28 / 1.4	1725	2.6 / 1.3	1725	3.2 / 1.6	1725	4.3 / 2.2	1725	5.8 / 2.9	1725	9.5 / 4.8
Approx. Ship Wt.			25#		28#		31#		41#		41#		43#	

MOTOR FRAME MUST NOT EXCEED NEMA SIZE 56.

CAB Series — Cabine Dimensional Data

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

MODEL NO. *	A in. (mm)	B in. (mm)	C in. (mm)	(mm)	(mm)	(mm)	G in. (mm)	APPR. SHIP WT. FILTER DATA SIZE **	FILTER REQ'D.	LESS MOTOR LB (KG)
CAB-1/100	65-1/2	26	10	18	21-1/4	15-3/4	15-5/8	25 X 25 X 1	1	135
	(1664)	(660)	(254)	(457)	(540)	(400)	(397)			(61)
CAB-1/125	65-1/2	26	10	18	21-1/4	15-3/4	18-3/8	25 X 25 X 1	1	135
	(1664)	(660)	(254)	(457)	(540)	(400)	(467)			(61)
CAB-2/150	65-1/2	26	10	18	21-1/4	15-3/4	18-3/8	25 X 25 X 1	1	155
	(1664)	(660)	(254)	(457)	(540)	(400)	(467)			(70)
CAB-2/175	65-1/2	26	10	18	21-1/4	15-3/4	21-1/8	25 X 25 X 1	1	155
	(1664)	(660)	(254)	(457)	(540)	(400)	(537)			(70)
CAB-3/200	65-1/2	40-1/2	10	18	35-3/4	30-3/8	23-7/8	25 X 20 X 1	2	200
	(1664)	(1029)	(254)	(457)	(908)	(772)	(606)			(91)
CAB-3/225	65-1/2	40-1/2	10	18	35-3/4	30-3/8	26-5/8	25 X 20 X 1	2	200
	(1664)	(1029)	(254)	(457)	(908)	(772)	(676)			(91)
CAB-3/250	65-1/2	40-1/2	10	18	35-3/4	30-3/8	29-3/8	25 X 20 X 1	2	200
	(1664)	(1029)	(254)	(457)	(908)	(772)	(746)			(91)
CAB-4/300	65-1/2	60-1/2	10	18	55-3/4	50-3/8	34-7/8	25 X 20 X 1	3	296
	(1664)	(1537)	(254)	(457)	(1416)	(1280)	(886)			(134)
CAB-4/350	69-1/2	60-1/2	14	22	55-3/4	50-3/8	40-3/8	25 X 20 X 1	3	296
	(1765)	(1537)	(356)	(559)	(1416)	(1280)	(1026)			(134)
CAB-4/400	69-1/2	60-1/2	14	22	55-3/4	50-3/8	45-7/8	25 X 20 X 1	3	296
	(1765)	(1537)	(356)	(559)	(1416)	(1280)	(1165)			(134)

*Never use a single cabinet blower to handle more than one duct furnace. CAB-4 has two blowers driven by one motor.
**Standard filters are 1'' thick throw away type. Side panels removable for inspection, servicing and motor maintenance. Cabinet painted gray enamel.

Sterling reserves the right to change specifications without incurring obligations.

Cabinet blower units are not certified by ETL.

DIMENSIONS .XXX STANDARD UNITS
DIMENSIONS IN PARENTHESIS (XX) MILLIMETERS

CAB Series — Cabi
Performance Data

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

Total Static Pressure * in. of W.C. (kPa)	0.2 (0.05)		0.3 (0.07)		0.4 (0.10)		(0.12)		(0.15)		(0.17)		0.8 (0.20)		0.9 (0.22)		DUCT FURNACE SECTIONS PRESSURE DROP			
MODEL	CFM (cu. m/s)	RPM	HP (kW)	RPM	HP (kW)	RPM	HP (kW)	RPM	HP (kW)	RPM	HP (kW)	RPM	HP (kW)	RPM	HP (kW)	RPM	HP (kW)	SIZE	in. W.C. (kPa)	SIZE	in. W.C. (kPa)
	1,250 (0.590)	525	1/3 (0.25)	650	1/3 (0.25)	680	1/3 (0.25)	760	1/3 (0.25)	780	1/3 (0.25)	840	1/3 (0.25)	..	..	..	..	100	0.16 (0.04)	..	..
	1,250 (0.590)	525	1/3 (0.25)	650	1/3 (0.25)	680	1/3 (0.25)	760	1/3 (0.25)	780	1/3 (0.25)	840	1/3 (0.25)	..	..	..	..	125	0.10 (0.02)	..	..
CAB 1	1,500 (0.708)	600	1/3 (0.25)	680	1/3 (0.25)	715	1/3 (0.25)	790	1/3 (0.25)	810	1/2 (0.37)	860	1/2 (0.37)	895	1/2 (0.37)	970	1/2 (0.37)	125	0.15 (0.04)	..	..
10" BLOWER	1,750 (0.826)	650	1/3 (0.25)	710	1/3 (0.25)	750	1/2 (0.37)	805	1/2 (0.37)	850	1/2 (0.37)	890	1/2 (0.37)	940	3/4 (0.56)	990	3/4 (0.56)	125	0.18 (0.04)	..	..
	2,000 (0.944)	700	1/2 (0.37)	760	1/2 (0.37)	800	1/2 (0.37)	850	1/2 (0.37)	890	1/2 (0.37)	925	3/4 (0.56)	980	3/4 (0.56)	1,010	3/4 (0.56)	125	0.24 (0.06)	..	..
	1,500 (0.708)	425	1/3 (0.25)	500	1/3 (0.25)	550	1/3 (0.25)	630	1/3 (0.25)	..	..	..	..	..	..	..	..	150	0.09 (0.02)	175	0.07 (0.02)
	1,750 (0.826)	450	1/3 (0.25)	515	1/3 (0.25)	560	1/3 (0.25)	635	1/2 (0.37)	680	1/2 (0.37)	725	1/2 (0.37)	..	..	..	..	150	0.15 (0.04)	175	0.11 (0.03)
CAB 2	2,000 (0.944)	475	1/3 (0.25)	530	1/3 (0.25)	590	1/2 (0.37)	640	1/2 (0.37)	690	1/2 (0.37)	740	1/2 (0.37)	785	1/2 (0.37)	810	3/4 (0.56)	150	0.20 (0.05)	175	0.14 (0.03)
12" BLOWER	2,250 (1.062)	515	1/2 (0.37)	560	1/2 (0.37)	610	1/2 (0.37)	650	1/2 (0.37)	700	3/4 (0.56)	750	3/4 (0.56)	790	3/4 (0.56)	815	3/4 (0.56)	175	0.18 (0.04)	..	..
	2,500 (1.180)	540	1/2 (0.37)	590	1/2 (0.37)	625	1/2 (0.37)	670	1/2 (0.37)	710	3/4 (0.56)	760	3/4 (0.56)	795	3/4 (0.56)	820	3/4 (0.56)	175	0.22 (0.05)	..	..
	2,750 (1.298)	575	1/2 (0.37)	615	1/2 (0.37)	650	3/4 (0.56)	690	3/4 (0.56)	730	3/4 (0.56)	780	3/4 (0.56)	800	3/4 (0.56)	830	1 (0.75)	175	0.27 (0.07)	..	..
	1,750 (0.826)	450	1/3 (0.25)	510	1/3 (0.25)	560	1/3 (0.25)	630	1/3 (0.25)	675	1/2 (0.37)	720	1/2 (0.37)	..	..	..	..	200	0.09 (0.02)	..	..
	2,000 (0.944)	475	1/3 (0.25)	525	1/3 (0.25)	590	1/2 (0.37)	635	1/2 (0.37)	680	1/2 (0.37)	735	1/2 (0.37)	785	1/2 (0.37)	810	3/4 (0.56)	200	0.11 (0.03)	225	0.09 (0.02)
	2,250 (1.062)	500	1/2 (0.37)	550	1/2 (0.37)	600	1/2 (0.37)	645	1/2 (0.37)	685	1/2 (0.37)	740	3/4 (0.56)	785	3/4 (0.56)	810	3/4 (0.56)	200	0.14 (0.03)	225	0.11 (0.03)
	2,500 (1.180)	525	1/2 (0.37)	580	1/2 (0.37)	615	1/2 (0.37)	665	1/2 (0.37)	700	3/4 (0.56)	750	3/4 (0.56)	790	3/4 (0.56)	815	3/4 (0.56)	200	0.17 (0.04)	225	0.13 (0.03)
	2,750 (1.298)	560	1/2 (0.37)	605	1/2 (0.37)	640	3/4 (0.56)	685	3/4 (0.56)	715	3/4 (0.56)	775	3/4 (0.56)	805	3/4 (0.56)	825	1 (0.75)	200	0.20 (0.05)	225	0.14 (0.03)
CAB 3	3,000 (1.416)	610	1/2 (0.37)	640	3/4 (0.56)	660	3/4 (0.56)	710	3/4 (0.56)	750	1 (0.75)	790	1 (0.75)	815	1 (0.75)	845	1 (0.75)	200	0.22 (0.05)	225	0.175 (0.04)
12" BLOWER	2,250 (1.062)	500	1/2 (0.37)	550	1/2 (0.37)	590	1/2 (0.37)	645	1/2 (0.37)	675	1/2 (0.37)	735	1/2 (0.37)	780	3/4 (0.56)	805	3/4 (0.56)	250	0.09 (0.02)	..	..
	2,500 (1.180)	520	1/2 (0.37)	580	1/2 (0.37)	610	1/2 (0.37)	665	1/2 (0.37)	700	3/4 (0.56)	745	3/4 (0.56)	800	3/4 (0.56)	810	3/4 (0.56)	250	0.11 (0.03)	..	..
	2,750 (1.298)	550	1/2 (0.37)	605	1/2 (0.37)	640	3/4 (0.56)	680	3/4 (0.56)	710	3/4 (0.56)	770	3/4 (0.56)	810	3/4 (0.56)	820	3/4 (0.56)	250	0.12 (0.03)	..	..
	3,000 (1.416)	600	3/4 (0.56)	640	3/4 (0.56)	670	3/4 (0.56)	705	3/4 (0.56)	730	3/4 (0.56)	785	1 (0.75)	820	1 (0.75)	840	1 (0.75)	250	0.14 (0.03)	..	..
	3,250 (1.534)	630	3/4 (0.56)	675	3/4 (0.56)	700	1 (0.75)	735	1 (0.75)	750	1 (0.75)	790	1 (0.75)	830	1 (0.75)	860	1 (0.75)	250	0.16 (0.04)	..	..
	3,500 (1.652)	675	3/4 (0.56)	700	1 (0.75)	725	1 (0.75)	775	1 (0.75)	800	1 (0.75)	840	1-1/2 (1.12)	875	1-1/2 (1.12)	890	1-1/2 (1.12)	250	0.20 (0.05)	..	..
	2,750 (1.298)	400	3/4 (0.56)	450	3/4 (0.56)	510	3/4 (0.56)	..	..	..	..	..	..	..	..	..	..	300	0.09 (0.02)	..	..
	3,000 (1.416)	425	3/4 (0.56)	475	3/4 (0.56)	550	3/4 (0.56)	600	3/4 (0.56)	650	3/4 (0.56)	..	..	..	..	..	..	300	0.10 (0.02)	..	..
	3,500 (1.652)	430	3/4 (0.56)	480	3/4 (0.56)	560	3/4 (0.56)	610	3/4 (0.56)	660	3/4 (0.56)	700	1 (0.75)	730	1 (0.75)	..	..	300	0.14 (0.03)	350	0.1 (0.02)
	4,000 (1.888)	450	3/4 (0.56)	500	3/4 (0.56)	565	3/4 (0.56)	615	3/4 (0.56)	670	1 (0.75)	710	1 (0.75)	740	1 (0.75)	790	1 (0.75)	300	0.18 (0.04)	350	0.13 (0.03)
	4,500 (2.124)	475	3/4 (0.56)	525	3/4 (0.56)	575	3/4 (0.56)	620	1 (0.75)	680	1 (0.75)	715	1 (0.75)	750	1 (0.75)	800	1-1/2 (1.12)	350	0.16 (0.04)	400	0.14 (0.03)
	5,000 (2.360)	500	3/4 (0.56)	540	3/4 (0.56)	600	1 (0.75)	630	1 (0.75)	690	1 (0.75)	720	1-1/2 (1.12)	760	1-1/2 (1.12)	810	1-1/2 (1.12)	350	0.20 (0.05)	400	0.17 (0.04)
	5,500 (2.596)	530	1 (0.75)	575	1 (0.75)	615	1 (0.75)	650	1-1/2 (1.12)	700	1-1/2 (1.12)	700	1-1/2 (1.12)	730	1-1/2 (1.12)	820	1-1/2 (1.12)	350	0.23 (0.06)	400	0.2 (0.05)
CAB 4 (2) 12" BLOWERS	6,000 (2.832)	575	1-1/2 (1.12)	615	1-1/2 (1.12)	660	1-1/2 (1.12)	690	1-1/2 (1.12)	715	1-1/2 (1.12)	760	2 (1.49)	800	2 (1.49)	830	2 (1.49)	350	0.26 (0.06)	400	0.23 (0.06)
	6,500 (3.068)	610	1-1/2 (1.12)	660	2 (1.49)	710	2 (1.49)	750	2 (1.49)	800	2 (1.49)	840	2 (1.49)	890	3 (2.24)	930	3 (2.24)	350	0.30 (0.07)	400	0.26 (0.06)
	7,000 (3.304)	720	1-1/2 (1.12)	790	2 (1.49)	830	2 (1.49)	860	2 (1.49)	910	3 (2.24)	940	3 (2.24)	960	3 (2.24)	NA		400	0.28 (0.07)	..	..
	7,500 (3.540)	800	2 (1.49)	860	2 (1.49)	900	3 (2.24)	930	3 (2.24)	960	3 (2.24)	NA		NA		NA		400	0.30 (0.07)	..	..
	8,000 (3.776)	860	2 (1.49)	930	3 (2.24)	960	3 (2.24)	NA		NA		NA		NA		NA		400	0.31 (0.08)	..	..

*External static pressure in inches of W.C. Add the pressure drop of the duct furnace and the pressure drop of the ductwork to determine the total external static pressure.

Accessories [AC]

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

FACTORY INSTALLED

A8 - INPUT DERATE
Series QVED, QVES, QVSD
Factory Installed
Unit is derated up to 50% for specific applications.

K4 - FAN TIME DELAY
Series QVED, QVES, QVSD
Field Installed
Thermal bi metalic type time delay is standard on all units except duct furnaces. Provides a 60 delay on and 45 second delay off for blower operation.

K5 - AIR FLOW PROVE SWITCH
Series QVED, QVES and QVSD
Factory Installed
A Dwyer 1910-0 pressure switch with an operating range of 0.15 - 0.5" WC.

M6 - OSHA TYPE FAN GUARD
Series TF, SF
Factory installed available on series TF and SF only, standard on series GG. Required for installations that must conform to OSHA standards. Also known as fingerproof fan guards.

M8 - DISCHARGE DUCT FLANGE ASSEMBLY
Series TC, SC
Factory Installed
(Specify — No Charge)
Used in lieu of louvers on blower units for incorporating field duct work.

P4 - TERMINAL BLOCK WIRING
Series TF, TC, SF, SC, QVED, QVES, QVSD
Factory Installed
Provides specific terminal designation for field wiring.

P6 - SUMMER/WINTER SWITCH
Series TF, TC, SF, SC, QVED, QVES, QVSD
Factory Installed
Allows operation of fan or blower for ventilating purposes during hot summer months (manually operated).

S1 - 409 STAINLESS STEEL BURNERS
Series QVED, QVES, QVSD
Factory Installed
409 stainless steel burners in lieu of the standard aluminized steel burners.

S3 - STAINLESS STEEL FLUE COLLECTOR
All Series and Sizes
Factory Installed
409 Stainless steel flue collector in lieu of standard aluminized steel collector.

S5 - STAINLESS STEEL BURNERS
Series TF, TC, SF, SC
Factory Installed
304L Stainless steel in-shot burners in lieu of the standard aluminized steel in-shot burners.

FIEI

A7 -

Field Installed
Required where main line pressure exceeds 14" WC (1/2 psig), must specify incoming pressure when ordered. One regulator per unit required, shipped separately.

F1 - ONE STAGE DUCTSTAT
Series TC, SC, QVED, QVES, QVSD
Field Installed
Single pole, double throw. 55-175°F setpoint range.
[2" W x 5-5/8" H x 2-7/16" D]

F2 - TWO STAGE DUCTSTAT
Series TC, SC, QVED, QVES, QVSD
Field Installed
Single pole, double throw. 55-175°F setpoint range.
[2" W x 5-5/8" H x 2-7/16" D]

G1 - ONE STAGE T87K (MERCURY-FREE) THERMOSTAT WITH SUBBASE
All Series and Sizes
Field Installed
Single stage heating thermostat with subbase. Includes fan switching relay. Standard round styling suitable for any decor. 40-90°F range.

G2 - ONE STAGE T87K (MERCURY-FREE) THERMOSTAT WITH TG511A GUARD
All Series and Sizes
Field Installed
Same features as "G1" except a tamper proof guard is included.

G3 - ONE STAGE T834N (MERCURY-FREE) THERMOSTAT WITH FAN SWITCH
All Series and Sizes
Field Installed
Single stage heating thermostat with fan switch. Manufactured exclusively for Sterling with a "Sterling" logo face plate. 50-90°F range.
[2-3/8" W x 4-3/4" H x 1-1/2" D]

G5 - TWO STAGE TH5220D (MERCURY-FREE) THERMOSTAT WITH SUBBASE
All Series and Sizes
Field Installed
Two stage heating and two stage cooling with system and fan switching and built in 10°F heating/cooling differential. Includes fan relay. Heating 40-90°F range, Cooling 50-99°F.
[5-13/16" W x 3-9/16" H x 1-1/2" D]

G6 - LOCKING THERMOSTAT COVER
All Series and Sizes
Field Installed
Universal locking thermostat cover for use with all thermostats listed.

G8 - ONE STAGE T6169C LINE VOLTAGE STAT WITH SUBBASE
All Series and Sizes
Field Installed
Single stage heating only thermostat. 115 volt operation. 44-86°F range
[4-1/2" W x 4-5/8" H x 1-7/8" D]

G9 - ONE STAGE T822K (MERCURY-FREE) THERMOSTAT
All Series and Sizes
Field Installed
Single stage heating only thermostat with subbase. 24 volt operation. 50-90°F range.
[2-7/8" W x 4-3/4" H x 1-1/2" D]

H5 - LOW AMBIENT CONTROL
Series QVED, QVES and QVSD
Field Installed
Disengages duct furnace(s) from firing in times of mild ambient temperatures.

M2 - 1, 2, 3 - VENT CAP
Series TF, TC, SF, SC, QVED, QVES, QVSD
Field Installed
4 (QVED, QVES, QVSD only), 5 or 6 inch vent cap for use with series TF, TC, SF, SC, QVED, QVES, QVSD. Must indicate unit size when ordered.

M3-1 - ADAPTOR
Series QVED, QVES and QVSD
Field Installed
4 to 5" flue vent adaptor for use with 100 through 175 MBH power vented units. Power vented unit capacities 300, 350 and 400 require 5 to 6" flue vent adaptor which is supplied with the unit as standard equipment.

M4 - VERTICAL CONCENTRIC FLUE KIT
Series QVSD
Field Installed
Allows for one 8 inch vent/combustion air vertical penetration through a structure. Kit includes collection box, 5" flue gas vent cap and 8" combustion air inlet cap.

M5- HORIZONTAL CONCENTRIC FLUE KIT
Series QVSD
Field Installed
Allows for one 8 inch vent/combustion air horizontal penetration through a structure. Kit includes collection box, 5" flue gas vent cap and 8" combustion air inlet cap.

M7- 2 to 4 POINT SUSPENSION KIT
Series TF, SF
Field Installed
Kit converts 2 point unit heater suspension to 4 point.

P2 - ADJUSTABLE HIGH LIMIT SWITCH
Series QVED, QVES and QVSD
Field Installed
Adjustable switch used in conjunction with the standard header mounted high limit switch.

Accessories [AC]

RESURGAM. CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/04/13

P3 - ADJUSTABLE FAN SWITCH
Series QVED, QVES, QVES and QVSD
Field Installed
Adjustable switch used to cycle a separate blower.

P5 - 24 VOLT RELAY
All Series and Sizes
Field Installed
Specify purpose. 24 volt SPST relay.

Q7 - HORIZONTAL AND VERTICAL LOUVERS
Series QVED, QVES and QVSD
Field Installed
For four way deflection on duct.

S4 - 409 STAINLESS STEEL DRAIN PAN
Series QVED, QVES
Field Installed
Condensate drain pan typically used when cooling coils are installed upstream of duct.

VC - 4 VENT CAP
Series GG
Field Installed
4" vent cap for use with series GG.

Air can be directed up to 60° by adjusting the horizontal louvers. Louvers are supplied with the unit heater and must be reinstalled in the nozzle discharge. Must indicate unit size when ordered.

X3 - 60° NOZZLE
Series GG, TF, TC, SF, SC
Field Installed
Directs the discharge air at a 60° angle. Air can be directed up to 90° by adjusting the horizontal louvers. Louvers are supplied with the unit heater and must be reinstalled in the nozzle discharge. Must indicate unit size when ordered.

X4 - 90° NOZZLE
Series GG, TF, TC, SF, SC
Field Installed
Directs the discharge air at a 90° angle. Louvers are supplied with the unit heater and must be reinstalled in the nozzle discharge. Must indicate unit size when ordered.

X5 - VERTICAL LOUVER KIT
Series TF, TC, SF, SC
Field Installed
Vertical Louvers to provide 4 way air deflection. Must indicate unit size when ordered.

X7 - 4, 5 COMBUSTION AIR INLET KIT
Series GG
Field Installed
Allows for one 6 or 8" vent/combustion air opening through a structure. One kit permits for either horizontal or vertical applications. *Kit required for converting a series GG to separated combustion.*

X7 - H5, H6 HORIZONTAL COMBUSTION AIR INLET KIT
Series SF, SC
Field Installed
Allows for one 8 or 10" horizontal vent/combustion air opening through a structure. Must indicate unit size when ordered.

X7 - V5, V6 VERTICAL COMBUSTION AIR INLET KIT
Series SF, SC
Field Installed
Allows for one 8 or 10" vertical vent/combustion air opening through a structure. Must indicate unit size when ordered.

Heat Throw Data

NOTES: 1. All throw data shown below is for tubular unit h QVSD and CAB.
2. All throw data figures are approximations. Allov mance, altitude, etc.
3. "NR" - Units not recommended at these mounti
4. 30°, 60° and 90° nozzles are shipped unassemb

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

STANDARD UNIT HEATER APPLICATIONS

Distance From Floor to Bottom of Unit "H" Ft. (m)	Approximate Distance of Heat Throw - Feet (Meters)			
	UNIT SIZE BTU/HR (kW)			
	30,000 (8.8)	45,000 (13.2)	60,000 (17.6)	75,000 (22.0)
8 (2.4)	33 (10.1)	33 (10.1)	33 (10.1)	40 (12.2)
10 (3.0)	28 (8.5)	28 (8.5)	28 (8.5)	35 (10.7)
12 (3.7)	NR	NR	NR	NR
15 (4.6)	NR	NR	NR	NR
20 (6.1)	NR	NR	NR	NR
	UNIT SIZE BTU/HR (kW)			
	90,000 (26.4)	100,000 (29.3)	105,000 (30.8)	120,000 (34.2)
8 (2.4)	40 (12.2)	60 (18.3)	60 (18.3)	65 (19.8)
10 (3.0)	35 (10.7)	54 (16.5)	54 (16.5)	56 (17.1)
12 (3.7)	NR	44 (13.4)	44 (13.4)	46 (14.0)
15 (4.6)	NR	NR	NR	NR
20 (6.1)	NR	NR	NR	NR
	UNIT SIZE BTU/HR (kW)			
	125,000 (36.6)	150,000 (43.9)	175,000 (51.2)	200,000 (58.6)
8 (2.4)	65 (19.8)	70 (21.3)	75 (22.9)	80 (24.4)
10 (3.0)	56 (17.1)	60 (18.3)	64 (19.5)	68 (20.7)
12 (3.7)	46 (14.0)	49 (14.9)	57 (17.4)	61 (18.6)
15 (4.6)	NR	45 (13.7)	49 (14.9)	52 (15.8)
20 (6.1)	NR	NR	NR	46 (14.0)
	UNIT SIZE BTU/HR (kW)			
	250,000 (73.2)	300,000 (87.8)	350,000 (102.5)	400,000 (117.1)
8 (2.4)	90 (27.4)	105 (32.0)	110 (33.5)	120 (36.6)
10 (3.0)	78 (23.8)	90 (27.4)	95 (29.0)	100 (30.5)
12 (3.7)	68 (20.7)	80 (24.4)	84 (25.6)	90 (27.4)
15 (4.6)	60 (18.3)	70 (21.3)	74 (22.6)	80 (24.4)
20 (6.1)	54 (16.5)	63 (19.2)	66 (20.1)	70 (21.3)

30° NOZZLE

Distance From Floor to Bottom of Unit "H" Ft. (m)	Approximate Distance of Heat Throw - Feet (Meters)			
	UNIT SIZE BTU/HR (kW)			
	30,000 (8.8)	45,000 (13.2)	60,000 (17.6)	75,000 (22.0)
8 (2.4)	Data Not Available			
10 (3.0)	Data Not Available			
12 (3.7)	Data Not Available			
15 (4.6)	Data Not Available			
20 (6.1)	Data Not Available			
	UNIT SIZE BTU/HR (kW)			
	90,000 (26.4)	100,000 (29.3)	105,000 (30.8)	120,000 (34.2)
8 (2.4)	Data Not Available	65 (19.8)	Data Not Available	Data Not Available
10 (3.0)	Data Not Available	57 (17.4)	Data Not Available	Data Not Available
12 (3.7)	Data Not Available	50 (15.2)	Data Not Available	Data Not Available
15 (4.6)	Data Not Available	NR	Data Not Available	Data Not Available
20 (6.1)	Data Not Available	NR	Data Not Available	Data Not Available
	UNIT SIZE BTU/HR (kW)			
	125,000 (36.6)	150,000 (43.9)	175,000 (51.2)	200,000 (58.6)
8 (2.4)	70 (21.3)	75 (22.9)	80 (24.4)	85 (25.9)
10 (3.0)	60 (18.3)	64 (19.5)	68 (20.7)	72 (21.9)
12 (3.7)	54 (16.5)	57 (17.4)	60 (18.3)	64 (19.5)
15 (4.6)	45 (13.7)	48 (14.6)	50 (15.2)	53 (16.2)
20 (6.1)	NR	NR	44 (13.4)	47 (14.3)
	UNIT SIZE BTU/HR (kW)			
	250,000 (73.2)	300,000 (87.8)	350,000 (102.5)	400,000 (117.1)
8 (2.4)	95 (29.0)	115 (35.1)	120 (36.6)	125 (38.1)
10 (3.0)	86 (26.2)	99 (30.2)	105 (32.0)	110 (33.5)
12 (3.7)	77 (23.5)	88 (26.8)	94 (28.7)	100 (30.5)
15 (4.6)	64 (19.5)	74 (22.6)	79 (24.1)	84 (25.6)
20 (6.1)	58 (17.7)	66 (20.1)	71 (21.6)	75 (22.9)

Heat Throw Data

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

60° NOZZLE

Distance From Floor to Bottom of Unit "H" Ft. (m)	Approximate Distance of Heat Throw - Feet (Meters)			
	UNIT SIZE BTU/HR (kW)			
	30,000 (8.8)	45,000 (13.2)	60,000 (17.6)	75,000 (22.0)
8 (2.4)	Data Not Available			
10 (3.0)	Data Not Available			
12 (3.7)	Data Not Available			
15 (4.6)	Data Not Available			
20 (6.1)	Data Not Available			
	UNIT SIZE BTU/HR (kW)			
	90,000 (26.4)	100,000 (29.3)	105,000 (30.8)	120,000 (34.2)
8 (2.4)	Data Not Available	75 (22.9)	Data Not Available	Data Not Available
10 (3.0)	Data Not Available	65 (19.8)	Data Not Available	Data Not Available
12 (3.7)	Data Not Available	60 (18.3)	Data Not Available	Data Not Available
15 (4.6)	Data Not Available	50 (15.2)	Data Not Available	Data Not Available
20 (6.1)	Data Not Available	NR	Data Not Available	Data Not Available
	UNIT SIZE BTU/HR (kW)			
	125,000 (36.6)	150,000 (43.9)	175,000 (51.2)	200,000 (58.6)
8 (2.4)	80 (24.4)	85 (25.9)	90 (27.4)	95 (29.0)
10 (3.0)	70 (21.3)	75 (22.9)	79 (24.1)	83 (25.3)
12 (3.7)	64 (19.5)	68 (20.7)	72 (21.9)	76 (23.2)
15 (4.6)	54 (16.5)	56 (17.1)	61 (18.6)	65 (19.8)
20 (6.1)	49 (14.9)	52 (15.8)	55 (16.8)	59 (18.0)
	UNIT SIZE BTU/HR (kW)			
	250,000 (73.2)	300,000 (87.8)	350,000 (102.5)	400,000 (117.1)
8 (2.4)	110 (33.5)	125 (38.1)	130 (39.6)	138 (42.1)
10 (3.0)	95 (29.0)	109 (33.2)	115 (35.1)	120 (36.6)
12 (3.7)	84 (25.6)	100 (30.5)	103 (31.4)	108 (32.9)
15 (4.6)	71 (21.6)	85 (25.9)	88 (26.8)	94 (28.7)
20 (6.1)	65 (19.8)	77 (23.5)	81 (24.7)	85 (25.9)

90° NOZZLE*

Distance From Floor to Bottom of Unit "H" Ft. (m)	Approximate Distance of Heat Throw - Feet (Meters)		
	UNIT SIZE BTU/HR (kW)		
	100,000 (29.3)	125,000 (36.6)	150,000 (43.9)
10 (3.0)	NR	NR	NR
15 (4.6)	30 x 25 (9.1) x (7.6)	35 x 30 (10.7) x (9.1)	40 x 35 (12.2) x (10.7)
20 (6.1)	NR	NR	NR
25 (7.6)	NR	NR	NR
30 (9.1)	NR	NR	NR
	UNIT SIZE BTU/HR (kW)		
	175,000 (51.2)	200,000 (58.6)	250,000 (73.2)
10 (3.0)	NR	NR	NR
15 (4.6)	45 x 40 (13.7) x (12.2)	50 x 40 (15.2) x (12.2)	60 x 45 (18.3) x (13.7)
20 (6.1)	NR	40 x 35 (12.2) x (10.7)	56 x 40 (17.1) x (12.2)
25 (7.6)	NR	NR	50 x 35 (15.2) x (10.7)
30 (9.1)	NR	NR	NR
	UNIT SIZE BTU/HR (kW)		
	300,000 (87.8)	350,000 (102.5)	400,000 (117.1)
10 (3.0)	NR	NR	NR
15 (4.6)	70 x 45 (21.3) x (13.7)	80 x 50 (24.4) x (15.2)	100 x 50 (30.5) x (15.2)
20 (6.1)	65 x 40 (19.8) x (12.2)	70 x 45 (21.3) x (13.7)	80 x 45 (24.4) x (13.7)
25 (7.6)	60 x 35 (18.3) x (10.7)	65 x 40 (19.8) x (12.2)	75 x 40 (22.9) x (12.2)
30 (9.1)	55 x 35 (16.8) x (10.7)	60 x 35 (18.3) x (10.7)	65 x 40 (19.8) x (12.2)

*It is not recommended to mount a unit with a 90° nozzle at 10 feet or less.
Heat Throw data for GG Series units with a 90° nozzle installed is not currently available.

Nozzle Dimensions*

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

30º NOZZLE

60º NOZZLE

90º NOZZLE

*Nozzles are field assembled.

NOZZLE DIMENSIONAL DATA CHART

DIMENSION	NOZZLE TYPE	30, 45	60, 75	90, 105, 120	100, 125, 150	175, 200, 250	300, 350, 400
WIDTH A In. (mm)	30º	19-5/8 (498)	19-5/8 (498)	19-5/8 (498)	20-3/4 (527)	32-3/4 (832)	50-3/4 (1289)
	60º	19-5/8 (498)	19-5/8 (498)	19-5/8 (498)	20-3/4 (527)	32-3/4 (832)	50-3/4 (1289)
	90º	19-5/8 (498)	19-5/8 (498)	19-5/8 (498)	20-3/4 (527)	32-3/4 (832)	50-3/4 (1289)
HEIGHT B In. (mm)	30º	12-1/16 (306)	15-5/8 (397)	22-3/8 (568)	31-1/2 (800)	31-1/2 (800)	31-1/2 (800)
	60º	12-1/16 (306)	15-5/8 (397)	22-3/8 (568)	31-1/2 (800)	31-1/2 (800)	31-1/2 (800)
	90º	12-1/16 (306)	15-5/8 (397)	22-3/8 (568)	31-1/2 (800)	31-1/2 (800)	31-1/2 (800)
FURTHEST DEPTH C In. (mm)	30º	13-1/8 (333)	13-1/8 (333)	13-1/8 (333)	15 (381)	15 (381)	15 (381)
	60º	22-3/16 (564)	22-3/16 (564)	22-3/16 (564)	25-1/2 (648)	25-1/2 (648)	25-1/2 (648)
	90º	25-9/16 (694)	25-9/16 (694)	25-9/16 (694)	28-1/4 (718)	28-1/4 (718)	28-1/4 (718)
HEIGHT WITH OVERHANG D In. (mm)	30º	N/A					
	60º	13-5/16 (338)	16-7/8 (429)	23-5/8 (600)	30 (762)	30 (762)	30 (762)
	90º	15-1/4 (387)	18-13/16 (478)	25-9/16 (649)	34 (864)	34 (864)	34 (864)

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

GG Series Typical Standard Specification

Furnish and install, where indicated or scheduled on plans, gas-fired unit heaters manufactured by Sterling HVAC. All heaters are to have a minimum thermal efficiency of 82%. The heat exchanger consists of aluminized steel tubes not lighter than 20-gauge. Burner system is to be of the "single-orifice burner" design. A direct spark ignition system with integrated control and redundant gas valve shall be utilized. Flame rectification shall be independent of the spark igniter, allowing true indication of complete ignition of the burner. Most cabinetry and trim pieces shall be fabricated of 20-gauge material, and finished with a baked gray enamel.

Separated combustion style units must utilize clean air from the outside of the structure for combustion purposes. A concentric type adapter must be used at the point of building termination. This adapter will allow for the outside air to enter and combustion flue gases exit through one opening.

Heaters shall be equipped with a 120/24 volt transformer; factory wiring shall permit the use of propeller fan for continuous air circulation when combined with manufacturers (optional) 24 volt summer/winter single stage thermostat. The control transformer and pressure switch shall be factory mounted in a main control cabinet located on the side of the unit; the side panel is removed to create easy access and all wiring information will be indicated on the inside control cabinet.

Units will be equipped with a low voltage automatic reset high temperature control, wired to de-energize the main gas valve and maintain fan operation until the high temperature control resets. Units will be equipped with 120/1/60 volt motors which include internal automatic reset thermal overload protection. Fans will be hubbed with aluminum blades and have OSHA-approved fan guard protection. Adjustable and individually removable horizontal louver blades shall be provided for directing air flow.

All units and component assemblies shall be warranted for a period of one year from the date of shipment from the factory or 18 months from the date of manufacture, whichever occurs first. All burners, heat exchangers, and flue collectors shall carry a ten year non-prorated limited warranty on materials and workmanship (subject to appropriate disclaimers).

Series Typical Standard Specification

Furnish and install, where indicated or scheduled on plans, gas-fired unit heaters manufactured by Sterling HVAC. All heaters are to have a minimum thermal efficiency of 83%. The heat exchanger consists of aluminized steel tubes not lighter than 20-gauge. Burners are to be of the "in-shot" design. A direct spark ignition system with integrated control and redundant gas valve shall be utilized. Flame rectification shall be independent of the spark igniter allowing true indication of complete ignition of the burner. Most cabinetry and trim pieces shall be fabricated of 20-gauge material and finished with a baked gray enamel.

All line voltage wiring shall be completely enclosed in flexible conduit. Heaters shall be equipped with a 120/24 volt controls transformer. Factory wiring shall permit the use of propeller fan on TF units and blower on TC units, for continuous air circulation when combined with manufacturer's (optional) 24-volt summer/winter single stage thermostat. The control transformer and pressure switch shall be factory mounted in a main control panel located on the side of the unit; this panel creates easy access and all wiring information will be indicated on the inside control panel door.

Units will be equipped with a low voltage automatic reset high temperature control, wired to de-energize the main gas valve and maintain fan or blower operation until the high temperature control resets. Units will be equipped with 120/1/60 volt motors, which include internal automatic reset thermal overload protection. TF unit fans will be hubbed with aluminum blades and have fan guard protection. TF units with inputs greater than 250,000's BTU's shall be equipped with dual motors and fan blades for optimum air distribution. TC units shall have centrifugal blowers with an OSHA-type belt guard. TC units with inputs greater than 250,000 BTU's shall be equipped with dual blowers on a single shaft for optimum air distribution. Adjustable and individually removable horizontal louver blades shall be provided on all units for directing air flow.

All units and component assemblies shall be warranted for a period of one year from the date of shipment from the factory or 18 months from the date of manufacture, whichever occurs first. All burners, heat exchangers, and flue collectors shall carry a ten year non-prorated limited warranty on materials and workmanship (subject to appropriate disclaimers).

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

SF/SC Series Typical Standard Specification

Furnish and install, where indicated or scheduled on plans, gas-fired unit heaters manufactured by Sterling HVAC. All heaters to be designed to separate the combustion process from the environment where the units are installed; the burners, igniter and flue system will be enclosed within the unit and a power venting system will both draw in combustion air from outside the space and exhaust flue gas products to the outside. All heaters are to have a minimum thermal efficiency of 83%. The heat exchanger consists of aluminized steel tubes not lighter than 20-gauge. Burners are to be of the "in-shot" design. A direct spark ignition system with integrated control and redundant gas valve shall be utilized. Flame rectification shall be independent of the spark igniter allowing true indication of complete ignition of the burner. Most cabinetry and trim pieces shall be fabricated of 20-gauge material and finished with baked gray enamel.

All line voltage wiring shall be completely enclosed in flexible conduit. Heaters shall be equipped with a 120/24 volt controls transformer. Factory wiring shall permit the use of propeller fan on SF units and blower on SC units for continuous air circulation when combined with manufacturer's (optional) 24-volt summer/winter single stage thermostat. The control transformer and pressure switch shall be factory mounted in a main control panel located on the side of the unit; this panel creates easy access and all wiring information will be indicated on the inside control panel door.

Units will be equipped with a low voltage automatic reset high temperature control, wired to de-energize the main gas valve and maintain fan or blower operation until the high temperature control resets. Units will be equipped with 120/1/60 volt motors, which include internal automatic reset thermal overload protection. SF unit fans will be hubbed with aluminum blades and have fan guard protection. SF units with inputs greater than 250,000 BTU's shall be equipped with dual motors and fan blades on a single shaft for optimum air distribution. SC units shall have centrifugal blowers with an OSHA-type belt guard. SC units with inputs greater than 250,000 BTU's shall be equipped with dual blowers on a single shaft for optimum air distribution. Adjustable and individually removable horizontal louver blades shall be provided on all units for directing air flow.

Units to be vented horizontally or vertically via standard two-pipe configuration. When necessary to vent concentrically through one wall or roof penetration, an optional combustion air inlet kit will be made available.

All units and component assemblies shall be warranted for a period of one year from the date of shipment from the factory or 18 months from the date of manufacture, whichever occurs first. All burners, heat exchangers, and flue collectors shall carry a ten year non-prorated limited warranty on materials and workmanship (subject to appropriate disclaimers).

QVES/QVSD Series Standard ation

Furnish and install where shown on plans, gas-fired duct furnaces as made by Sterling HVAC. Duct furnaces must have ETL certification for use downstream (cold air side) of a cooling coil and must be constructed of ETL defined corrosion resistant material with a built-in flue collector. Burners shall be pressed aluminized steel or 409 stainless steel, and shall have stainless steel port protectors. Heat exchangers shall be aluminized steel, 409 stainless steel or 321 stainless steel. Tubes shall not be lighter than 20-gauge. Headers shall not be lighter than 18-gauge. Furnaces to be of neat appearance and good workmanship. All units and components are to be warranted (subject to appropriate disclaimers) from defects in material and workmanship for a period of one year from date of shipment from the factory.

All sizes have exceptionally low pressure drop, making it possible to handle large volumes of air without using an axillary by-pass. Sterling duct furnaces are tested to operate against 2.0 inches water column pressure.

All models are equipped with electronic spark ignition (100% safety shutoff on LP models), 115 volt power venter, vent system pressure switch, high limit switch, fan time delay and 24 volt control transformer.

Indoor Duct Furnaces are completely factory assembled, piped, wired and test fired. All models are ETL certified and approved by these agencies for installation downstream (cold air side) of direct expansion air conditioning coils (stainless steel heat exchanger recommended). All models conform to the latest ANSI Standards for safe and efficient performance. Units are provided with a four-point suspension system and are available for operation on either natural or LP gas.

Casings are die-formed 20-gauge bonderized steel, finished in baked enamel. Heat exchangers are available in aluminized steel, type 409 stainless steel and type 321 stainless steel. Burners are individually removable, die formed and feature stainless steel port protectors. Burners are accessible through a removable, bottom panel.

All models are equipped with a 24 volt control system, which is powered by a factory installed 115/24 volt transformer, Electronic Spark Ignition and Integral Power Venting with a sealed flue collector.

CAB Series Typical Standard Specification

Cabinet blowers shall be as made by Sterling HVAC consisting of a 20-gauge aluminized steel cabinet, with removable side panels, centrifugal fan, motor and filters. Motor and drive shall be furnished by the factory and shipped fully mounted so that field mounting is not required. Motor pulley shall be adjustable as to pitch diameter. When a cabinet blower-duct furnace combination is required, the manufacturer shall furnish the standard cataloged duct transition piece. Furnaces shall be of neat appearance and good workmanship. All units and components are to be warranted (subject to appropriate disclaimers) from defects in materials and workmanship for a period of one year from the date of shipment from the factory.

Tubular Unit Heater

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

LIMITED WARRANTY

1. **SERIES GG, TF, TC, SF AND SC**
   Sterling ("the Manufacturer") warrants to th
   at original installation site that the above models of Sterling Gas–Fired Heaters ("the Product") will be free from defects in material or workmanship for one (1) year from the date of shipment from the factory, or one and one–half (1-1/2) years from the date of manufacture, whichever occurs first. Sterling further warrants that the complete heat exchanger, flue collector, and burners will be free from defects in material or workmanship for a period of ten (10) years from the date of manufacture. If upon examination by the Manufacturer the Product is shown to have a defect in material or workmanship during the warranty period, the Manufacturer will repair or replace, at its option, that part of the Product which is shown to be defective.
2. This limited warranty does not apply:
   (a) if the Product has been subjected to misuse or neglect, has been accidentally or intentionally damaged, has not been installed, maintained or operated in accordance with the furnished written instructions, or has been altered or modified in any way by any unauthorized person.
   (b) to any expenses, including labor or material, incurred during removal or reinstallation of the Product.
   (c) to any damage due to corrosion by chemicals, including halogenated hydrocarbons, precipitated in the air.
   (d) to any workmanship of the installer of the Product.

d warranty is conditional upon:
ing the installing contractor, who will in turn notify the distributor or manufacturer.
(b) shipment to the Manufacturer of that part of the Product thought to be defective. Goods can only be returned with prior written approval of the Manufacturer. All returns must be freight prepaid.
(c) determination in the reasonable opinion of the Manufacturer that there exists a defect in material or workmanship.

4. Repair or replacement of any part under this Limited Warranty shall not extend the duration of the warranty with respect to such repaired or replaced part beyond the stated warranty period.
5. **THIS LIMITED WARRANTY IS IN LIEU OF ALL OTHER WARRANTIES, EITHER EXPRESS OR IMPLIED, AND ALL SUCH OTHER WARRANTIES, INCLUDING WITHOUT LIMITATION IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, ARE HEREBY DISCLAIMED AND EXCLUDED FROM THIS LIMITED WARRANTY. IN NO EVENT SHALL THE MANUFACTURER BE LIABLE IN ANY WAY FOR ANY CONSEQUENTIAL, SPECIAL, OR INCIDENTAL DAMAGES OF ANY NATURE WHATSOEVER, OR FOR ANY AMOUNTS IN EXCESS OF THE SELLING PRICE OF THE PRODUCT OR ANY PARTS THEREOF FOUND TO BE DEFECTIVE. THIS LIMITED WARRANTY GIVES THE ORIGINAL OWNER OF THE PRODUCT SPECIFIC LEGAL RIGHTS. YOU MAY ALSO HAVE OTHER RIGHTS WHICH MAY VARY BY EACH JURISDICTION.**

Duct Furnaces, Cabinet Blowers

1 YEAR LIMITED WARRANTY UNIT TYPE QVES, QVED, QVSD, CAB 1-4

Duct Furnaces, Separated Combustion Unit Heaters and Cabinet Blowers are warranted by Sterling to be free from defects in materials and workmanship for a period of one (1) year from date of shipment from Sterling's Plant.

Sterling will repair or replace, at its option, any components which, upon inspection, it finds to be defective, provided that the unit has been operated within its listed capacity, has been installed in accordance with the furnished instructions, has not been misused or subject to negligence and has received reasonable and necessary maintenance.

This warranty does not cover loss due to corrosion by chemicals precipitated in the air such as halogenated hydrocarbons.

Sterling will in no event be liable for incidental or consequential damages of any kind whatsoever.

Written permission is required prior to the return of defective components. All returns must be sent with all transportation charges prepaid to the plant designated in the written permission.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 11/04/13

STERLING®
HVAC PRODUCTS
260 NORTH ELM ST. WESTFIELD, MA 01085
(413) 564-5540 • FAX: (413) 562-5311
www.sterlinghvac.com
A MESTEK COMPANY