

Page 2 Application - 254 Commercial S1

Grease Gutters provided? Yes

Hood Clearance reduction to Combustibles design /specs:

Duct Clearance reduction to Combustibles design /specs:

Vibration Isolation System:

Air Velocity within the duct system 2000 FPM

Grease accumulation prevention system:

Yes -

Cleanouts None

Grease Duct enclosure _____

Exhaust Termination Roof _____ Wall X

Fire Suppression System Yes

Exhaust fan mounting and clearance from the roof / wall or Combustibles:

Exhaust fan distance from property lines 15'

Exhaust fan distance from other vents or openings min. 10'

Exhaust fan distance from adjacent buildings _____

Exhaust fan height above adjoining grade min. 10'

Hood Specs

Style of Hood Capture Air Box Style

Type of Filter baffle

Height of filter above nearest cooking surface min 48"

Capacity of hood CFM 2900 CFM

Make up Air system description and capacity

50% Make up air (2250 CFM) Heated Make up
air ~~over~~ Direct Fired Fan with Front Perforated
Supply Plenum.