



172' - 0"

REMOVEDNESS OF EXITS = 1/3 MAX. DIAGONAL DIMENSION OF THE BUILDING = 122' MINIMUM SEPARATION

LEGEND

- FIRE EXIT STAIR
- 2 HR. RATED PARTITION
- DEAD END CORRIDOR (50' MAX ALLOWED)
- COMMON PATH TO EXIT (100' MAX ALLOWED)
- PRIMARY EXIT PATH
- FIRE EXTINGUISHER LOCATION (REQUIRED EVERY 75' & AT STAIRS)

CODE PLAN PREPARED BY:

Winton Scott Architects
 5 Milk Street, Portland, ME 04101
 207.774.4811 www.wintonscott.com



PROJECT
PIERCE ATWOOD
 WATERFRONT
 PORTLAND, MAINE

NO.	DATE	REVISION

TITLE
**5TH FLOOR
 CODE PLAN**
 SCALE: 1/8"=1'-0"
 DATE: 07/27/10 PROJECT NO: 2010JAS3
 DRAWN: AD CHK: SN

DRAWING NO.

A-1.5