


1 PARTIAL SECOND FLOOR PLAN
SCALE: 1/4" = 1'-0"



AHU-223: MITSUBISHI MSZ-GEI2NA WALL MOUNTED AIR HANDLING UNIT. 12,000 BTU NOMINAL COOLING & 8,800 BTU HEATING (AT 17°F. OUTDOORS). 0.76 FAN P.L.A. & 1 AMP M.C.A. 344 MAXIMUM CFM, 208/230V - 60 HZ - 1Ø PROVIDE PAR-ZIMAA WIRED CONTROLLER.

OU-21: MITSUBISHI MUZ-GEI2NA 12A M.C.A. 208/230V - 60 HZ - 1Ø POWER SYSTEM POWER. 960 WATTS COOLING (20.5 SEER) AND 1,200 WATTS HEATING.

2 PARTIAL BASEMENT FLOOR PLAN
SCALE: 1/4" = 1'-0"



MECHANICAL SYSTEMS ENGINEERS
ROYAL RIVER CENTER, UNIT #10
10 FOREST FALLS DRIVE
YARMOUTH, MAINE 04096
(207) 846-1441

© COPYRIGHT 2011 M.S.E. Proj. 1121

COMPASS HEALTH Tenant Fit up

Merrill's Wharf, Portland, Maine

Winton Scott Architects
5 Milk St. Portland, ME 04101
207.774.6680 | wintonsscott.com

Mechanical Systems Engineers
Royal River Center #10
10 Forest Falls Dr., Yarmouth, ME 04096
207.846.1441 |

Bartlett Design
942 Washington St., Bath, ME 04530
207.443.5447 |
bartlettdesigninc@comcast.net

SCALE: 1/4" = 1'-0"

ADDITION OF
AHU-223
& OU-21

M1.3

AUGUST 01, 2011