PAUL R. LEPAGE GOVERNOR

STATE OF MAINE DEPARTMENT OF ENVIRONMENTAL PROTECTION



March 3, 2016

Irving Oil Marketing 190 Commerce Way Portsmouth, NH 03801 Attn: Jessica Bullock

RE: Irving Mainway

Dear Ms. Bullock:

This letter is to acknowledge the Department's receipt of your registration materials on March 2, 2016 for either a new tank and piping or the replacement of ancillary equipment at the, Irving Mainway, Portland, Maine. Maine Statute dictates that the installation may take place ten (10) business days following Department notification (38 M.R.S.A., Section 563 1. A.). This installation may begin on March 17, 2016. Have a copy of your registration and display this letter in a prominent place during the construction or replacement activities.

NOTE: Please note it is the owners responsibility to ensure that the installer complete and submit the Certification of Proper Installation to the Department within thirty (30) days of completing the project (Chapter 691, Section 5 B. (4) (g).

Additionally, please remember that if the equipment at a facility changes, or the leak detection method changes, any A/B Operators for the facility are required to become recertified using the Department's "TankSmart" operator training program. This should be done within 30 days of receiving a new replacement facility registration form indicating that the above approved work has been performed.

If you have any questions or concerns, I can be reached at (207) 287-2651.

Sincerely,

John M Dunlap Division of Oil and Hazardous Waste Facilities Regulation Bureau of Remediation and Waste Management

PC Paul Thompson # 289