



NOTE:
 1. SEE SHEET M-001 FOR LEGEND AND ABBREVIATIONS.

KEYED NOTES:

- ① RG-4 (2500 CFM) MOUNTED 24" WIDE & 36" TOP-TO-BOTTOM WITH TOP AT 12" BELOW CEILING.
- ② RG-2 (2 EACH) CONNECTED BY A 10x10 LD (250 CFM).
- ③ SG-1 (250 CFM) - ONE ON EACH SIDE OF DUCT.
- ④ IF THE INSTALLATION OF A HOOD IS DEFERRED, INSTALL ONE RG-8 CONNECTED TO THE EXHAUST DUCT WITH A 10" BALANCE FOR 1100 CFM.
- ⑤ 4" SCHEDULE 40 PVC PIPE TIGHT TO WALL UP FROM UNDERSLAB VENTING SYSTEM - TYPICAL 4 PLACES.
- ⑥ INSTALL INLINE FAN (EF-5) @ 5' AFF.

0	ISSUED FOR CONSTRUCTION	10-23-03
REV.	DESCRIPTION	DATE

ISSUED FOR CONSTRUCTION
10-23-03

CURRENT ISSUE STATUS:

PROJECT NORTH

DAVID B. REINHEIMER
 #2521
 ARCHITECTURE ENGINEERING PLANNING

SM RT

ARCHITECTURE ENGINEERING PLANNING

SMRT
 144 Fore Street P.O. Box 618
 Portland, Maine 04104
 tel. (207) 772-3846
 fax. (207) 772-1070

THE GULF OF MAINE RESEARCH INSTITUTE
 PORTLAND, MAINE

FIRST FLOOR HVAC PLAN

SHEET TITLE:	FIRST FLOOR HVAC PLAN	
SCALE:	1/8" = 1'-0"	DATE: 10-23-03
PROJECT MANAGER:	DRL	GRAPHIC SCALE: 0" = 1'
JOB CAP/DRAWN:	SDL/CAH	
A/E OF RECORD:	DBR	SHEET No.
SMRT CAD FILE:	MH101-03034	MH101
PROJECT No.	03034	

A1 FLOOR PLAN

1/8" = 1'-0"