



**NOTES:**

- SEE SHEET M-001 FOR LEGEND AND ABBREVIATIONS.
- UNLESS OTHERWISE NOTED PIPING IS 3/4" IPS.

**KEYED NOTES:**

- 1-1/4" HWS & HWR - VALVE & CAP FOR FUTURE CONNECTION TO SALTWATER TEMPERING EQUIPMENT.
- EACH CU IS PIPED SEPARATELY TO ITS CIRCUIT IN THE COOLING COIL. REFRIGERANT PIPING SIZE PER MANUFACTURER RECOMMENDATIONS.

REV.	DESCRIPTION	DATE
0	ISSUED FOR CONSTRUCTION	10-23-03

**ISSUED FOR CONSTRUCTION**  
10-23-03

PROJECT NORTH

DAVID B. RENNER  
PROFESSIONAL ENGINEER  
STATE OF MAINE  
LICENSE NO. 1051

**SMRT** ARCHITECTURE ENGINEERING PLANNING  
SMRT  
144 Fore Street, P.O. Box 618  
Portland, Maine 04104  
tel. (207) 772-3846  
fax. (207) 772-1070

**THE GULF OF MAINE RESEARCH INSTITUTE**  
PORTLAND, MAINE

PROJECT: **MEZZANINE HVAC PIPING PLAN**

SHEET TITLE: **MEZZANINE HVAC PIPING PLAN**  
SCALE: 1/8" = 1'-0" DATE: 10-23-03  
PROJECT MANAGER: DRL GRAPHIC SCALE: 0" 1"  
JOB CAP/DRAWN: SOL/CAH  
A/E OF RECORD: DBR SHEET No.  
SMRT CAD FILE: MP104-03034  
PROJECT No. 03034 **MP104**

A1 FLOOR PLAN  
1/8" = 1'-0"