



- NOTES:**
- SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.
 - PROVIDE RIGID GALVANIZED STEEL RISER CONDUITS TO A MINIMUM 8" AFG. PROVIDE STAND-OFF BRACKETS AS REQUIRED. COORDINATE RISER POLE AND CONDUIT INSTALLATION WITH UTILITY AND UTILITY REQUIREMENTS.
 - REFER TO STRUCTURAL DRAWINGS FOR GRADE BEAM LOCATIONS AND PENETRATIONS.

KEYED NOTE:

(1) PROVIDE METER PEDESTAL IN ACCORDANCE WITH UTILITY COMPANY REQUIREMENTS. PROVIDE A 3/4" CONDUIT BETWEEN METER PEDESTAL AND UTILITY POLE FOR REMOTE REVENUE METERING CAPABILITY AND PROVIDE A 1-1/4" CONDUIT BETWEEN METER PEDESTAL AND PRIMARY METERING STATION FOR METERING INSTRUMENT WIRES.

REV.	DESCRIPTION	DATE
0	ISSUED FOR CONSTRUCTION	10-23-03

ISSUED FOR CONSTRUCTION
10-23-03

CURRENT ISSUE STATUS:

SMRT ARCHITECTURE ENGINEERING PLANNING
SMRT
144 Fore Street/P.O. Box 618
Portland, Maine 04104
tel. (207) 772-3846
fax. (207) 772-1070

THE GULF OF MAINE RESEARCH INSTITUTE
PORTLAND, MAINE

SITE POWER PLAN

SHEET TITLE:	1" = 20'	DATE:	10-23-03
PROJECT MANAGER:	DRL	GRAPHIC SCALE:	0" = 1"
JOB CAP/DRAWN:	LAM/JAC	SHEET No.	ES102
A/E OF RECORD:	JPP	PROJECT No.	03034
SMRT CAD FILE:	ES102-03034		
PROJECT No.	03034		

A1 SITE PLAN
1" = 20'