


**NOTE:**  
 1. SEE SHEET E-001 FOR LEGEND AND GENERAL NOTES.

**KEYED NOTES:**  
 ① UPON FIRE ALARM INITIATION, ROOF HATCH MOTOR SHALL ENERGIZE ALLOWING HATCH TO OPEN. PROVIDE 120V RATED CONTACT FROM FIRE ALARM PANEL.

REV.	DESCRIPTION	DATE
0	ISSUED FOR CONSTRUCTION	10-23-03

**ISSUED FOR CONSTRUCTION**  
**10-23-03**



**SMRT**  
 ARCHITECTURE ENGINEERING PLANNING  
 144 Fore Street P.O. Box 618  
 Portland, Maine 04104  
 tel. (207) 772-3846  
 fax. (207) 772-1070

PROJECT: **THE GULF OF MAINE RESEARCH INSTITUTE**  
 PORTLAND, MAINE

SHEET TITLE: **MEZZANINE FLOOR SYSTEMS PLAN**

SCALE: 1/8" = 1'-0" DATE: 10-23-03

PROJECT MANAGER: DRL GRAPHIC SCALE: 0" 1"

JOB CAP/DRAWN: SDL/LAM

A/E OF RECORD: JPP SHEET No. EY104

SMRT CAD FILE: EY104-03034 PROJECT No. 03034

A1 MEZZANINE FLOOR PLAN

1/8" = 1'-0"