

•
•
•
•
•
•
•

389 Congress St.Rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal


To: David Lay **From:** Mike Nugent

Fax: 772-1070 **Date:** December 22, 2003

Phone: 772-3846 **Pages:** 1

Re: 340 Commercial St.

Urgent For Review Please Comment Please Reply Please Recycle



I have reviewed the submissions for Permit #031067 and have the following questions/comments:

- 1) I need a dimensional detail for the alternating tread stair that shows treads risers width, headroom and guards, please look at Section 1014.6.6 and 1022.0.
- 2) How are you classifying the use group of the 4th floor (I assume you are using the openings in guard option in Secion 1021.3)?
- 3) The guards are removable in a portion of this area, I'd like to talk about this from an operations standpoint.
- 4) The handrail in fig. E5 on page AE402 is 32", (must be 34")
- 5) Need specs on the smoke removal system specs for the atrium.

• • • • •