CITY OF PORTLAND FIRE PREVENTION BUREAU

380 Congress Street, Portland, Maine 04101 fireprevention@portlandmaine.gov (207) 874-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

July 6, 2017

Responsible Party 1:				
BERLIN MILLS WHARF				
PO BOX 3542				
PORTLAND, ME 04104				
Location	CBL	Inspection Date		
Location 400 COMMERCIAL ST	CBL 042 E001001	Inspection Date 6/12/2017		
		=		

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 7/30/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 101- 9.1.2 IMPROPER WIRING, NOT TO CODE ; Electrical wiring and equipment shall be in accordance with NFPA 70, unless such installations are approved existing installations, which shall be permitted to be continued in service.	
The pier section and associated boat yard buildings of this property have multiple electric code violations. Non weatherproof electrical installations used outside. Improper GFCI protection as required, Broken and/or missing covers. Broken PVC conduit with wires exposed. Extension cords in permanent use. Exposed electrical componants and wiring.	
NFPA 101- 9.1.2 CERTIFY ELECTRICAL SYSTEM ; Electrical wiring and equipment shall be in accordance with NFPA 70, unless such installations are approved existing installations, which shall be permitted to be continued in service.	
It is clear that electrical wiring was not installed by a licensed Master electrician as is required for all commercial properties. Have a Master Electrician make repairs and certify all electrical for this property.	
NFPA 10- 7.2.4.4 FIRE EXTINGUISHER INSPECTION TAG; Where manual inspections are conducted, records for manual inspections shall be kept on a tag or label attached to the fire extinguisher, on an inspection checklist maintained on file, or by an electronic method. All extinguishers must have current inspection tag	
NFPA 101- 9.7.4.1 FIRE EXTINGUISHERS REQ- OTHER; Where required by the provisions of another section of this code, portable fire extinguishers shall be installed, inspected, and maintained in accordance with NFPA 10, Standard for Portable Fire Extinguishers. There are no extinguishers readily available in the yard area where boats are being worked on. (Cutting, welding, grinding, painting, ect)	

Violation		Proposed Date of Completion
FINAL DATE OF COMPLETE	D VIOLATION(S)	· / / /
FIRE PREVENTION BUREAU	RE-INSPECTION OF COMPLETED VIOLATION(S)	//
	t to reject or modify any proposed plan of action, and may nical capacity to complete the proposed plan. Please contact TION	-
understand that I must conta	ons listed within the timeframes provided. If I require add act the Fire Prevention Bureau <u>prior to the deadline</u> to requ's discretion to grant or deny.	
v	is my responsibility to schedule a reinspection of my prope . My failure to schedule a reinspection shall be deemed an nedied.	•
	greement, I understand that I am liable for penalties pursurs $\{s, s, s, 1-15\}$ and 10-25, and 30-A M.R.S. $\{s, s, s$	
Date	Responsible Party	
Date	Responsible Party	
SEEN AND AGREED		

Fire Prevention Bureau

Date