

<b>OBSERVATION REPORT</b>
Rough Carpentry

<b>Date:</b>	2/23/12
<b>Time:</b>	1:00PM
<b>Temp:</b>	45
<b>Weather:</b>	Cloudy

<b>Project:</b>	International Marine Terminal (Office Building)
<b>Location:</b>	Portland, ME
<b>Becker Job No:</b>	2402.01

**Observation Location:** Holddowns at shear walls.

	Satisfactory	Un-Satisfactory	Not Completed	Not Applicable	Comments
Member Sizes	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Correct holddown.
Material Quality	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Bearing Condition	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Connections	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Holddowns properly installed.
Nailing Pattern	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Bridging/Bracing	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Other:	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	(1) Holddown damaged. A 2nd Holddown to be installed in adjacent stud bay.
Other:	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

**Notes:**

**Signed:** Ben Van Deventer, E.I.