

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND

# BUILDING PERMIT

This is to certify that **HIGH TECH FIRE PROTECTION**  
of **PO Box 156, Minot, ME 04258**

For installation at **454 COMMERCIAL ST**  
**IMT Office Building**


Job ID: **2011-12-2924-FAFS**

CBL: **043- D-005-001**

has permission to install supervised, automatic sprinkler system  
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be

  
Fire Prevention Officer

Code Enforcement Officer / Plan Reviewer

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
PENALTY FOR REMOVING THIS CARD**



# PORTLAND MAINE

*Strengthening a Remarkable City, Building a Community for Life • [www.portlandmaine.gov](http://www.portlandmaine.gov)*

Director of Planning and Urban Development  
Penny St. Louis

**Job ID: 2011-12-2924-FAFS**  
**install supervised, automatic sprinkler**  
**system**

**For installation at:**  
**454 COMMERCIAL ST**  
**IMT Office Building**

**CBL: 043- D-005-001**

## **Conditions of Approval:**

### **Fire**

The sprinkler system shall be installed in accordance with NFPA 13.

A separate sprinkler permit is required from the State Fire Marshal's Office.

Sprinkler supervision shall be provided in accordance with NFPA 101, *Life Safety Code*, and NFPA 72, *National Fire Alarm and Signaling Code*.

Sprinkler protection shall be maintained. Where the system is to be shut down for maintenance or repair, the system shall be checked at the end of each day to insure the system has been placed back in service.

Fire department connection shall be a single 2 1/2" per 13:6.8.1.3 with a Knox locking cap.

System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.

Installation of a sprinkler or fire alarm system requires a Knox Box to be installed per city ordinance.

Private fire mains and fire hydrants shall be maintained, tested and painted in accordance with NFPA 25 and City Code Chapter 10, Art IV.

**City of Portland, Maine - Building or Use Permit Application**

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

Job No: 2011-12-2924-FAFS	Date Applied: 12/14/2011	CBL: 043- D-005-001	
Location of Construction: 468 COMMERCIAL ST	Owner Name: CITY OF PORTLAND	Owner Address: 389 CONGRESS ST. PORTLAND, MAINE 04101	Phone:
Business Name: International Marine Terminal	Contractor Name: High Tech Fire Protection	Contractor Address: PO Box 156, Minot, ME 04258-0258	Phone: 998-2551
Lessee/Buyer's Name:	Phone:	Permit Type: Fire Suppression System	Zone: WPDZ
Past Use: New Office Bldg on site	Proposed Use: Same: Office use – to install fire suppression system	Cost of Work: \$12,000.00	CEO District:
		Fire Dept: <input checked="" type="checkbox"/> Approved w/ conditions <input type="checkbox"/> Denied <input type="checkbox"/> N/A	Inspection: Use Group: Type:
Proposed Project Description: wterbased fire suppression system		Pedestrian Activities District (P.A.D.)	
Permit Taken By: Gayle		<b>Zoning Approval</b>	

<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building Permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False informatin may invalidate a building permit and stop all work.</p>	<p><b>Special Zone or Reviews</b></p> <p><input type="checkbox"/> Shoreland</p> <p><input type="checkbox"/> Wetlands</p> <p><input type="checkbox"/> Flood Zone</p> <p><input type="checkbox"/> Subdivision</p> <p><input type="checkbox"/> Site Plan</p> <p><input type="checkbox"/> Maj <input type="checkbox"/> Min <input type="checkbox"/> MM</p> <p>Date: <i>OK</i> 12/14/11</p>	<p><b>Zoning Appeal</b></p> <p><input type="checkbox"/> Variance</p> <p><input type="checkbox"/> Miscellaneous</p> <p><input type="checkbox"/> Conditional Use</p> <p><input type="checkbox"/> Interpretation</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Denied</p> <p>Date:</p>	<p><b>Historic Preservation</b></p> <p><input checked="" type="checkbox"/> Not in Dist or Landmark</p> <p><input type="checkbox"/> Does not Require Review</p> <p><input type="checkbox"/> Requires Review</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Approved w/Conditions</p> <p><input type="checkbox"/> Denied</p> <p>Date: <i>[Signature]</i></p>
	<b>CERTIFICATION</b>		

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the appication is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE



2011 12 29 24



# Water-Based Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

466 454 Commercial

WP 17

Installation address: 468 Commercial St CBL: 043 D 006 ES

Exact location: (within structure) Portland International Marine Terminal

Type of occupancy(s) (NFPA & ICC): Light Hazard Occupancy

Should be where the Bldg permit is located  
043-D-005

Building owner: \_\_\_\_\_

Managing Supervisor (RMS): Ed Poulin License No: 515

Supervisor phone: 207-998-2551 E-mail: epoulin@fairpoint.net

Installing contractor: High Tech Fire Protection License No: \_\_\_\_\_

Contractor phone: High Tech Fire Protection E-mail: htfp@fairpoint.net

The suppression work to be done will be: New:  Renovation:  Addition to existing system:

This is an amendment to an existing permit: Yes:  NO  Permit no: 9764

NFPA Standard this system is designed to: NFPA 13 Edition: 2007

\*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from [www.portlandmaine.gov/fire](http://www.portlandmaine.gov/fire) for every submittal. Attach all working documents and complete approved submittals as may be required by the State Fire Marshal's Office on electronic PDF's in addition to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

**COST OF WORK: \$11,554.00**

**PERMIT FEE: \$140.00**

(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

**RECEIVED**

BY: *mail* DEC 14 2011

**Dept. of Building Inspections**  
City of Portland Maine

Applicant signature: *Tim Bob* Date: 11-15-11



... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION  
PO. BOX 156  
MINOT, ME 04258-0258  
207-998-2551

Job Name : Portland Marine Terminal Calc  
Building : FP-01  
Location : Congress St  
System : REMOTE AREA #1  
Contract : 071211-1  
Data File : Portland Marine Terminal Calc.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**Project name:** Portland Marine Terminal Calc  
**Location:** Congress St  
**Drawing no:** FP-01  
**Date:** 10-19-11

**Design**

**Remote area number:** REMOTE AREA #1  
**Remote area location:** OFFICE AND CORRIDOR  
**Occupancy classification:** LIGHT HAZARD  
**Density:** .1 - Gpm/SqFt  
**Area of application:** 1125 - SqFt  
**Coverage per sprinkler:** 196 - SqFt  
**Type of sprinklers calculated:** GLOBE MODEL GL5606  
**No. of sprinklers calculated:** 13  
**In-rack demand:** N/A - GPM  
**Hose streams:** 100 - GPM  
**Total water required (including hose streams):** 421 - GPM @ 98 - Psi  
**Type of system:** WET SYSTEM  
**Volume of dry or preaction system:** N/A - Gal

**Water supply information**

**Date:**  
**Location:** PORTLAND WATER DEPT.  
**Source:** TWO HYDRANT CALC

**Name of contractor:** HIGH TECH FIRE PROTECTION  
**Address:** PO. BOX 156 / / MINOT, ME 04258-0258  
**Phone number:** 207-998-2551  
**Name of designer:** TIM FORTIN  
**Authority having jurisdiction:** STATE OF MAINE & CITY OF PORTLAND  
**Notes:** (Include peaking information or gridded systems here.)


# Water Supply Curve (C)

HIGH TECH FIRE PROTECTION  
Portland Marine Terminal Calc

Page 2  
Date 10-19-11

City Water Supply:  
C1 - Static Pressure : 108  
C2 - Residual Pressure: 88  
C2 - Residual Flow : 1574

Demand:  
D1 - Elevation : 4.721  
D2 - System Flow : 321.656  
D2 - System Pressure : 98.929  
Hose ( Adj City ) :  
Hose ( Demand ) : 100  
D3 - System Demand : 421.656  
Safety Margin : 7.322





## Fittings Used Summary

HIGH TECH FIRE PROTECTION  
Portland Marine Terminal Calc

Page 3  
Date 10-19-11

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
Abbrev.	Name																					
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0	
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0	
Zia	Wilkins 350	Fitting generates a Fixed Loss Based on Flow																				

## Units Summary

Diameter Units                   Inches  
Length Units                       Feet  
Flow Units                         US Gallons per Minute  
Pressure Units                   Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.



Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION  
Portland Marine Terminal Calc

Page 4  
Date 10-19-11

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	5.6	12.25	na	19.6	0.1	196	7.0
DP2	-1.0	5.6	12.25	na	19.6	0.1	196	7.0
DP3	-1.0	5.6	12.25	na	19.6	0.1	196	7.0
1	10.9	K = K @ EQ01	12.37	na	19.64			
2	10.9	K = K @ EQ01	12.32	na	19.6			
3	10.9	K = K @ EQ02	13.61	na	20.6			
4	10.9	K = K @ EQ01	16.5	na	22.68			
5	10.9	K = K @ EQ01	19.94	na	24.94			
6	10.9	K = K @ EQ01	22.98	na	26.77			
L1	10.9		12.7	na				
L2	10.9		13.03	na				
L3	10.9		14.39	na				
L4	10.9		17.43	na				
L5	10.9		19.3	na				
L6	10.9		20.61	na				
L7	10.9		21.03	na				
L8	10.9		24.23	na				
10	17.0	K = K @ EQ03	14.34	na	20.83			
11	17.0	K = K @ EQ03	14.32	na	20.82			
12	17.0	K = K @ EQ03	15.7	na	21.8			
13	17.0	K = K @ EQ03	19.94	na	24.57			
L10	17.0		14.7	na				
L11	17.0		15.1	na				
L12	17.0		16.55	na				
L13	17.0		18.62	na				
L14	10.9		23.3	na				
L15	10.9		23.65	na				
20	10.9	K = K @ EQ01	27.6	na	29.34			
21	10.9	K = K @ EQ01	34.63	na	32.86			
22	10.9	K = K @ EQ01	44.43	na	37.22			
M1	10.9		24.69	na				
M2	9.6		26.52	na				
M3	9.6		29.94	na				
M4	9.6		38.84	na				
M5	9.6		52.75	na				
M6	9.6		56.75	na				
M7	9.6		70.13	na				
TOR	9.6		76.25	na				
BOR	2.6		87.99	na				
BAK	0.0		98.06	na				
U1	-5.0		101.0	na				
TEST	0.0		98.93	na	100.0			

The maximum velocity is 30.75 and it occurs in the pipe between nodes M5 and M6

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
Portland Marine Terminal Calc

Page 5  
Date 10-19-11

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	19.60 19.6	1.049 120.0 0.1252	1E 2.0 0.0 0.0	2.000 2.000 4.000	12.250 -0.433 0.501			K Factor = 5.60 Vel = 7.28	
	0.0 19.60					12.318		K Factor = 5.58	
DP2 to EQ02	19.60 19.6	1.049 120.0 0.1252	1E 2.0 0.0 0.0	2.000 2.000 4.000	12.250 -0.433 0.501			K Factor = 5.60 Vel = 7.28	
	0.0 19.60					12.318		K Factor = 5.58	
DP3 to EQ03	19.60 19.6	1.049 120.0 0.1253	1T 5.0 0.0 0.0	2.000 5.000 7.000	12.250 -0.433 0.877			K Factor = 5.60 Vel = 7.28	
	0.0 19.60					12.694		K Factor = 5.50	
1 to L1	19.64 19.64	1.049 120.0 0.1257	1E 2.0 0.0 0.0	0.650 2.000 2.650	12.367 0.0 0.333			K Factor @ node EQ01 Vel = 7.29	
	0.0 19.64					12.700		K Factor = 5.51	
2 to L2	19.60 19.6	1.049 120.0 0.1254	1T 5.0 0.0 0.0	0.700 5.000 5.700	12.318 0.0 0.715			K Factor @ node EQ01 Vel = 7.28	
	0.0 19.60					13.033		K Factor = 5.43	
3 to L3	20.60 20.6	1.049 120.0 0.1374	1T 5.0 0.0 0.0	0.700 5.000 5.700	13.607 0.0 0.783			K Factor @ node EQ02 Vel = 7.65	
	0.0 20.60					14.390		K Factor = 5.43	
4 to L4	22.68 22.68	1.049 120.0 0.1644	1T 5.0 0.0 0.0	0.700 5.000 5.700	16.495 0.0 0.937			K Factor @ node EQ01 Vel = 8.42	
	0.0 22.68					17.432		K Factor = 5.43	
5 to L7	24.94 24.94	1.049 120.0 0.1957	1T 5.0 0.0 0.0	0.600 5.000 5.600	19.938 0.0 1.096			K Factor @ node EQ01 Vel = 9.26	
	0.0 24.94					21.034		K Factor = 5.44	
6 to L8	26.77 26.77	1.049 120.0 0.2230	1T 5.0 0.0 0.0	0.600 5.000 5.600	22.976 0.0 1.249			K Factor @ node EQ01 Vel = 9.94	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
Portland Marine Terminal Calc

Page 6  
Date 10-19-11

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes *****
	0.0 26.77				24.225		K Factor =	5.44
L1 to L2	19.64	1.38 120.0	0.0 0.0	10.050 0.0	12.700 0.0		Vel =	4.21
L2 to L3	19.60	1.38 120.0	0.0 0.0	11.400 0.0	13.033 0.0		Vel =	8.42
L3 to L4	39.24	0.1190	0.0	11.400	1.357		Vel =	12.84
L4 to L5	20.60	1.38 120.0	0.0 0.0	11.700 0.0	14.390 0.0		Vel =	13.00
L5 to L6	59.84	0.2600	0.0	11.700	3.042		Vel =	13.00
L6 to L7	22.68	1.61 120.0	1E 4.0 0.0	4.400 4.000	17.432 0.0		Vel =	13.00
L7 to L8	82.52	0.2223	0.0	8.400	1.867		Vel =	13.00
L8 to L9	0.0	1.61 120.0	1E 4.0 0.0	1.900 4.000	19.299 0.0		Vel =	13.00
L9 to M1	82.52	0.2226	0.0	1.900	0.423		Vel =	16.93
L10 to M1	24.94	1.61 120.0	1T 8.0 0.0	2.100 8.000	21.034 0.0		Vel =	21.62
L11 to M1	107.46	0.3624	0.0	10.100	3.660		Vel =	9.94
	0.0 26.77				24.694		K Factor =	5.39
L8 to M1	26.77	1.049 120.0	0.0 0.0	2.100 0.0	24.225 0.0		Vel =	7.73
L10 to L11	20.83	1.049 120.0	1E 2.0 0.0	0.600 2.000	14.338 0.0		Vel =	5.43
L11 to L12	20.83	0.1400	0.0	2.600	0.364		Vel =	5.43
L12 to L13	0.0	1.049 120.0	1T 5.0 0.0	0.600 5.000	14.320 0.0		Vel =	7.73
L13 to L14	20.82	0.1400	0.0	5.600	0.784		Vel =	5.36
L14 to L15	0.0	1.049 120.0	1T 5.0 0.0	0.600 5.000	15.699 0.0		Vel =	8.09
L15 to L16	21.80	0.1527	0.0	5.600	0.855		Vel =	



Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
Portland Marine Terminal Calc

Page 7  
Date 10-19-11

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes *****
	0.0 21.80				16.554			K Factor = 5.36
13 to L15	24.57	1.049 120.0 0.1904	1T 5.0 0.0 0.0	0.600 5.000 5.600	19.944 2.642 1.066			K Factor @ node EQ03 Vel = 9.12
	0.0 24.57				23.652			K Factor = 5.05
L10 to L11	20.83	1.38 120.0 0.0369	0.0 0.0 0.0	10.900 0.0 10.900	14.702 0.0 0.402			Vel = 4.47
L11 to L12	20.82	1.38 120.0 0.1330	0.0 0.0 0.0	10.900 0.0 10.900	15.104 0.0 1.450			Vel = 8.93
L12 to L13	21.79	1.61 120.0 0.1367	1T 8.0 0.0 0.0	7.100 8.000 15.100	16.554 0.0 2.064			Vel = 10.00
L13 to L14	0.0	1.61 120.0 0.1367	1T 8.0 0.0 0.0	6.900 8.000 14.900	18.618 2.642 2.037			Vel = 10.00
L14 to L15	0.0	1.61 120.0 0.1365	0.0 0.0 0.0	2.600 0.0 2.600	23.297 0.0 0.355			Vel = 10.00
L15 to M2	24.57	1.61 120.0 0.2505	1T 8.0 0.0 0.0	1.200 8.000 9.200	23.652 0.563 2.305			Vel = 13.87
	0.0 88.01				26.520			K Factor = 17.09
20 to M3	29.34	1.049 120.0 0.2645	1T 5.0 0.0 0.0	1.700 5.000 6.700	27.602 0.563 1.772			K Factor @ node EQ01 Vel = 10.89
	0.0 29.34				29.937			K Factor = 5.36
21 to M4	32.86	1.049 120.0 0.3261	1T 5.0 0.0 0.0	6.200 5.000 11.200	34.628 0.563 3.652			K Factor @ node EQ01 Vel = 12.20
	0.0 32.86				38.843			K Factor = 5.27
22 to M5	37.22	1.049 120.0 0.4106	1E 2.0 1T 5.0 0.0	11.900 7.000 18.900	44.426 0.563 7.761			K Factor @ node EQ01 Vel = 13.82
	0.0							

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION  
Portland Marine Terminal Calc

Page 8  
Date 10-19-11

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	37.22				52.750			K Factor = 5.12	
M1 to M2	134.22	2.067 120.0	0.0	7.800	24.694 0.563			Vel = 12.83	
M2 to M3	88.01	2.067 120.0	0.0	8.300	26.520 0.0			Vel = 21.25	
M3 to M4	222.23	0.4117	0.0	8.300	3.417				
M3 to M4	29.34	2.067 120.0	1V 3.5 0.0	13.700 3.500	29.937 0.0			Vel = 24.05	
M4 to M5	251.57	0.5178	0.0	17.200	8.906				
M4 to M5	32.87	2.067 120.0	0.0	21.400	38.843 0.0			Vel = 27.20	
M5 to M6	284.44	0.6499	0.0	21.400	13.907				
M5 to M6	37.22	2.067 120.0	0.0	4.900	52.750 0.0			Vel = 30.75	
M6 to M7	321.66	0.8159	0.0	4.900	3.998				
M6 to M7	0.0	2.067 120.0	1X 8.5 1V 3.5	4.400 12.000	56.748 0.0			Vel = 30.75	
M7 to TOR	321.66	0.8159	0.0	16.400	13.380				
M7 to TOR	0.0	2.067 120.0	1V 3.5 0.0	4.000 3.500	70.128 0.0			Vel = 30.75	
TOR to BOR	321.66	0.8159	0.0	7.500	6.119				
TOR to BOR	0.0	2.067 120.0	1Fsp 0.0 0.0	7.000 0.0	76.247 6.032			* Fixed loss = 3 Vel = 30.75	
BOR to BAK	321.66	0.8159	0.0	7.000	5.711				
BOR to BAK	0.0	2.635 120.0	1Zia 0.0 0.0	0.100 0.0	87.990 10.050			* Fixed loss = 8.924 Vel = 18.92	
BAK to U1	321.66	0.2400	0.0	0.100	0.024				
BAK to U1	0.0	6.16 140.0	2E 40.168 1G 4.304	170.000 87.509	98.064 2.166			Vel = 3.46	
U1 to TEST	321.66	0.0030	1T 43.037	257.509	0.774				
U1 to TEST	0.0	9.79 140.0	1E 26.131 1T 59.389	200.000 85.520	101.004 -2.166			Vel = 1.37	
TEST	321.66	0.0003	0.0	285.520	0.091				
	100.00							Qa = 100.00	
	421.66				98.929			K Factor = 42.39	



# CITY OF PORTLAND, MAINE

Department of Building Inspections

## Original Receipt

December 14 2011

Received from James Corp.

Location of Work 166 Commercial

Cost of Construction \$ \_\_\_\_\_ Building Fee: \_\_\_\_\_

Permit Fee \$ \_\_\_\_\_ Site Fee: \_\_\_\_\_

Certificate of Occupancy Fee: \_\_\_\_\_

Total: \_\_\_\_\_

Building (IL)  Plumbing (I5) \_\_\_\_\_ Electrical (I2) \_\_\_\_\_ Site Plan (U2) \_\_\_\_\_

Other Free Supplemental

CBL: 042 2006

Check #: 159532 Total Collected \$ 140.00

**No work is to be started until permit issued.  
Please keep original receipt for your records.**

Taken by: [Signature]

WHITE - Applicant's Copy  
YELLOW - Office Copy  
PINK - Permit Copy