



- NOTES:**
1. 30A /2 Pole circuit breaker for engine jacket water heater. Confirm heater voltage (240V) with generator set vendor.
 2. Standby power panel SPP-1 see schedule and one-line diagram.
 3. 150A ATS see specifications & one-line diagram.
 4. Generator remote alarm panel, see specifications.
 5. Location of new "City Meter" & 150A cir. breaker.
 6. Exact placement of fence to be field coordinated with site conditions and gen. set.

	PORTLAND INTERNATIONAL JETPORT FACILITIES ENGINEERING DEPARTMENT		
	Part Site Plan, Gen. Loc.		
DATE: 12/06/04	REV. NO.	ADD #5 SPS-4	REV.
DWG BY: CLA	SCALE	1 OF 1	
CK BY: PHB			