

# ELECTRICAL PERMIT

## City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:  
 The undersigned hereby applies for a permit to make electrical installations  
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,  
 National Electrical Code and the following specifications:

Date April 22 2011  
 Permit # 201104881  
 CBL# 049A005

LOCATION: 127+129 YORK ST. METER MAKE & # \_\_\_\_\_  
 CMP ACCOUNT # 3-809281 OWNER RED FERN PROPERTIES / JONATHAN CULLEY  
 TENANT \_\_\_\_\_ PHONE # 776-9715

049A005

							TOTAL EACH FEE	
OUTLETS	300	Receptacles	120	Switches	36	Smoke Detector	.20	91.20
FIXTURES	72	Incandescent		Fluorescent		Strips	.20	14.40
SERVICES	1	Overhead		Underground		TTL AMPS <800	15.00	15
		Overhead		Underground		>800	25.00	
Temporary Service		Overhead		Underground		TTL AMPS	25.00	
METERS	13	(number of)					25.00	
MOTORS		(number of)					1.00	13
RESID/COM		Electric units					2.00	
HEATING		oil/gas units		Interior		Exterior	5.00	
APPLIANCES	12	Ranges		Cook Tops		Wall Ovens	2.00	24
		Insta-Hot		Water heaters		Fans	2.00	
	12	Dryers	12	Disposals	12	Dishwasher	2.00	72
		Compactors		Spa		Washing Machine	2.00	
		Others (denote)					2.00	
MISC. (number of)		Air Cond/win					3.00	
		Air Cond/cent				Pools	10.00	
		HVAC		EMS		Thermostat	5.00	
		Signs					10.00	
		Alarms/res					5.00	
		Alarms/com					15.00	
		Heavy Duty(CRKT)					2.00	
		Circus/Carnv					25.00	
		Alterations					5.00	
		Fire Repairs					15.00	
		E Lights						
		E Generators						
PANELS	1	Service	12	Remote		Main	4.00	52
TRANSFORMER		0-25 Kva					5.00	
		25-200 Kva					8.00	
		Over 200 Kva					10.00	
TOTAL AMOUNT DUE								281.60
MINIMUM FEE/COMMERCIAL 55.00							MINIMUM FEE	45.00

**RECEIVED**

APR 22 2011

Dept. of Building Inspections  
 City of Portland Maine

CONTRACTORS NAME DARLING'S ELECTRICAL SERVICE MASTER LIC. # MS60010638  
 ADDRESS 52 PINE KNOLL DR DURHAM, ME 04222 LIMITED LIC. # \_\_\_\_\_  
 TELEPHONE 212-1295

SIGNATURE OF CONTRACTOR [Signature]

4/25/2011 - ~~UNITS~~ <sup>#</sup> 129 UNITS 1+2+3 = Close in OK + BKL

5/9/2011 - <sup>#129</sup> UNITS 4+5+6 OK to close in - check for wire marked  
in switch box in Dining Room for wire buried in ceiling - BKL

6/15/2011 - # 127 UNITS 4+5+6 Close in OK BKL

6/30/2011 - NEW OH Service PASS - I called comp BKL



STATE OF MAINE  
DEPT OF PROFESSIONAL & FINANCIAL REGULATION  
ELECTRICIANS' EXAMINING BOARD

LICENSE # MS60010638

JEFFREY K. DARLING  
MASTER ELECTRICIAN

ISSUED Sep 01, 2010 EXPIRES Aug 31, 2012