

City of Portland, Maine

Inspections Division

Inspection Results

Date Range from 1/5/2005 through 11/20/2014

Date	CBL	Business	Appl ID	Appl Type	FT	Sch. Type	Status
06/01/2006	044 A005001		0	Complaint	No	Inspection	
127 YORK ST UNIT		Called in by MJN for sewer back up in Unit # 4 First floor due to torrential rain storm.					
03/20/2007	044 A005001		9081	Complaint	No	Sidewalk Snow/Ice	
127 YORK ST UNIT		PW Sidewalk Snow Complaint GD					
05/04/2007	044 A005001		0	Fire Prevention	No	FP Routine Inspection	
127 YORK ST UNIT							
12/07/2007	044 A005001		10538	Complaint	No	Sidewalk Snow/Ice	
127 YORK ST UNIT		9:00am, 12/06/07 uncleared sidewalks					
		20 High St. 22 High St. 129 York St. (east end of property)					
01/03/2008	044 A005001		10681	Complaint	No	Sidewalk Snow/Ice	
127 YORK ST UNIT		9:45am, 12/18/07 uncleared sidewalk					
		129 York St.					
01/07/2008	044 A005001		10681	Complaint	No	Sidewalk Snow/Post Reinsp	
127 YORK ST UNIT		9:45am, 12/18/07 uncleared sidewalk					
		129 York St.					
07/22/2008	044 A005001		80636	Building	No	Certificate of Occupancy/Final	
127 YORK ST UNIT		Final for replacement windows - 829-3893 Lonnie Allen MUST HAVE CALL WITH TIME AT LEAST 1 HOUR					
11/17/2009	044 A005001		90953	Building	No	Certificate of Occupancy/Final	
127 YORK ST UNIT		Permit for all window permits - 829-3893 Lonnie					
01/26/2011	044 A005001			ElcPeC	No	Electrical Only	
127 YORK ST UNIT		Jeff 212-1295 SET TIME 2:30PM				WALK TRU WITH ELECTRICIAN TO GO OVER REWIRING KITCHEN AND BATHROOM AND ELECTRICAL SERVICE.....12 UNIT BUILDING CURRENTLY....BKL	
04/25/2011	044 A005001			Building	No	Close-in Plumbing/Framing w/	
127 YORK ST UNIT		3 Units only Jonathan 776-9715					
05/09/2011	044 A005001			Building	No	Close-in Plumbing/Framing w/	
127 YORK ST UNIT		Units 129 4 5 6 776-9715					
05/10/2011	044 A005001			Building	No	Plumbing Only	
127 YORK ST UNIT		per nick					
06/15/2011	044 A005001			Building	No	Close-in Plumbing/Framing w/	
127 YORK ST UNIT		Units 4 5 & 6 776-9715 Jonathan Culley					
06/30/2011	044 A005001			ElcPeC	No	Electrical Service	
127 YORK ST UNIT		3-809281 Jeff 212-1295					

City of Portland, Maine

Inspections Divison

Inspection Results

Date Range from 1/5/2005 through 11/20/2014

Date	CBL	Business	Appl ID	Appl Type	FT	Sch. Type	Status
07/15/2011	044 A005001			Building	No	Certificate of Occupancy/Final	
127 YORK ST UNIT		Units 129 1, 2, 3	776-9715 Jonathan	2011-02-415-MF-			
07/20/2011	044 A005001			Building	No	Close-in Plumbing/Framing w/	
127 YORK ST UNIT		127 units 1 2 &3	Jonathan Culley	776-9715			
07/22/2011	044 A005001			Plumbing	No	Plumbing Only	
127 YORK ST UNIT		127 units 1 2 &3	Jonathan Culley	776-9715, plumbing only. /gg plumber 632-1014			
08/12/2011	044 A005001			Building	No	Certificate of Occupancy/Final	
127 YORK ST UNIT		Unt 129 1 through 6	Jonathan	776-9715			
08/18/2011	044 A005001			Building	No	Certificate of Occupancy/Final	
127 YORK ST UNIT		Jonathan Culley	776-9715	around 130			
09/07/2011	044 A005001			Building	No	Certificate of Occupancy/Final	
127 YORK ST UNIT		Units 3 & 6	Jonathan	776-9715			
01/11/2012	044 A005001		20113022	Electrical	No	Final - Electric	Follow-Up I
127 YORK ST UNIT		Jonathan Culley @ 776-9715 final for units #1, 2, 4 and 5. /gg				Gfci in top apartment has reverse polarity, some of the arc fault breakers not working correctly, smoke alarm not interconnected in top unit, gfci not working in unit 4	
01/11/2012	044 A005001		20111258	Building	No	Final Inspection	Follow-Up I
127 YORK ST UNIT		Jonathan Culley @ 776-9715 final for units #1, 2, 4 and 5. /gg				Unit #2 OK. Others failed elec.	
02/29/2012	044 A005001		20111258	Building	No	Certificate of Occupancy/Final	BP Inspecti
127 YORK ST UNIT		Jon 776-9715, Units 1, 4, & 5. He called and stated he talked w/Don.					