



MESSAGE REPLY FORM

KEYSTONE PROCESS PRINTING CO., JAMAICA, N.Y. 11433 FORM NO. KS-1

GEOFFREY I. RICE

658 CONGRESS STREET, 1ST FLOOR

PORTLAND, MAINE 04101

TELEPHONE (207) 773-1814

MESSAGE

REPLY

TO: [CITY OF PORTLAND, FIRE DEPT
INSPECTOR BRUCE D CYR, UNIT 5
280 CONGRESS ST
PORTLAND, ME 04101-0011]

DATE: _____

DATE: 20 APRIL 2010

Re: 40 HIGH ST

DEAR INSPECTOR CYR,

ENCLOSED IS A PHOTOCOPY OF YOUR
INSPECTION DATED 3/19/10. ITEM #1
HAS BEEN CORRECTED AND THERE IS CLEAR
PASSAGE IN THE STAIRWELL

ITEM #2 THE FIRE DOORS WILL BE
INSTALLED BY JULY 9, 2010 ON THE UNIT
DOORS.

YOURS TRULY,

GEOFFREY RICE

SIGNED: _____

SIGNED:



KEYSTONE PROCESS PRINTING CO., JAMAICA, N.Y. 11433 FORM NO. KS-1

THIS COPY FOR PERSON ADDRESSED