Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 08/17/16

SYSTEM RISER DIAGRAM

TYPICAL WIRING

LEGEND

- SK-MONITOR MODULE (POINT NUMBER)
- SK-PHOTO-T SMOKE DETECTOR (POINT NUMBER)
- SK-PULL (POINT NUMBER)
- SK-HEAT (POINT NUMBER)
- GATE VALVE TAMPER (POINT NUMBER)
- WATER FLOW (POINT NUMBER)
- AIR PRESSURE (POINT NUMBER)
- HORN/STROBE (CANDELA RATING)
- STROBE (CANDELA RATING)

BASEMENT

1ST FLOOR

Note; All Alarm Initiating Devices to Sound All Notification Appliances and Activate City Box

2ND FLOOR

3RD FLOOR

Note; No prints were available, drawing based on measurements taken on site and are reasonably close +/- Aprrox. 4 inches in floor spaces.

SHEET NUMBER: FA-1

SHEET TITLE: FIRE ALARM SYSTEM PLAN

© SECURADYNE SYSTEMS
DATE: 06-21-16
DRAWN: SURV-JK
SCALE: 1/8"=1'

PROJECT TITLE
CATHERINE MORRILL DAYCARE
DANFORTH ST
PORTLAND MAINE

| NO | REVISIONS | DATE | BY |
|---|---|---|---|
| 0 | ISSUED FOR REVIEW | 06-21-16 | SECURADYNE |

Date 23 JUN 16
Prepared by JohnKimball S.E.T. NICET Level IV Fire Alarm Systems
Cert.# 107989
Signature


John Kimball NICET Certified Senior Engineering Technician
Certification # 107989
securadyne systems
600 Research Drive
NE Reg Wilmington, MA Office
Wilmington, MA 01887
Toll Free: 800-354-2616
Fax: 978-688-9119
In State: 978-688-4444
NE Reg Portland, ME Office
4 Thomas Drive, Suite 5
Westbrook, ME 04092
Toll Free: 888-826-8567
Fax: 207-828-0044
In State: 207-828-0022