

From: Chris Pirone
To: JF@portlandmaine.gov
CC: BAB@portlandmaine.gov
Date: 10/29/2013 8:15 PM
Subject: Re: Fwd: FW: Code Review; 133 York St.

Yes.

Fire is all set with the condition that the FDC connection will be on York St.

Captain Chris Pirone
Portland Fire Department
Fire Prevention Bureau
380 Congress Street
Portland, ME 04101
(t) 207.874.8405
(f) 207.874.8410

>>> Jean Fraser 10/25/13 12:56 PM >>>
Chris

Could you please let me know if this addresses all of your concerns and that the proposals are OK as they stand. We have to decide when they can get on a PB Hearing agenda!!!

Thank you
Jean

>>> "Tom Greer" <TGreer@pinkhamandgreer.com> 10/25/2013 9:57 AM >>>

Hi Jean,
Here is Mark's report. Let me know if you have any questions.

Tom Greer
Pinkham and Greer, Consulting Engineers
207-781-5242 voice, 207-781-4245 fax
tgreer@pinkhamandgreer.com