


# DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK CITY OF PORTLAND

## BUILDING INSPECTION

### PERMIT

Please Read Application And Notes, If Any, Attached

Permit Number: 041070



This is to certify that Barker Wayne/Applicant  
has permission to Foundation only for a 3250 sq ft 8 unit building  
AT 157 York St 044 B005001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and work in permit in progress before this building or part thereof is loaded or otherwise used-in. HOUR NOTIFICATION REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

#### OTHER REQUIRED APPROVALS

Fire Dept. \_\_\_\_\_  
Health Dept. \_\_\_\_\_  
Appeal Board \_\_\_\_\_  
Other \_\_\_\_\_  
Department Name

*Ally Cuyt* 7/30/04  
Director - Building & Inspection Services

**PENALTY FOR REMOVING THIS CARD**



8/2/04  
8/3/04  
8/4/04  
8/10/04  
8/17/04  
8/18/04  
9/22/04  
10/14/04

8/3/04 Set backs too close to call. Corner pins set by Survey Co. Letter attached. Rebar not completed. Allow

8/4/04 Rebar OK

8/10/04 OK to pour concrete walls. Allow

8/17/04 OK to Backfill. Allow

8/18/04 OK for underground pb M

9/22/04 First Floor Framing OK. Allow  
See permit # 04/0845

10/14/04 - Electrical - Backfill - OK  
EXCEPT - only the 12" above tapes in -  
They will add the 12" below grade  
Call for info when they put in gas line. - (Mcf)  
Car 23 was out this day & the house was  
open across Gulfport Lane D