

---

---

**CITY OF PORTLAND**  
**DEPARTMENT OF PLANNING & URBAN DEVELOPMENT**

389 Congress Street  
Portland, Maine 04101

---

**Inspection Violations**

<b>Owner/Manager</b> LAMOUR RUSSELL & SYLVIE D JTS		<b>Inspector</b> Jon Rioux	<b>Inspection Date</b> 4/30/2007
<b>Location</b> 27 STATE ST	<b>CBL</b> 044 B010001	<b>Status</b> Re-Inspect 10 Days	<b>Inspection Type</b> Complaint-Inspection

<b>Code</b>	<b>Int/Ext</b>	<b>Floor</b>	<b>Unit No.</b>	<b>Area</b>	<b>Compliance Date</b>
1) 6-113.5	Exterior				
<b>Violation:</b>	Maintenance of lighting fixtures				
<b>Notes:</b>	Repair the building electrical service connection so that it is in good and safe working condition and in accordance with the electrical code of the city by the 10th day of May, 2007. Note: a Master Electrician is required.				
2) 6-108.1					
<b>Violation:</b>	Foundations cellars, exterior walls, roofs				
<b>Notes:</b>	Every foundation, and exterior wall shall be structurally sound and in good repair; and shall be safe for the intended use as well as capable of supporting whatever load normal use may cause to be placed thereon. A building permit must be submitted to this office by the 10th day of May, 2006.				

**Comments:**