



Portland Fire Department

2/21/2020

WOJCIK JOSEPH B JR
211 FALMOUTH RD
FALMOUTH, ME 04105
jwojcik@aol.com

CERTIFIED MAIL

RE:

Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 1/29/2020 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 3/5/2020 10:00:00AM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
PFD Rules, 5.10.2	All signal systems must have a current inspection sticker issued by a Master Fire Alarm Company.	No sticker on this very old system	2/21/2019
NFPA 101-9.1.2; NFPA 70	Electrical system must comply with NFPA 70, National Electric Code. A master electrician must certify that the system is safe and compliant.		2/20/2020
NFPA 54-9.6.4	No storage 36" in front of or 30" to either side of all electrical panels.	Utility room blocked	2/20/2020