



**Portland Fire Department**

2/27/2020

CERTIFIED MAIL

RE: 333 SAINT JOHN ST  
PORTLAND, ME 04102

065 C008001

Page 1 of 2

**NOTICE OF VIOLATION  
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 2/27/2020 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

**A reinspection of your property will take place on 3/19/2020 11:00:00AM .**

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Fire Prevention Bureau  
City of Portland

**NON-COMPLIANCE VIOLATION LIST**

<b>NAME</b>	<b>CODE DESCRIPTION</b>	<b>COMMENTS</b>	<b>Deadline</b>
PFD Rules, 5.10.2	All signal systems must have a current inspection sticker issued by a Master Fire Alarm Company.	sticker on fire alarm	3/19/2020
Portland Code Ch. 10	Buildings must comply with Ch. 10 of the Portland Code of Ordinances.	protection for heater in bay/ oil waste	3/19/2020