

Portland, Maine



Yes. Life's good here.

Portland Fire Department

2/6/2020

CITY OF PORTLAND (PORTLAND PUBLIC SCHOOLS)
353 CUMBERLAND AVENUE
PORTLAND, ME 04101
sherwd@portlandschools.org

CERTIFIED MAIL

RE: 175 AUBURN

374 B012001

Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 2/5/2020 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 3/5/2020 1:00:00PM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-4.5.8, 7.9.3	Emergency lights must be kept in good working order.	Bulbs in emergency lighting through main hallways need repair and or replacement.	3/5/2020
