
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager LOW INCOME PROPERTIES LLC		Inspector Suzanne Hunt	Inspection Date 8/4/2006
Location 36 STATE ST	CBL 044 C013001	Status Re-Inspect 30 Days	Inspection Type Complaint-Social Services/Gener

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-116.2	Interior	3	20	Bedroom	
Violation:	Egress				
Notes:	Egress Window not to code				

Comments: Window in apartment 20, MUST be an egress window. Building permit must be applied for within 30 Days, to show compliance with 1025.2 of the International Building Code.