

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

AHMED KANVAL

Located at

35 TATE ST

PERMIT ID: 2017-00776

ISSUE DATE: 08/03/2017

CBL: 044 D026001

has permission to **Replace existing cabinets and countertops, replace/repair existing drywall (using 5/8" fire-rated drywall on walls separating egress and dwelling units and 1/2" on all other walls) refinish existing flooring and painting.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Brian Stephens

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

3 dwelling units

Building Inspections

Use Group: R-2 Type: 5B

Apartment House (3 Units)

non-sprinkled

ENTIRE

MUBEC/IBC-2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Final - Electric

Final - Fire

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-00776	Date Applied For: 05/22/2017	CBL: 044 D026001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Multi family	Proposed Project Description: Replace existing cabinets and countertops, replace/repair existing drywall (using 5/8" fire-rated drywall on walls separating egress and dwelling units and 1/2" on all other walls) refinish existing flooring and painting.			
Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 05/26/2017 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) This permit is not approving any lot coverage or setback requirements for the existing structure. It is approving work within the existing building footprint and shell only. 2) This property shall remain a three dwelling units. Any change of use shall require a separate permit application for review and approval. 3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Brian Stephens Approval Date: 08/03/2017 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Guards must be 42 inches in height with openings less than 4 inches. Graspable rails must be installed on both sides of the stair guard at 34" to 38". Stair treads shall not be less than 11". Stair risers shall not be more than 7". 2) Permit approved based upon information provided by the applicant, This is an After the Fact permit for work that was performed prior to approvals. Inspections are required to confirm Life Safety, electrical and structural compliance, and may require exposure of any hidden elements. Additional work and design approvals shall be required. 3) Construction shall be in compliance with the requirements of the IBC 2009, MUBEC and ADA standards. 4) The issuance of this permit shall not be construed to be a permit for, or approval of, any violations of any of the provisions of the building code or of any other ordinance of this jurisdiction. 5) Egress size windows are required (1) in each sleeping room per IRC Sec. R310 or per the State Fire Marshal policies for existing buildings. 6) Per IBC Sec. 3401.3 for existing buildings and dwelling units, compliance with smoke, carbon monoxide, fire protection and safety systems and devices shall be per City Ordinance Chapter 10 and NFPA 101 7) All existing fire separation partitions, barriers and horizontal assemblies at adjacent occupancies or dwelling units shall be maintain for rating and continuity. Additional materials may need to be added for compliance. 8) All pre-1978 building and housing stock shall meet State and Federal regulations for lead abatement. 9) Window sills in locations more than 72 inches from finished grade shall be a minimum of 24 inches above the finished floor of the room, unless a window fall prevention devices is installed in accordance with section IRC Sec. R612.3 or IBC Sec. 1405.13.2. 10) Guardrail openings shall be less than 4" up to a height of 36". From 36" - 42" the opening can be less than 4-3/8". 11) The guardrail system shall meet the loading requirements of section 1607.7.1 of the IBC 2003 Building Code. 12) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
Dept: Fire Status: Approved w/Conditions Reviewer: Jason Grant Approval Date: 08/02/2017 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions:				

PERMIT ID: 2017-00776

Located at: 35 TATE ST

CBL: 044 D026001

- 1) Every sleeping and living area in a residential occupancy shall have at least 1 primary means of escape and 1 secondary means of escape. The secondary means of escape may be an outside egress window operable from the inside without the use of tools, keys or special effort. In buildings built before 1976, egress windows shall provide a net clear opening 3.3 sq. ft. The width shall not be less than 20 inches and height shall not be less than 24 inches. The bottom of the window opening shall not be more than 44 inches above the floor unless a permanent step is installed.
- 2) All construction shall comply with City Code, Chapter 10.
All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43 and other applicable chapters
All construction shall comply with 2009 NFPA 1, Fire Code.
This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4).
All means of egress to remain accessible at all times.
If applicable, all outstanding code violations shall be corrected prior to final inspection.
- 3) Adding a fire sprinkler system to the building is strongly recommended but is not required because the proposed work does not meet the definition of NFPA 101's reconstruction work which is the trigger for requiring a fire sprinkler system.
- 4) Fire extinguishers are required per NFPA 1 (2009 Edition) Table 13.6.2. The quantity, size, type and location shall be in accordance with NFPA 1, 13.6.8.
For light or ordinary hazard buildings, a 2-A rated extinguisher (5lb. Dry Chemical Ext.) is required no more than 75 feet of travel distance from anywhere in the building and at least 1 extinguisher per story.
- 5) The means of egress shall be illuminated and marked in accordance with 2009 NFPA 101, sections 7.8 and 7.10.
7.8.1.3 The minimum illumination of the egress path for stairs shall be at least 10 ft-candle and the minimum illumination of the egress path of floors and other walking surfaces other than stairs shall be at least 1 ft-candle.
- 6) All penetrations for cables, cable trays, conduits, pipes, tubes, vents, ducts, wires and similar items that pass through or penetrate a fire rated wall ceiling or floor assembly shall be protected and sealed by a listed firestop system and installed to comply with the systems manufactures recommendation.
- 7) City of Portland Code Chapter 10 section 10-3 (i) all new smoke alarm must use photoelectric technology. In existing apartment building smoke detectors must be the buildings electrical service and must have a secondary power source (battery). Smoke Alarms shall be installed per NFPA 101 2009 section 9.6.2.10. Detectors are required to be installed in the following locations
 1. Inside all sleeping rooms.
 2. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas
 3. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.In new construction per NFPA 101 2009 section 9.6.2.10.3 where 2 or more smoke detectors are required within a dwelling unit they shall be arranged so that the operation of any smoke alarm shall cause the alarm of all smoke alarms within the dwelling unit.
- 8) City of Portland Code Chapter 10 section 10-3 (L) all residential occupancies, and all new multiple occupancies containing attached parking structures or fuel burning appliances shall be protected in accordance with NFPA 720, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition. Detectors shall be provided in the following areas.
 1. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas
 2. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.