BUILDING SECTION

SCALE: 1/4" = 1'-0"

NOTES:

1. STEEL PLATE AND ANGLES SHALL BE ASTM A36
2. W BEAMS SHALL BE ASTM A992
3. ALL STEEL SHALL BE SHOP PRIMED EXCEPT AT SLIP CRITICAL B(
4. ALL BOLTS SHALL BE ASTM A325 UNLESS NOTED OTHERWISE.
5. ALL WELDING SHALL UTILIZE E70XX ELECTRODES
6. FIELD VERIFY ALL DIMENSIONS PRIOR TO FABRICATION

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/02/17

1 SECTION AT WALL

SCALE: 1 1/2" = 1'-0"

2 BEAM SEAT WELDMENT DETAIL

SCALE: 1 1/2" = 1'-0"

3 SECTION AT SPLICE

SCALE: 1 1/2" = 1'-0"

4 EXIST. JOIST TO STEEL BEAM DETAIL

SCALE: 1 1/2" = 1'-0"

STATE OF MAINE
SAMUEL J. THOMAS
No. 12157
LICENSED
PROFESSIONAL ENGINEER

11-07-2014

0 1/2' 1' 1 1/2'

SCALE: 1 1/2" = 1'-0"

REV	DESCRIPTION	DWN BY	CKD BY	APP BY	DATE
1	REVISED EXTER. WALL THICKNESS	SJT	SJT	SJT	11/7/14
0	REVISED, ISSUED FOR CONSTRUCTION	SJT	SJT	SJT	9/10/14
B	REVISED PER FIELD CONDITIONS	SJT	SJT	SJT	8/6/14
A	ISSUED FOR REVIEW	SJT	SJT	SJT	5/16/14

ANTHONY FILIPPONE
225 YORK ST

3rd FLOOR BEAM REINFORCING

SUPPLEMENTARY BEAM SUPPORT SECTION

PLEASE NOTE: THIS DOCUMENT MAY NOT ACCURATELY REPRESENT THE FINAL DOCUMENT. ONLY AN ENGINEER, ARCHITECT OR SURVEYOR SIGNED, SEALED AND DATED PAPER COPY, PROVIDED BY THIS OFFICE, MAY BE UTILIZED FOR BIDDING OR CONSTRUCTION PURPOSES.

Colby Company engineering
47A York Street
Portland, Maine 04101
207.553.7753
colbycoengineering.com

SIZE: AS NOTED
DATE: 5.16.14
DES BY: SJT
DWN BY: SJT
CKD BY: SJT

PROJECT NO. 288.001.001

SHEET 1 OF 1

DRAWING NO. SSK-1