

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND

BUILDING PERMIT

This is to certify that DANA FISHER LLC

Located At 231 YORK ST

Job ID: 2011-05-1049-FAFS


CBL: 044 - - E - 003 - 001 - - - -

has permission to install a supervised, automatic sprinkler system

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be


Fire Prevention Officer

(58)

5/16/11

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
PENALTY FOR REMOVING THIS CARD

BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.



PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life • www.portlandmaine.gov

Director of Planning and Urban Development
Penny St. Louis

Job ID: 2011-05-1049-FAFS

Located At: 231 YORK ST

CBL: 044 - - E - 003 - 001 - - - -

Conditions of Approval:

Fire

The sprinkler system shall be installed in accordance with NFPA 13.

Sprinkler protection shall be maintained. Where the system is to be shut down for maintenance or repair, the system shall be checked at the end of each day to insure the system has been placed back in service.

Fire department connection type and location shall be approved in writing by fire prevention bureau. The Fire Department will require Knox locking caps on all Fire Department Connections on the exterior of the building.

System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.

Installation of a sprinkler or fire alarm system requires a Knox Box to be installed per city ordinance.

This sprinkler system must be supervised by central station.

The water flow alarm shall be located over the FDC. The required manual pull station shall be located at the front exit from the restaurant.

A separate Fire Alarm Permit is required.

The fire alarm system shall comply with the City of Portland Standard for Signaling Systems for the Protection of Life and Property. All fire alarm installation and servicing companies shall have a Certificate of Fitness from the Fire Department.

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

Job No: 2011-05-1049-FAFS	Date Applied: 5/5/2011	CBL: 044 - - E - 003 - 001 - - - -	
Location of Construction: 231 YORK ST	Owner Name: DANA FISHER LLC	Owner Address: PO BOX 169 PORTLAND, ME - MAINE 04112	Phone:
Business Name:	Contractor Name: Ed Poulin - High Tech Fire Protection	Contractor Address: 84 Hackett Mills RD Minot ME 04258	Phone: (207) 998-2551
Lessee/Buyer's Name:	Phone:	Permit Type: FIRE SYS WB - Fire Suppression Water Based	Zone: B-1
Past Use: Restaurant	Proposed Use: Restaurant - water-based fire suppression system	Cost of Work: 22000.00	CEO District:
		Fire Dept: ☒ Approved w/conditions ☐ Denied ☐ N/A Signature: <i>Bjork</i> (58)	Inspection: Use Group. Type: Signature:
Proposed Project Description: 231 York St. water based fire suppression system		Pedestrian Activities District (P.A.D.)	
Permit Taken By:		Zoning Approval	

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.
2. Building Permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False informatin may invalidate a building permit and stop all work.

Special Zone or Reviews	Zoning Appeal	Historic Preservation
☐ Shoreland	☐ Variance	☒ Not in Dist or Landmark
☐ Wetlands	☐ Miscellaneous	☐ Does not Require Review
☐ Flood Zone	☐ Conditional Use	☐ Requires Review
☐ Subdivision	☐ Interpretation	☐ Approved
☐ Site Plan	☐ Approved	☐ Approved w/Conditions
☐ Maj ☐ Min ☐ MM	☐ Denied	☐ Denied
Date: OK 5/13/11 <i>ABN</i>	Date:	Date: <i>ABN</i>

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the appication is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
------------------------	---------	------	-------

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE	DATE	PHON
---	------	------

5/5/11

Job Summary Report

Job ID: 2011-05-1049-FAFS

Report generated on May 13, 2011 3:10:15 PM

Page 1

Job Type:	Fire Alarm / Suppression	Job Description:	231 York	Job Year:	2011
Building Job Status Code:	Initiate Plan Review	Pin Value:	1423	Tenant Name:	
Job Application Date:		Public Building Flag:	N	Tenant Number:	
Estimated Value:	22,000	Square Footage:			
Related Parties:		FISHER DANA		Property Owner	
		High Tech Fire - ED Poulin RMS#515		SPRINKLER CONTRACTOR	

Job Charges

Fee Code Description	Charge Amount	Permit Charge Adjustment	Net Charge Amount	Payment Date	Receipt Number	Payment Amount	Payment Adjustment Amount	Net Payment Amount	Outstanding Balance
----------------------	---------------	--------------------------	-------------------	--------------	----------------	----------------	---------------------------	--------------------	---------------------

Location ID: 6574

Location Details

Alternate Id	Parcel Number	Census Tract	GIS X	GIS Y	GIS Z	GIS Reference	Longitude	Latitude
O09915	044 E 003 001		M				-70.261306	43.648073

Location Type	Subdivision Code	Subdivision Sub Code	Related Persons	Address(es)
1				231 YORK STREET WEST

Location Use Code	Variance Code	Use Zone Code	Fire Zone Code	Inside Outside Code	District Code	General Location Code	Inspection Area Code	Jurisdiction Code
RETAIL & PERSONAL SERVICE		NOT APPLICABLE	B-1				DISTRICT 3	WEST END

Structure Details

Structure: Bar/ Lounge

Occupancy Type Code:

Structure Type Code	Structure Status Type	Square Footage	Estimated Value	Address
Stores & Customer Services (Mercantile)	0			231 YORK STREET WEST

Longitude	Latitude	GIS X	GIS Y	GIS Z	GIS Reference	User Defined Property	Value
-----------	----------	-------	-------	-------	---------------	-----------------------	-------

Permit #: 20113484

Permit Data

Job Summary Report
Job ID: 2011-05-1049-FAFS

Report generated on May 13, 2011 3:10:15 PM

Page 2

Location Id	Structure Description	Permit Status	Permit Description	Issue Date	Reissue Date	Expiration Date		
6574	Bar/ Lounge	Initialized	Install water based fire system					
Inspection Details								
Inspection Id	Inspection Type	Inspection Result Status	Inspection Status Date	Scheduled Start Timestamp	Result Status Date	Final Inspection Flag		
Fees Details								
Fee Code Description	Charge Amount	Permit Charge Adjustment	Permit Charge Adj Remark	Payment Date	Receipt Number	Payment Amount	Payment Adjustment Amount	Payment Adj Comment



Water-Based Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: 231 York Street CBL: _____

Exact location: (within structure) Entire Structure

Type of occupancy(s) (NFPA & ICC): Assembly and Office

Building owner: _____

Managing Supervisor (RMS): Edward M. Poulin License No: 515

Supervisor phone: (207) 998-2551 E-mail: EPoulin@Fairpoint.net

Installing contractor: High Tech Fire Protection License No: 102

Contractor phone: (207) 998-2551 E-mail: htfp@Fairpoint.net

The suppression work to be done will be: New: ☒ Renovation: ☐ Addition to existing system: ☐

This is an amendment to an existing permit: Yes: ☐ NO: ☒ Permit no: _____

NFPA Standard this system is designed to: NFPA 13 Edition: 2007

*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from

www.portlandmaine.gov/fire for every submittal. Attach all working documents and complete approved submittals as may be required by the State Fire Marshal's Office on electronic PDF's in addition to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

COST OF WORK: \$22,000

PERMIT FEE: \$240.00

(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

RECEIVED
MAY - 1 2011
Dept. of Engineering & Information Systems
City of Portland

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

Check # 17565

Applicant signature: _____ Date: 5/3/2011

* State Log #: 211130 ; Permit # 9481



... Fire Protection by Computer Design

High Tech Fire Protection
84 Hackett Mills Road
P.O. Box 156
Minot, Maine 04258-0156
998-2551

Job Name : First Floor Kitchen Calc.
Building : 231 York Street
Location : 231 York Street
System : NFPA-13
Contract : 031511-2
Data File : First Floor Kitchen Calc.wxf

Hydraulic Design Information Sheet

Name - First Floor Kitchen Calc. Date - 4/19/2011
Location - 231 York Street
Building - 231 York Street System No. - NFPA-13
Contractor - High Tech Fire Protection Contract No. - 031511-2
Calculated By - Jeremy Foss Drawing No. - FP-1.1
Construction: (X) Combustible () Non-Combustible Ceiling Height - 8'-11"
Occupancy - Commercial Kitchen

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. (X) 1 () 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E
M Area of Sprinkler Operation - 800 System Type Sprinkler/Nozzle
Density - .15 (X) Wet Make Globe
D Area Per Sprinkler - 130 () Dry Model GL5601
E Elevation at Highest Outlet - 22 () Deluge Size 1/2"
S Hose Allowance - Inside - () Preaction K-Factor 5.6
I Rack Sprinkler Allowance - () Other Temp.Rat.155
G Hose Allowance - Outside - 250

N
Note

Calculation Flow Required - 506 Press Required - 61
Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 5/26/2004 Cap. -
T Time of Test - Rated Cap.-
E Static Press - 77 @ Press -
R Residual Press - 71 Elev. -
Flow - 1383 Well
S Elevation - 8 Proof Flow

U
P Location - Test Hydrant Located on Brackett Street 20' from Project Site
P
L Source of Information - Portland Water District
Y

C Commodity Class Location
O Storage Ht. Area Aisle W.
M Storage Method: Solid Piled % Palletized % Rack
M
() Single Row () Conven. Pallet () Auto. Storage () Encap.
S R () Double Row () Slave Pallet () Solid Shelf () Non
T A () Mult. Row () Open Shelf
O C
R K Flue Spacing Clearance:Storage to Ceiling
A Longitudinal Transverse
G
E Horizontal Barriers Provided:


Water Supply Curve (C)

High Tech Fire Protection
First Floor Kitchen Calc.

Page 2
Date 4/19/2011

City Water Supply:
C1 - Static Pressure 77
C2 - Residual Pressure: 71
C2 - Residual Flow 1383

Demand:
D1 - Elevation 6.063
D2 - System Flow 255.679
D2 - System Pressure 60.597
Hose (Adj City)
Hose (Demand) 250
D3 - System Demand 505.679
Safety Margin 15.470



Fittings Used Summary

High Tech Fire Protection
First Floor Kitchen Calc.

Page 3
Date 4/19/2011

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zib	Wilkins 350A	Fitting generates a Fixed Loss Based on Flow																			

Pressure / Flow Summary - STANDARD

High Tech Fire Protection
First Floor Kitchen Calc.

Page 4
Date 4/19/2011

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
301	18.0	5.6	17.17	na	23.21	0.15	130	7.0
C1	18.0		18.22	na				
302	22.0	5.6	7.17	na	15.0	0.15	100	7.0
303	22.0	5.6	7.17	na	15.0	0.15	100	7.0
C2	22.0		7.94	na				
C3	18.0		11.32	na				
304	18.0	5.6	13.51	na	20.59	0.15	130	7.0
C4	18.0		13.72	na				
305	18.0	5.6	14.94	na	21.65	0.15	130	7.0
C5	18.0		18.22	na				
306	18.0	5.6	12.89	na	20.1	0.15	130	7.0
307	18.0	5.6	14.47	na	21.3	0.15	130	7.0
C6	18.0		18.42	na				
308	18.0	5.6	13.14	na	20.3	0.15	130	7.0
309	18.0	5.6	14.75	na	21.51	0.15	130	7.0
C7	18.0		18.77	na				
310	18.0	5.6	19.34	na	24.62	0.15	100	7.0
311	18.0	5.6	20.41	na	25.3	0.15	100	7.0
312	18.0	5.6	23.44	na	27.11	0.15	100	7.0
X1	18.0		28.58	na				
X2	7.0		36.11	na				
TOR	7.0		42.44	na				
BOR	1.0		49.98	na				
BASE	5.0		61.52	na				
H1	6.0		61.3	na				
H2	8.0		60.44	na				
TEST	8.0		60.6	na	250.0			

The maximum velocity is 15.52 and it occurs in the pipe between nodes 309 and C7

Final Calculations - Hazen-Williams

High Tech Fire Protection
First Floor Kitchen Calc.

Page 5
Date 4/19/2011

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
301 to C1	23.20 23.2	1.049 120 0.1713	1T	5.0 0.0 0.0	1.100 5.000 6.100	17.171 0.0 1.045			K Factor = 5.60 Vel = 8.61	
C1 to C5	0.0 23.2	2.635 120 0.0020		0.0 0.0 0.0	1.000 0.0 1.000	18.216 0.0 0.002			Vel = 1.36	
	0.0 23.20					18.218			K Factor = 5.44	
302 to C2	15.00 15.0	1.049 120 0.0764	1T	5.0 0.0 0.0	5.000 5.000 10.000	7.175 0.0 0.764			K Factor = 5.60 Vel = 5.57	
	0.0 15.00					7.939			K Factor = 5.32	
303 to C2	15.00 15.0	1.049 120 0.0764	1T	5.0 0.0 0.0	5.000 5.000 10.000	7.175 0.0 0.764			K Factor = 5.60 Vel = 5.57	
C2 to C3	15.00 30.0	1.049 120 0.2755	1E	2.0 0.0 0.0	4.000 2.000 6.000	7.939 1.732 1.653			Vel = 11.14	
C3 to C4	0.0 30.0	1.049 120 0.2756	1T	5.0 0.0 0.0	3.700 5.000 8.700	11.324 0.0 2.398			Vel = 11.14	
	0.0 30.00					13.722			K Factor = 8.10	
304 to C4	20.58 20.58	1.38 120 0.0362		0.0 0.0 0.0	5.800 0.0 5.800	13.512 0.0 0.210			K Factor = 5.60 Vel = 4.41	
C4 to 305	30.00 50.58	1.38 120 0.1905		0.0 0.0 0.0	6.400 0.0 6.400	13.722 0.0 1.219			Vel = 10.85	
305 to C5	21.65 72.23	1.38 120 0.3682	1T	6.0 0.0 0.0	2.900 6.000 8.900	14.941 0.0 3.277			K Factor = 5.60 Vel = 15.49	
C5 to C6	23.21 95.44	2.635 120 0.0264		0.0 0.0 0.0	7.500 0.0 7.500	18.218 0.0 0.198			Vel = 5.62	
	0.0 95.44					18.416			K Factor = 22.24	
306 to 307	20.10 20.1	1.049 120 0.1314		0.0 0.0 0.0	12.000 0.0 12.000	12.889 0.0 1.577			K Factor = 5.60 Vel = 7.46	
307 to C6	21.30 41.4	1.049 120 0.5000	1T	5.0 0.0 0.0	2.900 5.000 7.900	14.466 0.0 3.950			K Factor = 5.60 Vel = 15.37	
C6 to C7	95.44 136.84	2.635 120 0.0514		0.0 0.0 0.0	6.900 0.0 6.900	18.416 0.0 0.355			Vel = 8.05	
	0.0									

Final Calculations - Standard

High Tech Fire Protection
First Floor Kitchen Calc.

Page 6
Date 4/19/2011

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	136.84					18.771			K Factor = 31.58	
308	20.30	1.049		0.0	12.000	13.143			K Factor = 5.60	
to		120		0.0	0.0	0.0				
309	20.3	0.1338		0.0	12.000	1.606			Vel = 7.54	
309	21.51	1.049	1T	5.0	2.900	14.749			K Factor = 5.60	
to		120		0.0	5.000	0.0				
C7	41.81	0.5091		0.0	7.900	4.022			Vel = 15.52	
C7	136.84	2.635		0.0	6.700	18.771				
to		120		0.0	0.0	0.0				
310	178.65	0.0842		0.0	6.700	0.564			Vel = 10.51	
310	24.62	2.635		0.0	10.000	19.335			K Factor = 5.60	
to		120		0.0	0.0	0.0				
311	203.27	0.1070		0.0	10.000	1.070			Vel = 11.96	
311	25.30	2.635	1V	5.903	16.900	20.405			K Factor = 5.60	
to		120		0.0	5.903	0.0				
312	228.57	0.1330		0.0	22.803	3.032			Vel = 13.45	
312	27.11	2.635	1V	5.903	10.700	23.437			K Factor = 5.60	
to		120	1X	14.827	20.730	0.0				
X1	255.68	0.1636		0.0	31.430	5.141			Vel = 15.04	
X1	0.0	2.635	1V	5.903	11.000	28.578				
to		120		0.0	5.903	4.764				
X2	255.68	0.1635		0.0	16.903	2.764			Vel = 15.04	
X2	0.0	2.635	2V	11.807	26.900	36.106				
to		120		0.0	11.807	0.0				
TOR	255.68	0.1636		0.0	38.707	6.331			Vel = 15.04	
TOR	0.0	2.635	1Fsp	0.0	6.000	42.437				
to		120	1V	5.903	5.903	5.599			* Fixed loss = 3	
BOR	255.68	0.1636		0.0	11.903	1.947			Vel = 15.04	
BOR	0.0	2.635	1E	8.237	8.000	49.983				
to		120	1V	5.903	14.140	7.920			* Fixed loss = 9.652	
BASE	255.68	0.1636	1Zib	0.0	22.140	3.621			Vel = 15.04	
BASE	0.0	6.16	1G	4.304	60.000	61.524				
to		140	1T	43.037	47.341	-0.433				
H1	255.68	0.0020		0.0	107.341	0.211			Vel = 2.75	
H1	0.0	8.27		0.0	20.000	61.302				
to		140		0.0	0.0	-0.866				
H2	255.68	0.0004		0.0	20.000	0.009			Vel = 1.53	
H2	0.0	6.16	1E	20.084	10.000	60.445				
to		140	1G	4.304	67.425	0.0				
TEST	255.68	0.0020	1T	43.037	77.425	0.152			Vel = 2.75	
	250.00								Qa = 250.00	
	505.68					60.597			K Factor = 64.96	



... Fire Protection by Computer Design

High Tech Fire Protection
84 Hackett Mills Road
P.O. Box 156
Minot, Maine 04258-0156
998-2551

Job Name : First Floor Dining Area Calc.
Building : 231 York Street
Location : 231 York Street
System : NFPA-13
Contract : 031511-2
Data File : First Floor Dining Area Calc.wxf

Hydraulic Design Information Sheet

Name - First Floor Dining Area Calc. Date - 4/19/2011
Location - 231 York Street
Building - 231 York Street
Contractor - High Tech Fire Protection System No. - NFPA-13
Calculated By - Jeremy Foss Contract No. - 031511-2
Construction: (X) Combustible () Non-Combustible Drawing No. - FP-1.1
Occupancy - Dining Area Ceiling Height - 8'-11"

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve
S Other
T Specific Ruling Made By Date

E
M Area of Sprinkler Operation - 900 System Type Sprinkler/Nozzle
Density - .1 (X) Wet Make Globe
D Area Per Sprinkler - 225 () Dry Model GL5601
E Elevation at Highest Outlet - 18.500 () Deluge Size 1/2"
S Hose Allowance - Inside () Preaction K-Factor 5.6
I Rack Sprinkler Allowance - () Other Temp.Rat.155
G Hose Allowance - Outside - 100
N

Note

Calculation Flow Required - 277 Press Required - 60
Summary C-Factor Used: 150 Overhead 150 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 5/26/2004 Cap. -
T Time of Test - Rated Cap.- Elev.-
E Static Press - 77 @ Press -
R Residual Press - 71 Elev. - Well
Flow - 1383 Proof Flow
S Elevation - 8

U
P Location - Test Hydrant Located on Brackett Street 20' from Project Site
P
L Source of Information - Portland Water District
Y

C Commodity Class Location
O Storage Ht. Area Aisle W.
M Storage Method: Solid Piled % Palletized % Rack
M
S R () Single Row () Conven. Pallet () Auto. Storage () Encap.
T A () Double Row () Slave Pallet () Solid Shelf () Non
O C () Mult. Row () Open Shelf
R K Flue Spacing Clearance:Storage to Ceiling
A Longitudinal Transverse
G
E Horizontal Barriers Provided:


Water Supply Curve (C)

High Tech Fire Protection
First Floor Dining Area Calc.

Page 2
Date 4/19/2011

City Water Supply:
C1 - Static Pressure 77
C2 - Residual Pressure: 71
C2 - Residual Flow : 1383

Demand:
D1 - Elevation 4.548
D2 - System Flow 176.675
D2 - System Pressure 60.058
Hose (Adj City)
Hose (Demand) 100
D3 - System Demand 276.675
Safety Margin 16.636



Fittings Used Summary

High Tech Fire Protection
First Floor Dining Area Calc.

Page 3
Date 4/19/2011

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N	CPVC 90' Ell Harvel-Spears	7	7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
R	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zib	Wilkins 350A	Fitting generates a Fixed Loss Based on Flow																			

Pressure / Flow Summary - STANDARD

High Tech Fire Protection
First Floor Dining Area Calc.

Page 4
Date 4/19/2011

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	5.6	16.14	na	22.5	0.1	225	7.0
DP2	-1.0	5.6	16.14	na	22.5	0.1	225	7.0
201	18.5	K = K @ EQ01	16.39	na	22.5			
202	18.5	K = K @ EQ02	17.06	na	23.08			
B1	18.5		19.69	na				
B2	18.0		22.25	na				
203	18.5	K = K @ EQ01	19.56	na	24.58			
B3	18.5		22.01	na				
B4	18.0		22.77	na				
204	18.5	K = K @ EQ01	18.62	na	23.99			
205	18.5	K = K @ EQ02	19.38	na	24.6			
B5	18.5		23.04	na				
B6	18.0		25.19	na				
206	18.5	K = K @ EQ01	23.06	na	26.69			
B7	18.5		25.91	na				
B8	18.0		26.76	na				
B9	18.0		29.55	na				
207	18.0	K = K @ EQ01	31.58	na	31.23			
B10	18.0		32.51	na				
X1	18.0		36.9	na				
X2	7.0		43.06	na				
TOR	7.0		46.25	na				
BOR	1.0		52.83	na				
BASE	5.0		61.17	na				
H1	6.0		60.84	na				
H2	8.0		59.98	na				
TEST	8.0		60.06	na	100.0			

The maximum velocity is 30.57 and it occurs in the pipe between nodes B8 and B9

Final Calculations - Hazen-Williams

High Tech Fire Protection
First Floor Dining Area Calc.

Page 5
Date 4/19/2011

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	22.50 22.5	1.101 150 0.0846	1N 7.0 0.0 0.0	1.000 7.000 8.000	16.143 -0.433 0.677			K Factor = 5.60	
	0.0 22.50							Vel = 7.58	
					16.387			K Factor = 5.56	
DP2 to EQ02	22.50 22.5	1.101 150 0.0847	1O 5.0 0.0 0.0	1.000 5.000 6.000	16.143 -0.433 0.508			K Factor = 5.60	
	0.0 22.50							Vel = 7.58	
					16.218			K Factor = 5.59	
201 to 202	22.50 22.5	1.101 150 0.0846	1R 1.0 0.0 0.0	7.000 1.000 8.000	16.387 0.0 0.677			K Factor @ node EQ01	
								Vel = 7.58	
202 to B1	23.08 45.58	1.101 150 0.3123	1O 5.0 0.0 0.0	3.400 5.000 8.400	17.064 0.0 2.623			K Factor @ node EQ02	
								Vel = 15.36	
B1 to B2	0.0 45.58	1.101 150 0.3123	1N 7.0 0.0 0.0	0.500 7.000 7.500	19.687 0.217 2.342			Vel = 15.36	
B2 to B4	0.0 45.58	1.394 150 0.0991	1R 1.0 0.0 0.0	4.300 1.000 5.300	22.246 0.0 0.525			Vel = 9.58	
	0.0 45.58							K Factor = 9.55	
					22.771			K Factor @ node EQ01	
203 to B3	24.58 24.58	1.101 150 0.0997	2N 14.0 0.0 0.0	10.500 14.000 24.500	19.564 0.0 2.442			Vel = 8.28	
B3 to B4	0.0 24.58	1.101 150 0.0996	1O 5.0 0.0 0.0	0.500 5.000 5.500	22.006 0.217 0.548			Vel = 8.28	
B4 to B6	45.58 70.16	1.394 150 0.2198	1R 1.0 0.0 0.0	10.000 1.000 11.000	22.771 0.0 2.418			Vel = 14.75	
	0.0 70.16							K Factor = 13.98	
					25.189			K Factor @ node EQ01	
204 to 205	23.99 23.99	1.101 150 0.0952	1R 1.0 0.0 0.0	7.000 1.000 8.000	18.622 0.0 0.762			Vel = 8.08	
205 to B5	24.59 48.58	1.101 150 0.3514	1N 7.0 0.0 0.0	3.400 7.000 10.400	19.384 0.0 3.655			K Factor @ node EQ02	
								Vel = 16.37	
B5 to B6	0.0 48.58	1.101 150 0.3515	1O 5.0 0.0 0.0	0.500 5.000 5.500	23.039 0.217 1.933			Vel = 16.37	
B6 to B8	70.17 118.75	1.394 150 0.5819	1R 1.0 0.0 0.0	1.700 1.000 2.700	25.189 0.0 1.571			Vel = 24.96	
	0.0								

Final Calculations - Standard

High Tech Fire Protection
First Floor Dining Area Calc.

Page 6
Date 4/19/2011

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	118.75				26.760			K Factor = 22.96	
206 to B7	26.69	1.101 150 0.1160	2N 14.0 0.0 0.0	10.500 14.000 24.500	23.062 0.0 2.843			K Factor @ node EQ01	
B7 to B8	0.0	1.101 150 0.1160	1O 5.0 0.0 0.0	0.500 5.000 5.500	25.905 0.217 0.638			Vel = 8.99	
B8 to B9	118.75	1.394 150 0.8470	1R 1.0 0.0 0.0	2.300 1.000 3.300	26.760 0.0 2.795			Vel = 8.99	
B9 to B10	0.0	2.003 150 0.1449	1N 11.0 1R 1.0 0.0	8.400 12.000 20.400	29.555 0.0 2.956			Vel = 30.57	
	0.0								
	145.44				32.511			K Factor = 25.51	
207 to B10	31.23	1.101 150 0.1552	1O 5.0 0.0 0.0	1.000 5.000 6.000	31.580 0.0 0.931			K Factor @ node EQ01	
B10 to X1	145.45	2.003 150 0.2077	2R 2.0 1X 11.02 0.0	8.100 13.020 21.120	32.511 0.0 4.387			Vel = 10.52	
X1 to X2	0.0	2.635 120 0.0825	1V 5.903 0.0 0.0	11.000 5.903 16.903	36.898 4.764 1.395			Vel = 17.99	
X2 to TOR	0.0	2.635 120 0.0826	2V 11.807 0.0 0.0	26.900 11.807 38.707	43.057 0.0 3.196			Vel = 10.39	
TOR to BOR	0.0	2.635 120 0.0825	1Fsp 0.0 1V 5.903 0.0	6.000 5.903 11.903	46.253 5.599 0.982			* Fixed loss = 3 Vel = 10.39	
BOR to BASE	0.0	2.635 120 0.0825	1E 8.237 1V 5.903 1Zib 0.0	8.000 14.140 22.140	52.834 6.508 1.827			* Fixed loss = 8.24 Vel = 10.39	
BASE to H1	0.0	6.16 140 0.0010	1G 4.304 1T 43.037 0.0	60.000 47.341 107.341	61.169 -0.433 0.107			Vel = 1.90	
H1 to H2	0.0	8.27 140 0.0002		20.000 0.0 20.000	60.843 -0.866 0.004			Vel = 1.06	
H2 to TEST	0.0	6.16 140 0.0010	1E 20.084 1G 4.304 1T 43.037	10.000 67.425 77.425	59.981 0.0 0.077			Vel = 1.90	
	100.00							Qa = 100.00	
	276.68				60.058			K Factor = 35.70	



. . . Fire Protection by Computer Design

High Tech Fire Protection
84 Hackett Mills Road
P.O. Box 156
Minot, Maine 04258-0156
998-2551

Job Name : Second Floor Calc.
Building : 231 York Street
Location : 231 York Street
System : NFPA-13
Contract : 031511-2
Data File : Second Floor Calc.wxf

Hydraulic Design Information Sheet

Name - Second Floor Calc. Date - 4/19/2011
Location - 231 York Street
Building - 231 York Street
Contractor - High Tech Fire Protection
Calculated By - Jeremy Foss
Construction: (X) Combustible () Non-Combustible
Occupancy - Future Office Space

System No. - NFPA-13
Contract No. - 031511-2
Drawing No. - FP-1.1
Ceiling Height - Varies

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve
S Other
T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 510	System Type	Sprinkler/Nozzle
	Density	- .1	(X) Wet	Make Tyco
D	Area Per Sprinkler	- 240	() Dry	Model BB3
E	Elevation at Highest Outlet	- 31.500	() Deluge	Size 1/2"
S	Hose Allowance - Inside	-	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	-	() Other	Temp.Rat.212
G	Hose Allowance - Outside	- 100		

N Note

Calculation Flow Required - 228 Press Required - 66
Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 5/26/2004		Cap. -
T	Time of Test -	Rated Cap.-	Elev.-
E	Static Press - 77	@ Press -	
R	Residual Press - 71	Elev. -	Well
	Flow - 1383		Proof Flow
S	Elevation - 8		

U
P Location - Test Hydrant Located on Brackett Street 20' from Project Site
P
L Source of Information - Portland Water District
Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	Solid Piled %	Palletized % Rack
M	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf
O			
R	Flue Spacing	Clearance:Storage to Ceiling	
A	Longitudinal	Transverse	
G			
E	Horizontal Barriers Provided:		


Water Supply Curve (C)

High Tech Fire Protection
Second Floor Calc.

Page 2
Date 4/19/2011

City Water Supply:
C1 - Static Pressure 77
C2 - Residual Pressure: 71
C2 - Residual Flow 1383

Demand:
D1 - Elevation 10.178
D2 - System Flow 127.873
D2 - System Pressure 65.982
Hose (Adj City)
Hose (Demand) 100
D3 - System Demand 227.873
Safety Margin 10.805



Fittings Used Summary

High Tech Fire Protection
Second Floor Calc.

Page 3
Date 4/19/2011

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N	CPVC 90' Ell Harvel-Spears	7	7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
Zib	Wilkins 350A	Fitting generates a Fixed Loss Based on Flow																			

Pressure / Flow Summary - STANDARD

High Tech Fire Protection
Second Floor Calc.

Page 4
Date 4/19/2011

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
101	31.5	5.6	20.0	na	25.04	0.1	240	20.0
102	31.5	5.6	20.1	na	25.11	0.1	240	20.0
103	31.5	5.6	20.46	na	25.33	0.1	240	20.0
104	31.5	5.6	21.23	na	25.8	0.1	240	20.0
105	31.5	5.6	22.55	na	26.59	0.1	240	20.0
A1	31.5		32.59	na				
A2	18.0		40.58	na				
X1	18.0		46.12	na				
X2	7.0		51.65	na				
TOR	7.0		53.4	na				
BOR	1.0		59.54	na				
BASE	5.0		67.18	na				
H1	6.0		66.8	na				
H2	8.0		65.94	na				
TEST	8.0		65.98	na	100.0			

The maximum velocity is 18.46 and it occurs in the pipe between nodes 105 and A1

Final Calculations - Hazen-Williams

High Tech Fire Protection
Second Floor Calc.

Page 5
Date 4/19/2011

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
101	25.04	1.682		0.0	5.000	20.000			K Factor = 5.60	
to		120		0.0	0.0	0.0				
102	25.04	0.0198		0.0	5.000	0.099			Vel = 3.62	
102	25.11	1.682		0.0	5.000	20.099			K Factor = 5.60	
to		120		0.0	0.0	0.0				
103	50.15	0.0714		0.0	5.000	0.357			Vel = 7.24	
103	25.33	1.682		0.0	5.100	20.456			K Factor = 5.60	
to		120		0.0	0.0	0.0				
104	75.48	0.1525		0.0	5.100	0.778			Vel = 10.90	
104	25.80	1.682		0.0	5.000	21.234			K Factor = 5.60	
to		120		0.0	0.0	0.0				
105	101.28	0.2624		0.0	5.000	1.312			Vel = 14.62	
105	26.59	1.682	1E	4.95	10.000	22.546			K Factor = 5.60	
to		120	1T	9.9	14.850	0.0				
A1	127.87	0.4040		0.0	24.850	10.040			Vel = 18.46	
A1	0.0	2.157	1V	4.307	13.500	32.586				
to		120		0.0	4.307	5.847				
A2	127.87	0.1203		0.0	17.807	2.143			Vel = 11.23	
A2	0.0	2.003	2O	20.0	17.500	40.576				
to		150	1N	11.0	31.000	0.0				
X1	127.87	0.1142		0.0	48.500	5.539			Vel = 13.02	
X1	0.0	2.635	1V	5.903	11.000	46.115				
to		120		0.0	5.903	4.764				
X2	127.87	0.0454		0.0	16.903	0.767			Vel = 7.52	
X2	0.0	2.635	2V	11.807	26.900	51.646				
to		120		0.0	11.807	0.0				
TOR	127.87	0.0454		0.0	38.707	1.758			Vel = 7.52	
TOR	0.0	2.635	1Fsp	0.0	6.000	53.404				
to		120	1V	5.903	5.903	5.599			* Fixed loss = 3	
BOR	127.87	0.0453		0.0	11.903	0.539			Vel = 7.52	
BOR	0.0	2.635	1E	8.237	8.000	59.542				
to		120	1V	5.903	14.140	6.630			* Fixed loss = 8.362	
BASE	127.87	0.0454	1Zib	0.0	22.140	1.006			Vel = 7.52	
BASE	0.0	6.16	1G	4.304	60.000	67.178				
to		140	1T	43.037	47.341	-0.433				
H1	127.87	0.0005		0.0	107.341	0.058			Vel = 1.38	
H1	0.0	8.27		0.0	20.000	66.803				
to		140		0.0	0.0	-0.866				
H2	127.87	0.0002		0.0	20.000	0.003			Vel = 0.76	
H2	0.0	6.16	1E	20.084	10.000	65.940				
to		140	1G	4.304	67.425	0.0				
TEST	127.87	0.0005	1T	43.037	77.425	0.042			Vel = 1.38	
	100.00								Qa = 100.00	
	227.87					65.982			K Factor = 28.05	