Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/16/16

GENERAL NOTES

NOTES ON THESE DRAWINGS ARE NOT INTENDED TO REPLACE SPECIFICATIONS. SEE SPECIFICATIONS FOR REQUIREMENTS IN ADDITION TO DRAWING NOTES.

STRUCTURAL DRAWINGS SHALL BE USED IN CONJUNCTION WITH PROJECT SPECIFICATIONS AND THE ARCHITECTURAL, MECHANICAL, ELECTRICAL, PLUMBING, FIRE PROTECTION, EQUIPMENT, SITE AND SHOP DRAWINGS. CONSULT THESE DRAWINGS FOR LOCATIONS AND DIMENSIONS OF CHASES, INSERTS, SLEEVES, DEPRESSIONS AND OTHER DETAILS NOT SHOWN ON THE STRUCTURAL DRAWINGS.

ALL DIMENSIONS, ELEVATIONS AND CONDITIONS MUST BE VERIFIED IN THE FIELD BY THE GENERAL CONTRACTOR. ANY DISCREPANCY SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER BEFORE PROCEEDING WITH THE AFFECTED PART OF THE WORK. THE CONTRACTOR SHALL DETERMINE ALL NECESSARY DIMENSIONS, ELEVATIONS AND CONDITIONS REQUIRED FOR THE FABRICATION AND ERECTION OF THE BUILDING'S COMPONENTS PRIOR TO THE SUBMISSION OF SHOP DRAWINGS. ALL SHOP DRAWINGS SHALL ACCURATELY REFLECT THE GENERAL CONTRACTOR'S VERIFICATION OF FIELD CONDITIONS.

SHOP DRAWINGS SHALL BE ORIGINAL DRAWINGS PREPARED BY THE GENERAL CONTRACTOR OR A SUBCONTRACTOR. REPRODUCTION OF ANY STRUCTURAL DRAWING FOR USE AS A SHOP DRAWING IS NOT ACCEPTABLE.

THE STRUCTURE IS DESIGNED TO BE SELF-SUPPORTING AND STABLE AFTER THE BUILDING IS COMPLETE. IT IS SOLELY THE GENERAL CONTRACTOR'S RESPONSIBILITY TO DETERMINE ERECTION PROCEDURES AND SEQUENCING TO ENSURE THE THE SAFETY OF THE BUILDING AND IT'S COMPONENTS DURING ERECTION. THIS INCLUDES THE ADDITION OF NECESSARY SHORING, SHEETING, TEMPORARY BRACING, GUYS AND/OR TIEDOWNS. SUCH MATERIAL SHALL REMAIN THE PROPERTY OF THE GENERAL CONTRACTOR AFTER COMPLETION OF THE BUILDING.

SECTIONS AND DETAILS SHOWN ON THE STRUCTURAL DRAWINGS SHALL BE CONSIDERED TYPICAL AND USED IN SIMILAR CONDITIONS.

THE GENERAL CONTRACTOR AND ALL SUBCONTRACTORS SHALL FOLLOW ALL APPLICABLE FEDERAL, STATE AND MUNICIPAL REGULATIONS INCLUDING THE FEDERAL DEPARTMENT OF LABOR OCCUPATIONAL SAFETY AND HEALTH ACT.

DESIGN CRITERIA

BUILDING CODE: 2009 INTERNATIONAL BUILDING CODE

DESIGN LOADS:

LIVE LOADS	
RESIDENTIAL UNITS AND CORRIDORS SERVING THEM	40 PSF
STAIRS AND EXITS AND BALCONY	100 PSF
PUBLIC ROOMS AND CORRIDORS SERVING THEM	100 PSF
SNOW LOAD	
GROUND SNOW LOAD, Pg	60 PSF
SNOW EXPOSURE FACTOR, Ce	1.0
SNOW LOAD IMPORTANCE FACTOR, Is	1.0
THERMAL FACTOR, Ct	1.0
FLAT ROOF SNOW LOAD, Pf	42 PSF
WIND LOAD	
BASIC WIND SPEED (3 SEC GUST), V3s	100 MPH
WIND IMPORTANCE FACTOR, Iw	1.0
BUILDING CATEGORY	I
EXPOSURE CATEGORY	B
EARTHQUAKE DESIGN DATA	
SEISMIC IMPORTANCE FACTOR, Ie	1.0
MAPPED SPECTRAL RESPONSE ACCELERATIONS	
0.2 SEC PERIOD, Ss	0.241
1 SEC PERIOD, S1	0.078
SITE CLASS	C
SPECTRAL RESPONSE COEFFICIENTS	
0.2 PERIOD 5% DAMPED, Sds	0.193
1 SEC PERIOD 5% DAMPED, Sd1	0.088
SEISMIC DESIGN CATEGORY	B
BASIC SEISMIC-FORCE-RESISTING SYSTEM	DUAL: LIGHT-FRAMED WALLS WITH SHEAR PANELS AND ORDINARY STEEL MOMENT FRAME
DESIGN BASE SHEAR	13.2 KIPS
SEISMIC RESPONSE COEFFICIENT, Cs	0.055
DEFLECTION AMPLIFICATION FACTOR, Cd	3.0
RESPONSE MODIFICATION COEFFICIENT, R	3.5
SYSTEM OVERSTRENGTH FACTOR, Ω0	3.0
ANALYSIS PROCEDURE	EQUIVALENT LATERAL FORCE

COLUMN SCHEDULE

COLUMN MARK	SIZE	BOT. OF BASE PL ELEV.	BASE PL TYPE	TOP OF COLUMN ELEV.
1-A	W12x40	92'-9"	A	108'-1 3/4"
2-A	W12x40	93'-9"	A	108'-1 3/4"
3-A	W12x40	94'-9"	A	108'-1 3/4"
1-B	HSS5x5x0.25	95'-1"	B	107'-9 1/4"
2-C	HSS6x6x0.25	97'-4 1/2"	C	107'-9 1/4"
3-B	HSS5x5x0.25	97'-9"	B	107'-9 1/4"

BASE PLATE DETAILS
3/4"=1'-0"
HOLE DIA = 1 1/16"
HOLE EDGE DIST = 1 1/2" U.N.O.

TYPICAL ANCHOR ROD DETAILS
3/4"=1'-0"

FOOTING SCHEDULE

MARK	SIZE	REINFORCING
F1	4'-0" x 4'-0" x 1'-3"	5 #6 E.W. BOT.
F2	6'-0" x 6'-0" x 1'-3"	7 #6 E.W. BOT.

STATE OF MAINE DAVID TERRAULT 4840 PROFESSIONAL ENGINEER

Prepared For:
TATE STREET PARTNERSHIP, LLC
17 Chestnut Street
Portland, Maine 04101

Consulting Engineer:
STRUCTURAL DESIGN CONSULTING
2696 Lake Shore Road
Unit 1-130
Gilford, NH
03249
Tel 603.293.8038

Architect:
ARCHETYPE Architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056

Project:
WEST PORT LOFTS
22-28 Tate Street
Portland, Maine

Revisions:
Issued for Foundation Permit 03/21/16

Scale: As Noted

Date: 21 MAR 2016

GENERAL NOTES AND SCHEDULES

S0.01