Protection Professionals

325 U.S. Route 1
Falmouth, ME 04105
Ph 207-775-5755
Fax 207-781-2064

Device List

No.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 09/26/16

List Date
4/29/2016

Bill To Name / Address	Job Site
Kevin's Electric Attn: 837 Portland Road Saco, ME 04072-9663	West Port Lofts Condominiums 22 Tate Street Portland, ME 04102

CHANGING THIS DEVICE LIST DOES NOT ALTER THE ORIGINAL ESTIMATE
Attach copy to Purchase Order for accounting

Estimate No.

Item	Description	Qty To Order	Qty Ordered
	This quote is based upon a fire alarm sprinkler monitoring system only.		
PFC-6006-R-3992334	Sprinkler system Conventional fire panel, 6 zones, 1 amp power supply, One NAC at 0.5 amps. 0.5 AUX power	1	
Bat 12-7	12V 7AH Batteries SEC-1075	2	
IM-RJ31XSET	IM-RJ31XSET	2	
E120V-GT	Space Age 120V Surge Protector plus lockout and circuit breaker labels for FACP	1	
BK-2WB	Smoke Detector 2-wire over fire panel	1	
RMS-1T-KL-LP	Pull station WS-93 key	1	
HS-24W-WP-4890060	Horn/strobe, weatherproof, red	1	
SSU00672	Fire Document box 12 inches wide X 13.1 inches high X 2.25 inches deep, CAT 30 keyed	1	
WS-93 lockset	Potter lock set	1	
	Intercom system; All door hardware is supplied by others.		
AM492/08P	Intercom panel,8 buttons and name holders, postal release	1	
OF191	Trim Frame, one gang	1	
OH191	Intercom back box, single gang	1	
PK543A	Intercom amplifier	1	
SS102A	Transformer 16VAC 10VA	1	
IR104E	Intercom Station (4-wire)	8	
IH101	Housing 2" IR series	8	
	5.5% Maine Sales Tax		

Ordered By: _____ **Date:** _____

Received By: _____ **Date:** _____