DEAN & ALLYN, INC.

FIRE PROTECTION • SPECIAL HAZARD

DATE: 6/7/16

SKETCH BY: D.N.

JOB NAME: 22 TATE ST

JOB LOCATION: PORTLAND

FIRE SPRINKLER ALARM SWITCHES

ITEM	QTY	DESCRIPT
1.	3	TAMPER (SUPERVISORY)
2.	2	FLOW (ALARM)
3.	1	LOW AIR (SUPERVISORY)
4.	1	EXTERIOR BELL

AIR COMPRESSOR
W/PRESSURE SWITCH
- NO FA CONNECTION -

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 09/26/16
CITY OF PORTLAND, MAINE RESURGAM