

PARTITION TYPE	FIRE RATINGS AND ACOUSTICAL RATINGS	WALL PARTITION SCHEDULE	
		GENERAL WALL DESCRIPTION	GENERAL PICTORIAL
		<u>TYPICAL INTERIOR NON-BEARING WALL ASSEMBLY</u> 2x4 (2x6 IF INDICATED AS SUCH) WOOD STUDS @ 16" O.C. EXTEND TO 1/2" BELOW UNDERSIDE OF FLOOR JOISTS @ NEW ADDITION ONLY. WOOD STUDS EXTEND TO UNDERSIDE OF EXISTING FLOOR FRAMING ABOVE AT EXISTING BUILDING. CONTINUOUS 3 1/2" SOUND ATTENUATION BATTS WHERE GRAPHICALLY INDICATED ON ENLARGED UNIT PLAN. (1) LAYER 5/8" TYPE "X" GWB ON EACH SIDE TO UNDERSIDE OF FINISH CEILING. AIR SEAL AT CEILING DECK AND FLOOR.	
		SAME AS TYPE 4 BUT PARTIAL HEIGHT: REFER TO INTERIOR ELEVATIONS	
		SIMILAR TO WALL TYPE W/ (1) LAYER 5/8" TYPE "X" GWB ON ONE SIDE ONLY.	
	UL DESIGN NO. U305 1 HOUR	<u>TYPICAL INTERIOR 1 HOUR FIRE RATED WALL ASSEMBLY</u> 2x4 (2x6 IF INDICATED AS SUCH) WOOD STUDS @ 16" O.C. TO UNDERSIDE OF FLOOR SHEATHING, ABOVE AND / OR UNDERSIDE OF ROOF TRUSS ABOVE. (1) LAYER 5/8" TYPE "X" GWB ON EACH SIDE TO UNDERSIDE OF FLOOR SHEATHING ABOVE AND / OR UNDERSIDE OF ROOF TRUSS SYSTEM ABOVE. SEAL TIGHT EACH SIDE. CONTINUOUS 3 1/2" SOUND ATTENUATION BATTS.	
	UL DESIGN NO. U415 1 HOUR STC 49	<u>SHAFT WALL ASSEMBLY</u> 1" LINER PANEL SET BETWEEN 4" USG STEEL C-H STUDS @ 24" O.C. (1) LAYER 5/8" TYPE "X" GWB TAGGED SIDE ONLY SEALED TO UNDERSIDE OF RATED ASSEMBLY ABOVE.	
	UL DESIGN NO. U--- 2 HOUR STC ---	SIMILAR TO WALL TYPE W/ 1" LINER PANEL SET BETWEEN 6" USG STEEL C-H STUDS @ 24" O.C. (2) LAYERS 5/8" TYPE "X" GWB TAGGED SIDE ONLY SEALED TO UNDERSIDE OF RATED ASSEMBLY ABOVE. FIRE SEAL ALL JOINTS AT ALL MASONRY WALLS AND CEILINGS.	
	UL DESIGN NO. U309 1 HOUR STC = 51	<u>CORRIDOR / UNIT WALL ASSEMBLY</u> (1 OR 2) 2x6 WOOD STUDS @ 24" O.C. TO UNDERSIDE OF TOP PLATE. (REFERENCE STRUCTURAL DWGS FOR BEARING WALLS INFORMATION) 1/2" RESILIENT CHANNELS HORIZONTALLY @ 16" O.C. ON CORRIDOR SIDE ONLY. 3 1/2" SOUND ATTENUATION BATTS SOLID BLOCKING AT CEILING LEVEL OR ALTERNATIVE METHOD APPROVED BY IBC. (1) LAYER 5/8" TYPE "X" GWB ON EACH SIDE TO UNDERSIDE OF FLOOR JOIST, SHEATHING, AND / OR UNDERSIDE OF ROOF TRUSS SYSTEM ABOVE. SEE DETAILS. AIR SEAL TIGHT ON EACH SIDE. 4 1/2" SPACE 2x4 WOOD STUDS @ 16" O.C. TO 1/2" BELOW UNDERSIDE OF FLOOR JOISTS - SEE DRAWING AXX/XX FOR SECURE WALL DETAIL. (1) LAYER 5/8" TYPE "X" GWB ON ONE SIDE TO UNDERSIDE OF FINISH CEILING.	
		<u>INTERIOR FURRED WALL</u> EXISTING MASONRY WALL 4" SPACE 2x4 WOOD STUDS @ 16" O.C. ON TAGGED SIDE ONLY. CONTINUOUS 3 1/2" SOUND ATTENUATION BATTS (1) LAYER 5/8" TYPE "X" GWB TAGGED SIDE ONLY.	
		SIMILAR TO WALL TYPE WITHOUT SPACE BETWEEN FACE OF EXISTING MASONRY WALL AND NEW 2x4 WOOD STUDS.	
	SIMILAR TO UL DESIGN NO. U--- 1 HOUR	<u>INTERIOR FURRED WALL AT SHEARWALL ASSEMBLY</u> (1 OR 2) 2x6 WOOD STUDS @ 24" O.C. TO UNDERSIDE OF TOP PLATE. (REFERENCE STRUCTURAL DWGS FOR BEARING WALL INFORMATION) 1/2" PLYWOOD SHEATHING ON CORRIDOR SIDE (REFER TO STRUCT. DWGS FOR DETAIL) 3 1/2" SOUND ATTENUATION BATTS AND 2x SOLID BLOCKING AT CEILING LEVEL OR ALTERNATIVE METHOD APPROVED BY IBC. (1) LAYER 5/8" TYPE "X" GWB ON TAGGED SIDE TO UNDERSIDE OF FLOOR JOIST, SHEATHING, AND / OR UNDERSIDE OF ROOF TRUSS SYSTEM ABOVE, SEE DETAILS. SEAL TIGHT	
		<u>INTERIOR FURRED WALL AT EXISTING WALL ASSEMBLY</u> EXISTING WALL 1/2" RESILIENT CHANNELS HORIZONTALLY @ 16" O.C. (1) LAYER 5/8" TYPE "X" GWB ON EACH SIDE TO UNDERSIDE OF FLOOR JOIST, SHEATHING, AND / OR UNDERSIDE OF ROOF TRUSS SYSTEM ABOVE. SEE DETAILS. AIR SEAL TIGHT ON EACH SIDE.	

PARTITION TYPE	FIRE RATINGS AND ACOUSTICAL RATINGS	WALL PARTITION SCHEDULE	
		GENERAL WALL DESCRIPTION	GENERAL PICTORIAL
	UL DESIGN NO. 2 HOUR STC = 51	<u>TYPICAL CORRIDOR / UNIT WALL ASSEMBLY</u> 2x6 WOOD STUDS @ 24" O.C. TO UNDERSIDE OF TOP PLATE. 1/2" RESILIENT CHANNELS HORIZONTALLY @ 16" O.C. ON CORRIDOR SIDE ONLY. 3 1/2" SOUND ATTENUATION BATTS SOLID BLOCKING AT CEILING LEVEL OR ALTERNATIVE METHOD APPROVED BY IBC. (2) LAYER 5/8" TYPE "X" GWB ON EACH SIDE OF WALL FROM UNDERSIDE OF FLOOR CEILING DECK ABOVE. AIR SEAL SILL AND TOP PLATES TIGHT ON EACH SIDE. AIR SEAL ALL OUTLETS AND FIXTURES	
	UL DESIGN NO. U309 1 HOUR STC = 51	<u>TYPICAL CORRIDOR / UNIT WALL ASSEMBLY</u> (1 OR 2) 2x6 WOOD STUDS @ 24" O.C. TO UNDERSIDE OF TOP PLATE. (REFERENCE STRUCTURAL DWGS FOR BEARING WALLS INFORMATION) 1/2" RESILIENT CHANNELS HORIZONTALLY @ 16" O.C. ON CORRIDOR SIDE ONLY. 3 1/2" SOUND ATTENUATION BATTS SOLID BLOCKING AT CEILING LEVEL OR ALTERNATIVE METHOD APPROVED BY IBC. (1) LAYER 5/8" TYPE "X" GWB ON EACH SIDE TO UNDERSIDE OF FLOOR JOIST, SHEATHING, AND / OR UNDERSIDE OF ROOF TRUSS SYSTEM ABOVE. SEE DETAILS. AIR SEAL TIGHT ON EACH SIDE.	
		SIMILAR TO WALL TYPE A NON-BEARING WALL W/ 2x6 WOOD STUDS @ 24" O.C. TO 1/2" BELOW UNDERSIDE OF FLOOR TRUSS OR ROOF TRUSS SYSTEM. REFER TO DWG AXX DETAIL XX (FIRST FLOOR) AND DETAIL XX (SECOND FLOOR) FOR ADDITIONAL INFORMATION.	
		SIMILAR TO WALL TYPE A NON-BEARING WALL W/ 2x6 WOOD STUDS @ 16" TO UNDERSIDE OF EXISTING FLOOR FRAMING ABOVE AT EXISTING BUILDING.	
		SIMILAR TO WALL TYPE W/ (1) ADDITIONAL LAYER 5/8" TYPE "X" GWB OR (1) ADDITIONAL LAYER 5/8" TYPE "MRX" GWB ON BATHROOM SIDE (TO COVER TUB OR SHOWER ATTACHMENT FLANGE).	
	SIMILAR TO UL DESIGN NO. U309 1 HOUR STC = 51	<u>TYPICAL CORRIDOR / UNIT AT SHEARWALL ASSEMBLY</u> (1 OR 2) 2x6 WOOD STUDS @ 24" O.C. TO UNDERSIDE OF TOP PLATE. (REFERENCE STRUCTURAL DWGS FOR BEARING WALL INFORMATION) 1/2" PLYWOOD SHEATHING ON CORRIDOR SIDE (REFER TO STRUCT. DWGS FOR DETAIL) 3 1/2" RESILIENT CHANNELS HORIZONTALLY @ 16" O.C. ON CORRIDOR SIDE 1/2" SOUND ATTENUATION BATTS AND 2x SOLID BLOCKING AT CEILING LEVEL OR ALTERNATIVE METHOD APPROVED BY IBC. (1) LAYER 5/8" TYPE "X" GWB ON EACH SIDE TO UNDERSIDE OF FLOOR JOIST, SHEATHING, AND / OR UNDERSIDE OF ROOF TRUSS SYSTEM ABOVE, SEE DETAILS. SEAL TIGHT ON EACH SIDE;	
		SIMILAR TO WALL TYPE NOT A WOOD PANEL SHEARWALL	
	UL DESIGN NO. U340 1 HOUR STC = 54	<u>COMMON WALL BETWEEN UNIT WALL ASSEMBLY</u> 2x4 STAGGERED WOOD STUDS @ 12" O.C. (@ 24" O.C. ON EACH SIDE) ON 2x6 WOOD TOP AND BOTTOM PLATES TO UNDERSIDE OF FLOOR SHEATHING ABOVE AND / OR UNDERSIDE OF ROOF TRUSS ABOVE. 1/2" RESILIENT CHANNELS HORIZONTALLY @ 16" O.C. ONE EACH SIDE TO UNDERSIDE OF FLOOR SHEATHING ABOVE AND / OR UNDERSIDE OF ROOF TRUSS ABOVE. (1) LAYER OF 5/8" TYPE "X" GWB EACH SIDE TO UNDERSIDE OF FLOOR SHEATHING ABOVE AND / OR UNDERSIDE OF ROOF TRUSS SYSTEM ABOVE. AIR SEAL GWB AS PER SEALING DETAILS. CONTINUOUS 3 1/2" SOUND ATTENUATION BATTS EACH SIDE OF STAGGERED STUD. PROVIDE 2x SOLID BLOCKING AT CEILING LEVEL OR ALTERNATIVE METHOD APPROVED BY IBC FOR UNIT COMMON WALLS. NOTE: PROVIDE APPROPRIATE SEALANT AT ALL PENETRATIONS AND EDGE CONDITIONS TO ENSURE AIR SEALING AND ACOUSTIC ISOLATION BETWEEN UNITS.	
		SIMILAR TO WALL TYPE W/ (1) ADDITIONAL LAYER 5/8" TYPE "X" GWB OR (1) ADDITIONAL LAYER 5/8" TYPE "MRX" GWB ON BATHROOM SIDE (TO COVER TUB OR SHOWER ATTACHMENT FLANGE).	
	SIMILAR TO UL DESIGN NO. U340 1 HOUR STC = 54	<u>COMMON WALL BETWEEN UNIT AT SHEARWALL ASSEMBLY</u> 2x4 STAGGERED WOOD STUDS @ 12" O.C. (@ 24" O.C. ON EACH SIDE) ON 2x6 WOOD TOP AND BOTTOM PLATES TO UNDERSIDE OF FLOOR SHEATHING ABOVE AND / OR UNDERSIDE OF ROOF TRUSS ABOVE. 1/2" RESILIENT CHANNELS HORIZONTALLY @ 16" O.C. ON ONE SIDE AND 1/2" PLYWOOD SHEATHING ON OTHER SIDE TO UNDERSIDE OF FLOOR SHEATHING ABOVE AND / OR UNDERSIDE OF ROOF TRUSS ABOVE. (1) LAYER OF 5/8" TYPE "X" GWB EACH SIDE TO UNDERSIDE OF FLOOR SHEATHING ABOVE AND / OR UNDERSIDE OF ROOF TRUSS SYSTEM ABOVE, SEE DETAILS. AIR SEAL GWB AS PER SEALING DETAILS. CONTINUOUS 3 1/2" SOUND ATTENUATION BATTS EACH SIDE OF STAGGERED STUD. PROVIDE 2x SOLID BLOCKING AT CEILING LEVEL OR ALTERNATIVE METHOD APPROVED BY IBC FOR UNIT COMMON WALLS. NOTE: PROVIDE APPROPRIATE SEALANT AT ALL PENETRATIONS AND EDGE CONDITIONS TO ENSURE AIR SEALING AND ACOUSTIC ISOLATION BETWEEN UNITS.	
		SIMILAR TO WALL TYPE W/ (1) ADDITIONAL LAYER 5/8" TYPE "X" GWB OR (1) ADDITIONAL LAYER 5/8" TYPE "MRX" GWB ON BATHROOM SIDE (TO COVER TUB OR SHOWER ATTACHMENT FLANGE).	

PARTITION TYPE	FIRE RATINGS AND ACOUSTICAL RATINGS	WALL PARTITION SCHEDULE	
		GENERAL WALL DESCRIPTION	GENERAL PICTORIAL
	1 HOUR RATED SIMILAR TO UL DESIGN NO. U336 STC = 57+	<u>STAIR SHAFT WALL ASSEMBLY</u> UNIT WALL ASSEMBLY 2x6 WOOD STUD FRAMING @ 24" O.C. TO UNDERSIDE OF DECK. (ALIGN FACE OF STUDS WITH EDGE OF FLOOR OPENING). CONTINUOUS SOUND ATTENUATION BATTS. UNIT SIDE OF STUDS: 1/2" RESILIENT CHANNELS @ 16" O.C. HORIZONTALLY (1) LAYER 5/8" TYPE "X" GWB SEALED TO UNDERSIDE OF DECK. SHAFT SEPARATION WALL ASSEMBLY (2) LAYERS OF 1" LINER PANELS SET BETWEEN H-STUDS @ 24" O.C. FROM TOP OF FIRST FLOOR STRUCTURAL CONCRETE SLAB TO UNDERSIDE OF ROOF SHEATHING. STAIR SUPPORT WALL ASSEMBLY 2x4 WOOD STUD FRAMING @ 24" O.C. FROM FROM TOP OF FIRST FLOOR STRUCTURAL CONCRETE SLAB TO UNDERSIDE OF DECK SHEATHING. STAIR SIDE OF STUDS: (1) LAYER 1/2" PLYWOOD SHEATHING. (1) LAYER 5/8" TYPE "X" GWB SEALED TO UNDERSIDE OF DECK. **REFERENCE SHEET A6.02 FOR FURTHER INFORMATION**	
	1 HOUR RATED SIMILAR TO UL DESIGN NO. U336 STC = 57+	<u>STAIR SHAFT WALL ASSEMBLY</u> UNIT WALL ASSEMBLY 2x6 WOOD STUD FRAMING @ 24" O.C. TO UNDERSIDE OF DECK. (ALIGN FACE OF STUDS WITH EDGE OF FLOOR OPENING). CONTINUOUS SOUND ATTENUATION BATTS. UNIT SIDE OF STUDS: 1/2" RESILIENT CHANNELS @ 16" O.C. HORIZONTALLY (1) LAYER 5/8" TYPE "X" GWB SEALED TO UNDERSIDE OF DECK. SHAFT SEPARATION WALL ASSEMBLY (2) LAYERS OF 1" LINER PANELS SET BETWEEN H-STUDS @ 24" O.C. FROM TOP OF FIRST FLOOR STRUCTURAL CONCRETE SLAB TO UNDERSIDE OF ROOF SHEATHING. STAIR SUPPORT WALL ASSEMBLY 2x4 WOOD STUD FRAMING @ 24" O.C. FROM FROM TOP OF FIRST FLOOR STRUCTURAL CONCRETE SLAB TO UNDERSIDE OF DECK SHEATHING. STAIR SIDE OF STUDS: (1) LAYER 1/2" PLYWOOD SHEATHING. (1) LAYER 5/8" TYPE "MRX" GWB SEALED TO UNDERSIDE OF DECK. **REFERENCE SHEET A6.02 FOR FURTHER INFORMATION**	
	1 HOUR RATED SIMILAR TO UL DESIGN NO. U336 STC = 57+	<u>STAIR SHAFT WALL ASSEMBLY</u> CORRIDOR WALL ASSEMBLY (SHEAR WALL) 2x6 WOOD STUD FRAMING @ 24" O.C. TO UNDERSIDE OF DECK. (ALIGN FACE OF STUDS WITH EDGE OF FLOOR OPENING). CONTINUOUS SOUND ATTENUATION BATTS. UNIT SIDE OF STUDS: (1) LAYER 1/2" PLYWOOD SHEATHING. (REFERENCE STRUCTURAL DWGS) 1/2" RESILIENT CHANNELS @ 16" O.C. HORIZONTALLY (1) LAYER 5/8" TYPE "X" GWB SEALED TO UNDERSIDE OF DECK. SHAFT SEPARATION WALL ASSEMBLY (2) LAYERS OF 1" LINER PANELS SET BETWEEN H-STUDS @ 24" O.C. FROM TOP OF FIRST FLOOR STRUCTURAL CONCRETE SLAB TO UNDERSIDE OF ROOF SHEATHING. STAIR SUPPORT WALL ASSEMBLY 2x4 WOOD STUD FRAMING @ 24" O.C. FROM FROM TOP OF FIRST FLOOR STRUCTURAL CONCRETE SLAB TO UNDERSIDE OF DECK SHEATHING. STAIR SIDE OF STUDS: (1) LAYER 1/2" PLYWOOD SHEATHING. (1) LAYER 5/8" TYPE "X" GWB SEALED TO UNDERSIDE OF DECK. **REFERENCE SHEET A6.02 FOR FURTHER INFORMATION**	
GENERAL FIRE RATINGS NOTES:			
<ol style="list-style-type: none"> FIRE SAFING & FIRE STOPPING: <ol style="list-style-type: none"> PROVIDE FIRE SAFING SYSTEM/MATERIAL AT ALL PENETRATIONS THRU FIRE RATED ASSEMBLIES. COORDINATE PROPOSED SYSTEMS & MATERIALS FOR APPROPRIATENESS & COMPATIBILITY W/OTHER BLDG. SYSTEMS, TYPE OF SYSTEM PENETRATED, & APPLICATION. PROVIDE 2x SOLID BLOCKING AT CEILING LEVEL OR ALTERNATE METHOD APPROVED BY IBC 2003 IN UNIT COMMON WALLS. ALL PARTITIONING EXTENDING TO UNDERSIDE OF DECK OR CEILING SHALL BE INSTALLED UTILIZING A SLIP TRACK ALLOWING FOR 3/4" OF STRUCTURAL DEFLECTION. PROVIDE FIRE SAFING SYSTEM/MATERIAL AT TOP OF FIRE RATED PARTITIONS AS REQUIRED TO MAINTAIN THE FIRE RATED CLOSURE OF FIRE RATED PARTITION. FIRE DAMPERS: PROVIDE APPROPRIATELY RATED FIRE DAMPERS AT ALL LOCATIONS WHERE MECHANICAL VENTILATION DUCTS PENETRATE RATED ASSEMBLIES. LINE TYPE KEY: <div> <div>1-HOUR FIRE RATED PARTITION</div> <div>2-HOUR FIRE RATED PARTITION</div> </div> 			
PARTITION SCHEDULE NOTES			
<ol style="list-style-type: none"> PROVIDE MOISTURE RESISTANT TYPE "MRX" GWB AT ALL WALL AND CEILING SURFACES WITHIN ALL BATHROOMS, UTILITY ROOMS, AND JANITORS CLOSETS AND ALL BASEMENT WALL LOCATIONS. PROVIDE TYPE "MRX" GWB TO 4'-0" A.F.F. BEHIND ALL SINK LOCATIONS, TYP. PROVIDE CEILING SUPPORT CHANNELS @ 16" O.C. AT ALL LOCATIONS WHERE MRX BOARD IS USED ON CEILINGS PER ASTM STANDARDS. PROVIDE 5/8" MR GWB BEHIND ALL TUBS AND SHOWERS @ FIRE RATED ASSEMBLIES & EXTERIOR WALLS. PROVIDE AN ADDITIONAL LAYER 5/8" MR GWB TO COVER TUB AND SHOWER FLANGE. COORDINATE DOOR THREAT DEPTH ACCORDINGLY. PROVIDE MIN. 1/2" CLEARANCE BETWEEN CONC. SLAB AND GWB AND SEAL WITH ACOUSTIC SEALANT. REFERENCE AIR SEALING DETAILS <ol style="list-style-type: none"> PROVIDE SILL SEALER INSULATION FOR BOTH TOP AND BOTTOM PLATES OF PARTITION FOR UNIT SEPARATION WALLS AND UNIT/CORRIDOR SEPARATION WALLS, TYP. BRACE WALL ASSEMBLIES TO STRUCTURE ABOVE AT ALL DOORS AND ELSEWHERE AS REQUIRED. PROVIDE SOLID BLOCKING AS INDICATED ON DRAWINGS AND AS REQUIRED BY MANUFACTURER'S EQUIPMENT INCLUDING BUT NOT LIMITED TO KITCHEN CLOSET, TOILET AND BATH ACCESSORIES, CLOSET RODS AND SHELVING, H.C. GRAB BARS, AND WALL MOUNTED DOOR STOPS. PROVIDE CONTINUOUS ACOUSTICAL SEALANT ALONG ALL PERIMETER BUILDING EDGES, UNIT SEPARATION WALLS, AND UNIT/CORRIDOR WALLS, BETWEEN GWB AND THE SURROUNDING FLOOR, WALL AND CEILING ELEMENTS. REFERENCE AIR SEALING DETAILS. PROVIDE CONTINUOUS ACOUSTICAL SEALANT AT ALL PENETRATIONS (I.E. ELECTRICAL BOXES, DUCTS, SPRINKLER HEADS, ETC.) IN WALLS, FLOORS, AND CEILINGS. PROVIDE FIRE RATED SEALANT AT FIRE RATED WALL ASSEMBLIES, HILT OR EQUAL <ol style="list-style-type: none"> WHEN WALL DEVICES (I.E. ELECTRICAL OUTLETS, PIPES, TELEPHONE JACKS, ETC.) OCCUR IN UNIT SEPARATION WALL, PROVIDE CONTINUOUS ACOUSTICAL SEALANT ALONG ALL PERIMETER EDGES AND BACKS OF DEVICES. WHEN WALL PENETRATIONS (I.E. ELECTRICAL OUTLETS, PIPES, TELEPHONE JACKS, ETC.) OCCUR ON OPPOSITE SIDES OF UNIT SEPARATION WALL, OFFSET PENETRATION BY AT LEAST ONE COMPLETE STUD CAVITY OR 24 INCHES, OTHERWISE PROVIDE PUTTY PADS AT BOXES. SEAL ALL PENETRATIONS IN VAPOR BARRIER (EXTERIOR WALLS, ATTIC, AND CONCRETE SLAB-ON-GRADE) AS REQUIRED WITH APPROVED SEALERS, INSULATION, AND TAPES. REFERENCE FLOOR PLAN FOR SPECIFIC PARTITION NOTING AND DETAIL REFERENCING. REFERENCE SPECIFICATIONS FOR ADDITIONAL INFORMATION. 			

CWS Architects

☐ Architecture
☐ Space Planning
☐ Value Design

☐ 434 Cumberland Avenue
Portland, ME 04101
Phone: (207)774-4441
Fax: (207)774-4016

☐ www.CWSarch.com

REGISTERED ARCHITECT
BENEDICT
WALKER
NO. 1947
STATE OF MAINE

☐ Owner:

Children's Hospital Housing Partners, LP
309 Cumberland Ave.
Suite 203
Portland, Maine 04101

☐ CONSTRUCTION MANAGER:

WRIGHT-RYAN CONSTRUCTION
10 DANFORTH STREET
PORTLAND, ME 04101
TEL: (207) 773-3625

ELM TERRACE

68 HIGH STREET
PORTLAND, MAINE

Project No: 09428

☐ Drawing Title:

PARTITION SCHEDULE

Scale: SCALE

Date: ISSUED SEPTEMBER 8, 2011

Revisions:

- MAINE HOUSING CONCEPT SUBMISSION 02-01-2011
- HISTORIC PRESERVATION SUBMISSION 03-23-2011
- 50% MAINEHOUSING REVIEW 04-01-2011
- 90% MAINEHOUSING REVIEW 06-03-2011
- NPS SUBMISSION 07-01-2011
- ISSUED SEPTEMBER 8, 2011

Drawing Number:

A0.01