



PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life • www.portlandmaine.gov

Lee Urban - Director of Planning and Development
Jeanie Bourke - Inspection Division Services Director

May 2, 2007

Gawron Turgeon Architects
Attn: Kristi Woloszyn
29 Black Point Road
Scarborough, ME 04074

RE: 115 Danforth St. – Cutter House - CBL: 044-G-001
Permit # 07-0147

Dear Kristi,

Thank you for your request for waiver for the above property. The following are the facts:

- 1) The Cutter House is a historic building with archaic methods and materials
- 2) The sound transmission separation required in Sec. 1207 of the 2003 IBC does not constitute a distinct life safety hazard according to Sec. 3407 for Historic Buildings.

This letter grants the waiver of the requirements for compliance of Sec. 1207 of the 2003 International Building Code for sound transmission control. It is understood that full code compliance remains for all other portions of the approved building permit # 07-0147.

Yours truly,

Jeanie Bourke
Inspection Services Division Director