

CITY OF PORTLAND, MAINE Department of Building Inspection

Certificate of Occupancy

LOCATION

3 GRAY ST

CBL 044 H004002

Issued to

Irish Heritage Center / Consigli Construction

Date of Issue

10/07/2008

— changed as to use under Building Permit No. 08-0528 has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

First Floor

Use Group: A3 Type: 3B IBC, 2003

Limiting Conditions:

This is a temporary C of O that expires on the earlier of 01/01/09 or until an approved fire alarm system is installed. The occupancy load shall not exceed 299 with crowd managers in-place during occupancy.

This certificate supersedes certificate issued

Approved:

(Date)

Inspector

1,00

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.